One Meridian Boulevard
Suite 2C02

Wyomissing, PA 19610
Telephone +1 610 855 2000
Facsimile +1 610 855 2727
www.worley.com

Santee Cooper – Winyah Generating Station South Ash Pond
Notice of Completion of Closure by Removal of CCR

Santee Cooper is providing notification of completion of closure by removal of CCR for the Winyah Generating Station South Ash Pond in accordance with the United States Environmental Protection Agency (U.S. EPA) Federal Coal Combustion Residuals (CCR) Rule (40 CFR Part 257).

In accordance with §257.102(f)(3) the owner or operator of the CCR unit must obtain certification from a qualified professional engineer verifying that closure has been completed in accordance with the closure plan specified in §257.102(b) and the requirements of §257.102. §257.102(c) states that closure by removal of CCR is complete when:

1. CCR has been removed;
2. Any areas affected by releases from the CCR unit have been removed or decontaminated; and
3. Groundwater monitoring concentrations of the constituents listed in Appendix IV to 40 CFR Part 257 do not exceed groundwater protection standards established pursuant to §257.95(h).

Santee Cooper has completed CCR and underlying soil removal for the above-referenced CCR unit in accordance with the closure plan specified in §257.102(b) and the state-approved closure plan in accordance with §257.102(b)(3). Additionally, the South Ash Pond currently is in assessment monitoring in accordance with §257.95(h). As of the date of this certification and throughout the assessment monitoring period, constituents listed in Appendix IV of 40 CFR Part 257 have not been detected at statistically significant levels above the groundwater protection standard. The groundwater monitoring data and statistical evaluations have been documented in the Annual Groundwater Monitoring and Corrective Action Reports published on Santee Cooper's public website.

CERTIFICATION

I, the undersigned Professional Engineer registered in good standing in the State of South Carolina, do hereby certify to the best of my knowledge, information, and belief, that the information contained herein is true and correct and has been prepared in accordance with generally accepted good engineering practices.

Fletcher Wood

Digitally signed by Fletcher Wood
DN: cn=Fletcher Wood, ou=Users, email=Fletcher.Wood@worley.com
Reason: I am signing my seal
Date: 2025.10.22 15:46:09 -05'00'

Fletcher Wood
PE #24767

SOUTH CAROLINA LICENSED PROFESSIONAL ENGINEER No. 24767 FLETCHER M. WOOD

SOUTH CAROLINA WORLEY GROUP INC. No. C01505 CERTIFICATE OF AUTHORIZATION