



Prepared for

Santee Cooper
One Riverwood Drive
Moncks Corner, SC 29461

**2016 SURFACE IMPOUNDMENT
PERIODIC SAFETY FACTOR
ASSESSMENT REPORT
ASH POND B
WINYAH GENERATING STATION
GEORGETOWN, SOUTH CAROLINA**

Prepared by

Geosyntec 
consultants

engineers | scientists | innovators

104 South Main Street, Suite 115
Greenville, South Carolina 29601

Project Number: GSC5242

October 2016

TABLE OF CONTENTS

TABLE OF CONTENTS	i
CERTIFICATION STATEMENT	v
EXECUTIVE SUMMARY	vi
1. INTRODUCTION	1
1.1 Project Background	1
1.2 Project Site and Construction History	1
1.3 Report Organization	2
2. HYDROLOGIC AND HYDRAULIC EVALUATION	4
2.1 Hydrologic and Hydraulic Analysis	4
2.1.1 Regulatory Framework	4
2.1.2 Methodology and Assumptions	5
2.1.3 Analysis Results	6
3. GEOTECHNICAL SUBSURFACE INVESTIGATIONS	7
3.1 Paul C. Rizzo Associates (PCRA) Investigation	7
3.2 Geosyntec Investigations	8
3.2.1 Fall 2013 Subsurface Investigation	8
3.2.2 Spring 2016 Subsurface Investigation	9
3.2.3 Laboratory Testing	9
4. SUBSURFACE CONDITIONS AND GEOTECHNICAL PROPERTIES	11
4.1 Regional Geology	11
4.2 Perimeter Dike Subsurface Conditions and Water Levels	12
4.2.1 Subsurface Stratigraphy	12
4.2.2 Water Levels	13
4.3 Coal Combustion Residuals (CCRs)	14
4.4 Material Parameters	14
5. SEISMIC HAZARD EVALUATION AND SITE RESPONSE ANALYSIS ...	16
5.1 Seismic Hazard Evaluation	16
5.1.1 Seismic Hazard Level	16

TABLE OF CONTENTS – Continued

5.1.2	Peak Ground Acceleration (PGA).....	17
5.1.3	Earthquake Magnitude	17
5.1.4	Target Acceleration Response Spectra and Time History Selection.....	18
5.2	Site Response Analysis.....	19
5.2.1	Analysis Model Setup	19
5.2.2	Site Response Analysis Results.....	19
6.	EVALUATION OF LIQUEFACTION POTENTIAL.....	21
6.1	Regulatory Framework.....	21
6.2	Methodology.....	21
6.2.1	Dike Phreatic Surface Conditions	21
6.2.2	Age Correction Factor.....	22
6.3	Evaluation Results	22
7.	SAFETY FACTOR ASSESSMENT.....	24
7.1	Regulatory Framework.....	24
7.2	Analysis Models	24
7.3	Methodology.....	25
7.3.1	Static Slope Stability	25
7.3.2	Seismic Slope Stability.....	25
7.4	Static Safety Factor – Maximum Normal Storage Pool	26
7.5	Static Safety Factor – Maximum Surcharge Pool	26
7.6	Seismic Safety Factor – Maximum Normal Storage Pool.....	26
7.7	Liquefaction Safety Factor - Maximum Normal Storage Pool.....	26
7.8	Summary of Results.....	26
8.	SUMMARY AND GENERAL CONCLUSIONS	28
9.	REFERENCES	29

LIST OF TABLES

Table 1	Summary of Selected Geotechnical Material Properties
Table 2	Summary of Calculated Cyclic Shear Stresses
Table 3	Summary of Calculated Safety Factors

TABLE OF CONTENTS – Continued

LIST OF FIGURES

Figure 1a	Site Location Map
Figure 1b	Site Vicinity Map
Figure 2	Site Layout Map
Figure 3	Soil Boring Location Map
Figure 4	Representative Subsurface Profiles for Site Response Analysis
Figure 5	Cross Section Location Map
Figure 6	Cross Section A Geometry during Maximum Normal Storage Pool Conditions
Figure 7	Cross Section B Geometry during Maximum Normal Storage Pool Conditions
Figure 8	Cross Section C Geometry during Maximum Normal Storage Pool Conditions
Figure 9	Cross Section D Geometry during Maximum Normal Storage Pool Conditions
Figure 10	Critical FS for Cross Section C: Static FS - Maximum Normal Storage Pool
Figure 11	Critical FS for Cross Section C: Static FS - Maximum Surcharge Pool
Figure 12	Critical FS for Cross Section D: Seismic FS - Maximum Normal Storage Pool


TABLE OF CONTENTS – Continued

LIST OF ATTACHMENTS

Attachment 1	Hydrologic and Hydraulic (H&H) Analysis: Ash Pond B
Attachment 2	Boring Logs
Attachment 2-A	Geosyntec Boring Logs
Attachment 2-B	Paul C. Rizzo Boring Logs (PCRA, 1993)
Attachment 3	CPT Sounding Data
Attachment 3-A	CPT Sounding Logs (Provided by Mid-Atlantic Drilling and Terracon)
Attachment 3-B	Shear Wave Velocity Test Data (Provided by Mid-Atlantic Drilling)
Attachment 3-C	Dissipation Test Data (Provided by Mid-Atlantic Drilling)
Attachment 4	Laboratory Testing Results (Provided by Excel Geotechnical Testing and Terracon)
Attachment 5	Subsurface Stratigraphy and Material Properties: Ash Pond B
Attachment 6	Seismic Hazard Evaluation and Site Response Analysis: Ash Pond B
Attachment 7	Liquefaction Potential Analysis: Ash Pond B
Attachment 8	Safety Factor Assessment: Ash Pond B

CERTIFICATION STATEMENT

This initial safety factor assessment meets the requirements of §257.73(e) of the Code of Federal Regulations Title 40, Part 257, Subpart D, and was prepared in accordance with current practices and the standard of care exercised by scientists and engineers performing similar tasks in the field of civil engineering, and no other warranty is provided in connection therewith. The contents of this report are based solely on the observations of the conditions observed by Geosyntec personnel and information provided to Geosyntec by Santee Cooper. Consistent with applicable professional standards of care, our opinions and recommendations were based in part on data furnished by others. Although we were not able to independently verify such data, we found that it was consistent with other information that we developed in the course of our performance of the scope of services. The information contained in this report is intended for use solely by Santee Cooper and their subconsultants.



Fabian Benavente, P.E.
South Carolina License No. 32067

10/13/2016

Date

EXECUTIVE SUMMARY

The Winyah Generating Station (WGS or “Site”) is a coal-fired, electric generating facility owned and operated by Santee Cooper and is located approximately four miles southwest of Georgetown, South Carolina (SC). Historically, WGS has utilized six surface impoundments designated for disposal of coal combustion residuals (CCR): Slurry Pond 3&4 (Slurry Pond), West Ash Pond, Unit 2 Slurry Pond, Ash Pond A, Ash Pond B, and the South Ash Pond.

On 17 April 2015, the United States Environmental Protection Agency (USEPA) published rules in 40 CFR (Code of Federal Regulations) Parts 257 and 261, regulating the design and management of existing and new CCR units (commonly referred to as the “CCR Rule”). The CCR Rule became effective on 17 October 2015. The CCR Rule requires owners and operators of existing CCR surface impoundments to conduct periodic safety factor assessments in accordance with §257.73(e) of each impoundment and publish the results to the facility’s operating record.

Ash Pond B at WGS is classified as an “existing CCR surface impoundment” by the CCR Rule. This *2016 Surface Impoundment Periodic Safety Factor Assessment Report: Ash Pond B* (Safety Factor Assessment Report) presents the first periodic (i.e., initial) safety factor assessment in accordance with the CCR Rule for Ash Pond B at WGS prepared by Geosyntec Consultants (Geosyntec) on behalf of Santee Cooper.

A hydrologic and hydraulic analysis (H&H) (Attachment 1) of Ash Pond B and its appurtenances was conducted to demonstrate the inflow design flood (IDF) can be managed and conveyed safely (i.e., without overtopping the perimeter dikes) during and after the rainfall event. Since Ash Pond B has been classified as a “Low Hazard Potential” surface impoundment, the 100-yr rainfall event with rainfall duration of 72 hours was selected as the IDF. Ash Pond A drains stormwater through a culvert system southward into Ash Pond B. The free water level within Ash Pond B is maintained at an elevation of 34.9 ft National Geodetic Vertical Datum of 1929 (NGVD29) by a concrete riser which discharges westward into the Discharge Canal. The peak water level during and after the IDF within Ash Pond B was computed as 37.1 ft NGVD29, which is below the minimum dike crest of 39.7 ft NGVD29.

In support of the periodic safety factor assessment, Geosyntec developed and performed subsurface investigation and laboratory testing programs to characterize the dike fill and subsurface soils for Ash Pond B in 2013 and 2016. Boring logs, Cone Penetration Test (CPT) sounding data, and laboratory testing results have been provided in Attachments

2, 3, and 4 of this Safety Factor Assessment Report, respectively. The interpretation of the in-situ and laboratory data is described and presented in Attachment 5.

Since WGS resides within the Charleston Seismic Zone, a seismic hazard evaluation was performed to select the “maximum horizontal acceleration of lithified material” at the Site corresponding to an earthquake with a probability of exceedance of 2 percent in 50 years (i.e., 2,475 year return period) as defined in §257.53. Site response analyses (Attachment 6) were performed to evaluate the influence of the local subsurface conditions on the maximum horizontal acceleration and to compute the maximum cyclic shear stresses anticipated to occur within the soil profile during the design earthquake.

The potential of the dike fill to liquefy during the design earthquake was evaluated at each soil boring and CPT sounding location (Attachment 7) based on the cyclic shear stresses computed during the site response analyses, in-situ testing data, and laboratory index testing results. The evaluation results did not show that the dike fill soils within the Ash Pond B perimeter dikes or the foundation soils underlying the perimeter dikes of Ash Pond B were susceptible to liquefaction during the design earthquake. It is noted that the liquefaction potential of the foundation soils near the downstream dike toe (i.e., outside the perimeter dike footprint) of Ash Pond B will be evaluated separately as part of an evaluation of “Unstable Areas” in accordance with §257.64 at a later time.

A safety factor assessment (Attachment 8) was performed on four selected cross sections of the perimeter dikes of Ash Pond B to demonstrate that minimum required safety factors provided in §257.73(e)(1) of the CCR Rule are met. Static slope stability was evaluated considering the calculated “Maximum Normal Storage Pool” level (i.e., 34.9 ft NGVD29) and “Maximum Surcharge Pool” level (i.e., 37.1 ft NGVD29) under the anticipated long-term “steady-state” conditions according to the CCR Rule. The minimum safety factors required by the CCR Rule for “Maximum Normal Storage Pool” and “Maximum Surcharge Pool” conditions are 1.50 and 1.40, respectively. Additionally, seismic slope stability with a minimum safety factor of 1.00 was also evaluated for the perimeter dikes of Ash Pond B during “Maximum Normal Storage Pool” conditions. The safety factor assessment results indicated that the selected cross sections of the Ash Pond B perimeter dikes met the minimum required safety factors provided in §257.73(e)(1) of the CCR Rule. It is noted that the safety factor considering post-liquefaction conditions of the dike fill was not evaluated in this Safety Factor Assessment Report, because the dike fill and the foundation soils directly under the perimeter dike were not found to be susceptible to liquefaction. However, the

post-liquefaction conditions of the foundation soils outside the footprint of Ash Pond B involving the perimeter dikes may be evaluated as part of the assessment of “Unstable Areas” performed at a later time, depending on the liquefaction potential evaluation results of the foundation soils near the downstream perimeter dike toe.

1. INTRODUCTION

1.1 Project Background

The Winyah Generating Station (WGS or “Site”) is an electric generating facility owned and operated by Santee Cooper. WGS is located between Pennyroyal and Turkey Creeks, tributaries to Sampit River, and is situated approximately four miles southwest of Georgetown, South Carolina (SC) (see Figures 1a and 1b for Site Location and Site Vicinity Maps). WGS has historically utilized six surface impoundments (Figure 2) designated for disposal of coal combustion residuals (CCR): Slurry Pond 3&4 (Slurry Pond), West Ash Pond, Unit 2 Slurry Pond, Ash Pond A, Ash Pond B, and the South Ash Pond.

On 17 April 2015, the United States Environmental Protection Agency (USEPA) published rules in 40 CFR Parts 257 and 261, regulating the design and management of existing and new CCR units (commonly referred to as the “CCR Rule”). The CCR Rule became effective on 17 October 2015. Within the CCR Rule, §257.73(e) outlines the safety factor criteria for existing CCR surface impoundments.

Ash Pond B is situated southeast of the power block and west of the Site’s Cooling Pond. Ash Pond B manages CCR in the form of fly ash, boiler slag, and bottom ash as well as process water resulting from power generating activities. Ash Pond B is considered as an existing surface impoundment under the CCR Rule. The *2016 Surface Impoundment Periodic Safety Factor Assessment Report: Ash Pond B* (Safety Factor Assessment Report) has been prepared by Geosyntec Consultants (Geosyntec) on behalf of Santee Cooper to demonstrate that Ash Pond B meets criteria for periodic safety factor assessments in accordance with §257.73(e)(1) of the CCR Rule.

1.2 Project Site and Construction History

Ash Pond B, spanning approximately 65 acres, is located southeast of the power block and immediately west of the Cooling Pond. Ash Pond B, an unlined surface impoundment commissioned in the early 1970s, is designated for the disposal of fly ash, bottom ash, and boiler slag. Ash Pond B is bounded by the divider dike and Ash Pond A to the north, the Discharge Canal to the west, and the Cooling Pond to the south and east. Ash Ponds A and B were constructed simultaneously and are separated by a recompacted, earthen divider dike spanning west to east from the Discharge Canal to the Cooling Pond.

Ash Pond B was constructed by recompacting excavated soils from the impoundment interior to form the perimeter dikes and a divider dike. The Ash Pond B perimeter dikes are approximately 12 ft to 15 ft in height adjacent to the Discharge Canal and approximately 20 ft to 24.5 ft in height along the east and south sides adjacent to the Cooling Pond (Thomas and Hutton, 2012). The upstream and downstream slopes of the perimeter dikes range from 2 Horizontal to 1 Vertical (2H:1V) to 3H:1V. The Ash Pond B dike crest was originally constructed in the early 1970s with a 12- to 15-ft width and an approximate elevation of 34.5 ft National Geodetic Vertical Datum of 1929 (NGVD29), which was approximately 7 ft lower than the Ash Pond A perimeter and divider dikes. The Ash Pond B dike crest was raised to a design elevation of 41.0 ft NGVD29 in 1997 using downstream construction methods. The crest of Ash Pond B is currently at an elevation between 39.7 ft and 41.4 ft NGVD29 (Thomas and Hutton, 2012; Thomas and Hutton, 2016).

Historically, Ash Pond B has received free water from Ash Pond A, which has been routed southward via rim ditches and a group of culverts. Ash Ponds A and B are hydraulically connected through a 30-inch (in.) diameter corrugated metal pipe (CMP), a 48-in. diameter smooth steel pipe, and a 42-in. diameter smooth steel pipe (Thomas and Hutton, 2016; Thomas and Hutton, 2012). Free water within Ash Pond B is stored in the south corner of the surface impoundment and the free water elevation is managed by a concrete riser structure, which discharges into the Discharge Canal through a 24-in. diameter, smooth interior, corrugated high density polyethylene (HDPE) pipe. Ash Pond A receives low volume wastewater, hydrovevor water, and bottom ash sluice water from electric generating Units 1 and 2 along with bottom ash sluice water from Units 3 and 4 and contact water from the Unit 2 Slurry Pond after rainfall events, which are eventually routed into Ash Pond B.

1.3 Report Organization

This Safety Factor Assessment Report presents the first (i.e., initial) periodic safety factor assessment for Ash Pond B at WGS based on the results of subsurface investigations, hydrologic and hydrology (H&H) analysis, geotechnical engineering analyses, and a review of Site information. The remainder of this Safety Factor Assessment Report is organized as follows:

- Descriptions of the hazard potential classification of Ash Pond B and corresponding performance of the hydraulic structures are presented in Section 2;

- Geotechnical subsurface investigations performed by Geosyntec are presented in Section 3;
- Subsurface conditions, geology, and geotechnical properties are discussed in Section 4;
- Selection of the seismic hazard parameters for WGS and the site response analysis of the Ash Pond B perimeter dikes performed by Geosyntec are presented in Section 5;
- Assumptions and results of the liquefaction potential evaluation of the Ash Pond B perimeter dikes are presented in Section 6;
- Slope stability analyses performed for the safety factor assessment are discussed in Section 7; and
- A summary and the general conclusions of the safety factor assessment are presented in Section 8.

2. HYDROLOGIC AND HYDRAULIC EVALUATION

2.1 Hydrologic and Hydraulic Analysis

The following section discusses the regulatory framework, the methodology and assumptions, and the results of the H&H analysis for Ash Pond B and its appurtenances.

2.1.1 Regulatory Framework

The CCR Rule (§257.73(d)(1)) requires that the periodic stability assessment:

“...at minimum, document whether the CCR unit has been designed, constructed, and maintained with:

...

(v) a single spillway or a combination of spillways configured as specified in paragraph (d)(1)(v)(A) of this section. The combined capacity of all spillways must be designed, constructed, operated, and maintained to adequately manage flow during and following the peak discharge event specified in paragraph (d)(1)(v)(B) of this section.”

§257.73(d)(1)(v)(B)(3) states that the spillway or spillways must manage the peak discharge from the “100-year flood for a low hazard potential CCR Surface Impoundment”. Additionally, §257.73(d)(1)(v)(A) indicates that “All spillways must be either:

- (1) Of non-erodible construction and designed to carry sustained flows; or*
- (2) Earth- or grass-lined and designed to carry short-term, infrequent flows at non-erosive velocities where sustained flows are not expected.”*

Meanwhile, §257.73(e)(1) of the CCR Rule indicates:

“(ii) The calculated static factor of safety under the maximum surcharge pool loading condition must equal or exceed 1.40.”

Considering the requirements of §257.73(d)(1) listed above, this Safety Factor Assessment Report utilizes the maximum water elevation within the Ash Pond B as computed during the H&H analysis to select the “maximum surcharge pool” elevation to demonstrate that the requirements of §257.73(e)(1)(ii) are met.

The concrete riser structure situated in the south corner of Ash Pond B serves as the spillway for the CCR surface impoundment and manages the discharge during and after the Inflow Design Flood (IDF). The IDF was selected as the 100-yr rainfall event because Ash Pond B was assigned a “Low Hazard Potential” classification (Geosyntec, 2016) since a potential failure would be contained within the property boundary and is not anticipated to migrate offsite. H&H analyses were performed to demonstrate that the Ash Pond B riser structure is able to adequately manage flow during and following the 100-yr design rainfall (i.e., peak discharge event) without overtopping of perimeter dikes, meeting the criteria in §257.73(d)(1)(v). The results of the H&H analyses are utilized in this Safety Factor Assessment Report to calculate the maximum surcharge pool elevation in support of the safety factor assessment per §257.73(e)(1)(ii).

2.1.2 Methodology and Assumptions

Details of the H&H analysis are provided in a calculation package titled “*Hydrologic and Hydraulic Analysis for Ash Pond B*”, which is included as Attachment 1 of this Safety Factor Assessment Report. The remainder of this section describes the assumptions, conditions, and results of the H&H analysis for Ash Pond B.

Ash Ponds A and B are hydraulically connected and thus, modeled as a single pond connected by: (i) a 30-in. diameter CMP culvert with an upstream invert at 37.50 ft NGVD29; (ii) a 48-in. diameter smooth steel pipe with an upstream invert at 35.49 ft NGVD29; and (iii) a 42-in. diameter smooth steel pipe with an upstream invert at 36.20 ft NGVD29 (Thomas and Hutton, 2016; Thomas and Hutton, 2012). These culverts allow for the southward conveyance of stormwater and process water from Ash Pond A to Ash Pond B.

Ash Pond A receives contact water from the Unit 2 Slurry Pond after rainfall events. The Unit 2 Slurry Pond is equipped with a 6JSVE Thompson pump operating at a maximum capacity of 2,600 gallons per minute (gpm) (5.79 ft³/s), which was considered a base flow into Ash Pond A. Low volume wastewater, hydroveyor water, and bottom ash sluice water from Units 1 and 2 and bottom ash sluice water from Units 3 and 4 were considered to have a combined base inflow to Ash Pond A totaling 6,099 gpm (13.59 ft³/s). These process water inflows are ultimately routed into Ash Pond B.

The operating level in Ash Pond B is maintained by a 4-ft by 4-ft concrete riser structure (or spillway) with a top stop log elevation of 34.9 ft NGVD 29 (Thomas and Hutton, 2016) and a 24-in. diameter smooth interior, corrugated HDPE pipe discharging to the Discharge Canal. The tailwater conditions associated with discharge from Ash Pond B into the Discharge Canal were modeled using a fixed water surface elevation

within the Discharge Canal and Cooling Pond estimated by conservatively assuming 2.5-ft of free water overtopping the Cooling Pond emergency spillway during a significant rainfall event. The top of the 4-ft by 4-ft stop log bolted to the top of the concrete spillway of the Cooling Pond is at elevation 21.65 ft NGVD 29 (Thomas and Hutton, 2016). The water surface of the Discharge Canal and Cooling Pond was assumed to be at 24.15 ft NGVD 29 (21.65 ft NGVD 29 plus an additional 2.5 ft of water) during the IDF.

HydroCAD[®] (HydroCAD, 2011) software was utilized to apply the Soil Conservation Service (SCS) Technical Release 20 (TR-20) method (SCS, 1982) to compute the stormwater volume and to model the performance of the hydraulic structures of Ash Ponds A and B during the 100-yr rainfall event. The 100-yr rainfall event was selected with a 72-hour (hr) duration precipitation event resulting in a rainfall depth of 12.8 inches (NOAA, 2006), and modeled within HydroCAD[®] using a SCS Type III rainfall distribution. The analysis was performed under the following assumptions, which were confirmed by WGS personnel:

- The Site will construct a 100-ft wide emergency spillway with an invert elevation of 37.0 ft NGVD 29 in the divider dike between Ash Ponds A and B by October 2016. The emergency spillway will be constructed with 10H:1V side slopes and will be located between the 48-in. diameter smooth steel pipe and the 42-in. diameter smooth steel pipe.
- Ash Ponds A and B effectively operate as a single surface impoundment with respect to hydraulic performance (i.e., the two impoundments are “hydraulically connected”).

2.1.3 Analysis Results

Under the conditions and assumptions described in Section 2.1.2, the maximum free water level or “maximum surcharge pool” level during and following the 100-yr rainfall event was computed as 37.1 ft NGVD29 occurring 42.6 hours into the rainfall event.

3. GEOTECHNICAL SUBSURFACE INVESTIGATIONS

This section summarizes the geotechnical subsurface investigation programs performed in the vicinity of the Ash Pond B perimeter dikes at WGS. In the fall of 2013, Geosyntec conducted a focused geotechnical subsurface investigation program to obtain geotechnical data necessary to evaluate closure alternatives for the surface impoundment. Geosyntec returned to the Site in the spring of 2016 and performed an additional geotechnical subsurface investigation to collect subsurface information along the Ash Pond B perimeter dikes. Historically, soil borings were performed in the vicinity of Ash Pond B prior to construction of the CCR surface impoundment; however, records (i.e., locations, soil boring logs, laboratory testing results) pertaining to these subsurface investigations were not available during the preparation of this Safety Factor Assessment Report. Paul C. Rizzo Associates (PCRA) performed a geotechnical subsurface investigation program supporting the raising of crest of the Ash Pond B perimeter dikes in 1993. These available soil boring logs were utilized during this evaluation. Figure 3 presents the locations of soil borings and Cone Penetration Test (CPT) soundings performed during historical (when available) and Geosyntec's geotechnical subsurface investigations.

The geotechnical data obtained from these subsurface investigation programs, including soil borings, CPT sounding data, and laboratory test results, are provided in Attachments 2, 3, and 4, respectively. The interpretation of the subsurface stratigraphy and material properties is presented in Attachment 5. The following sections provide summaries of each of the geotechnical subsurface investigations in the vicinity of Ash Pond B.

3.1 Paul C. Rizzo Associates (PCRA) Investigation

In 1993, PCRA conducted a focused subsurface investigation of the Ash Pond B perimeter dikes to evaluate the feasibility of raising the structures by 7 ft. PCRA's investigation included six soil borings which were advanced 25 to 30 ft below ground surface (ft bgs) using a CME-55 drilling rig and the hollow stem auger (4.25-inch inner diameter) drilling method. Standard Penetration Tests (SPTs) were conducted in 5-ft depth intervals using a rope-and-cathead system to apply the 140-lb hammer falling 30 inches. Boring logs prepared by PCRA (Attachment 2) indicated that the perimeter dikes were constructed of medium dense to dense sand with some trace clay and silt. Underlying the dike fill soils, poorly graded sand to clayey and silty sands with some shell fragments were generally encountered within the foundation soils. Depth to water (DTW) level measurements were collected from each soil boring location prior to termination. During this subsurface investigation, the surface water elevation within

Ash Pond B was maintained approximately at 29.2 ft NGVD29 (PCRA, 1993). Additionally, PCRA identified a potential offsite borrow source adjacent to WGS containing suitable soil for structural fill to raise the perimeter dikes. Two samples of the potential borrow soils were collected and tested for index properties (i.e., grain size distribution tests and Atterberg limits) and compaction properties (i.e., standard Proctor tests).

3.2 Geosyntec Investigations

3.2.1 Fall 2013 Subsurface Investigation

In October 2013, Geosyntec mobilized to WGS to collect geotechnical subsurface data through additional soil test borings and CPT soundings in support of evaluating preliminary and conceptual closure alternatives for each CCR surface impoundment at WGS. The subsurface investigation was focused in the vicinity of the South Ash Pond, Unit 2 Slurry Pond, Ash Pond A, and Ash Pond B. In the Ash Pond B area, Geosyntec advanced four soil borings by the mud rotary wash drilling method and seven CPT soundings. Soil Consultants, Inc. (SCI) of Charleston, South Carolina was the drilling contractor during this subsurface investigation while Mid-Atlantic Drilling, Inc. (MAD) from Wilmington, North Carolina performed the CPT soundings. One soil boring (SPT-122) and three CPT soundings (CPT-152, CPT-153, and CPT-154) were advanced within the interior of Ash Pond B, but were terminated once native or foundation materials were encountered. The remaining soil borings and CPT soundings during this investigation were performed on the perimeter and divider dikes and were terminated once refusal was encountered, which was defined as SPT N-value of 50 blows per foot over an advancement of 6" or the inability to further advance the cone.

For each soil boring, split spoon samples were collected and SPT blow counts (i.e., N-values) were measured, typically in 5-ft depth intervals. Attempts were made to push Shelby tubes within dike fill and foundation soils; however, these soils were typically found to be dense and cohesionless and thus, undisturbed samples were unable to be collected. In one soil test boring (SPT-115), SCI switched from a paddle drilling bit to a tri-cone rotary wash drill bit once the Chicora Member stratum was encountered to penetrate the stratum and extend the borehole into the underlying stiff clay. In SPT-115, an attempt was made to push a Shelby tube to collect a sample of the underlying stiff clay for laboratory testing. However, the Shelby tube was sheared during extraction from the borehole (i.e., the screws attached to the drilling rods sheared). For select CPT soundings, the shear wave velocity (V_s) was measured in 5-ft depth intervals or a porewater pressure dissipation test was performed to evaluate the

phreatic surface at the location. Results of the V_s and porewater pressure dissipation tests are provided in Attachment 3.

In November 2013, Geosyntec returned to WGS to install piezometers as part of the development of the hydrogeological model at the Site. One piezometer (PPZW-10D) was installed adjacent to a Site monitoring well (WAP-10) by South Atlantic Environmental Drilling and Construction Co. Inc. (SAEDACCO). Prior to installing the piezometer, subsurface soils were collected within the borehole using a split spoon sampler and logged by a geologist. SPT blow counts measured during this piezometer installation were utilized within this Safety Factor Assessment Report.

3.2.2 Spring 2016 Subsurface Investigation

Geosyntec mobilized to WGS in the spring of 2016 to perform a focused geotechnical subsurface investigation in the vicinity of the South Ash Pond, Ash Pond A, Ash Pond B, and the former Unit 2 Slurry Pond. The investigation program along the Ash Pond B perimeter dikes consisted of two soil test borings (SPT-309 and SPT-310) advanced using the mud-rotary drilling technique by MAD and three CPT soundings (CPT-225, CPT-226, and CPT-227) advanced by Terracon. Additionally, Terracon (by means of Carolina Drilling, Inc.) advanced two additional borings (SPT-307 and SPT-308) and several CPT soundings within the Ash Pond B interior in support of evaluating preliminary and conceptual closure alternatives. For SPT-309 and SPT-310, split spoon samples were collected and SPTs were performed continuously in the upper 20 ft bgs and in 5-ft depth intervals thereafter until refusal was encountered. Refusal was defined as SPT N-values of 50 blows per foot over an advancement of 6 inches or less. Select soil samples were sealed and transported to a geotechnical laboratory for testing.

3.2.3 Laboratory Testing

For both geotechnical subsurface investigations led by Geosyntec, Excel Geotechnical Testing, Inc. (EGT) of Roswell, Georgia was subcontracted to conduct a geotechnical laboratory testing program on representative disturbed (i.e., bulk or split spoon) samples of the dike fill and foundations soils, including twelve grain size distribution tests with two hydrometer tests, twenty-two fines content tests (to supplement the grain size distribution tests), seven Atterberg limits tests, and thirty-five natural water content tests. Additionally, EGT conducted two grain size distribution tests, two Atterberg limits tests, two CU triaxial tests, and one 1-D consolidation tests on undisturbed (i.e., thin-walled Shelby tube) samples of impounded fly ash collected from the interior of Ash Pond B. Laboratory testing results from each geotechnical subsurface investigation

are provided in Attachment 4 and the interpretation of the laboratory testing results is discussed in Attachment 5.

4. SUBSURFACE CONDITIONS AND GEOTECHNICAL PROPERTIES

This section presents subsurface conditions, phreatic surface and free water levels, and material properties for Ash Pond B based on the geotechnical subsurface investigation programs discussed in Section 3. A summary of the regional geology is also provided as a framework to develop the subsurface stratigraphy model. Additional information on the subsurface conditions and the material properties is presented in Attachment 5 of this Safety Factor Assessment Report.

4.1 Regional Geology

Georgetown County, SC is located in the Atlantic Coastal Plain physiographic province which is characterized by Quaternary terrace deposits produced by fluctuating sea levels. Coastal Plain sediments are underlain by Tertiary and late Cretaceous sediments to a depth of approximately 2,200 ft bgs in the Georgetown area. Descriptions of geologic units of interest in the area have been referenced from Campbell and Coes (2010) and are summarized below from top to bottom. The approximate thicknesses of each unit were estimated from several borings referenced in Campbell and Coes (2010). The specific borings used for this estimation include: 1) CHN-0820 located approximately 12 miles to the south of WGS; 2) GEO-0088 located approximately 7 miles to the southeast of WGS; and 3) GEO-0185 located less than 1.5 miles to the northwest of WGS.

- Undifferentiated Quaternary sediments consist of yellowish-brown and reddish-orange poorly sorted, very fine to very coarse, clayey sand and gravel. Accessory minerals include opaque heavy minerals, mica, and feldspar. The reported thickness of Undifferentiated Quaternary sediments ranges between 20 and 42 ft in the area.
- The Williamsburg Formation (Williamsburg) consists of gray to black interbedded clay and coarse quartz sand overlying shelly clay and calcareous clay. The Williamsburg can include sandy shale, fuller's earth, fossiliferous clayey sand (Lower Bridge Member), and fossiliferous clayey sand and mollusk-rich, bioclastic limestones (Chicora Member). The reported thickness of the Williamsburg in the vicinity of the site ranges between 30 and 90 ft.
- The Lang Syne Formation (Muthig and Colquhoun, 1988) was described as consisting of red and yellow (where weathered) or white, gray, and black (where freshly exposed) interbedded sand, silt, and clay and thin beds of silicified shell debris. Opaline clay stone is the most characteristic lithology.

- The Rhems Formation which consists of light-gray to black shale interlaminated with thin seams of fine-grained sand and mica.
- The Peedee Formation which consists of a dark-green to gray, fossiliferous, glauconitic clayey sand and silt. The combined thickness of the Lang Syne and Rhems and Peedee Formations ranges between 185 and 378 ft in the vicinity of the WGS.

Additional late Cretaceous Formations are present to a depth of approximately 2,200 ft bgs in the area. These Formations, in descending order, include: Donoho Creek, Bladen, Coachman, Cane Acre, Caddin, Sheppard Grove, Pleasant Creek, Cape Fear and undifferentiated Cretaceous sediments. The most important geologic units for this report are the undifferentiated Quaternary and Williamsburg Formations, which are encountered within 60 to 100 ft bgs as described in detail by Doar (2012).

4.2 Perimeter Dike Subsurface Conditions and Water Levels

4.2.1 Subsurface Stratigraphy

The subsurface stratigraphy at the Site was developed from information obtained from the historical and more recent geotechnical subsurface investigations at WGS and from regional geologic data. The information indicates that the subsurface soils primarily consist of four geotechnical units, within the depths of interest for the analyses presented in this Safety Factor Assessment Report. A brief description on each unit is presented as follows:

- **Dike Fill:** Dike fill soils for the Ash Pond B perimeter dikes were generally observed to be medium dense to very dense poorly graded silty sands with uncorrected SPT blow counts typically ranging between 9 and 51 blows per foot. CPT tip resistances in the top 10 ft of fill typically ranged between 30 and 200 tons per square foot (tsf), while CPT tip resistances below the top 10 ft of fill typically ranged between 200 and 450 tsf. Grain size distribution analyses indicated that the dike fill soils consist of approximately 70 percent to 90 percent sand-sized particles (smaller than No. 4 sieve but greater than No. 200 sieve) and 8 percent to 27 percent silt and clay-sized particles (i.e., “fines” with diameters smaller than a No. 200 sieve).
- **Foundation Soils:** Foundation materials were observed to be variable across the Ash Pond B footprint, consisting primarily of poorly graded silty sands with shells and a few isolated seams of clayey sand or high plasticity clay. Uncorrected SPT blow counts within sandy foundations typically ranged

between 2 and 30 blows per foot, while CPT tip resistances typically ranged between 25 and 150 tsf.

- **Chicora Member:** A dense to very dense layer of partially cemented to heavily cemented shells was encountered beneath the foundations soils during the past subsurface investigations at WGS. Blow counts in this layer exceeded 50 blows over less than 6 in. of advancement with minimal sample recovery. The thickness of the Chicora Member varies across WGS, particularly the partially cemented layers of the stratum. Based on review of historical (Doar, 2012) and existing data, this layer is the upper portion of the overall Williamsburg Formation and has also been referred to as “Coquina” or “Shell Hash” by others. The term “Chicora Member” or “Chicora” has been used to refer to this soil unit throughout this Safety Factor Assessment Report. Soil boring and CPT refusal was typically encountered at the top of this stratum, though one soil boring (SPT-115) within the Ash Pond B area penetrated this stratum.
- **Williamsburg Formation Clay:** The Williamsburg Formation Clay stratum was encountered beneath the Chicora Member. The Williamsburg Formation Clay is described as stiff to very hard, dark gray to black, medium to high plasticity clay or silt with sand. The Williamsburg Formation Clay has historically been referred to as “Black Mingo Clay” or the “Black Mingo Formation” at the Site. The term “Williamsburg Formation Clay” is the most recent geological term for this stratum and is used throughout this Safety Factor Assessment Report. The Williamsburg Formation Clay was found to be between 30-ft and 90-ft thick in the vicinity of WGS based on a review of the regional geology.

4.2.2 Water Levels

As described within the H&H analysis for Ash Pond B provided in Attachment 1 of this Safety Factor Assessment Report, the free water level within Ash Pond B is maintained at an elevation of 34.9 ft NGVD29 by a 4-ft by 4-ft concrete riser structure. Ash Pond B receives free water and process water from Ash Pond A through a series of rim ditches and culverts. The concrete riser structure in Ash Pond B maintains free water at an operating elevation of 34.9 ft NGVD29 and discharges free water westward into the Discharge Canal.

The phreatic surface through the Ash Pond B perimeter dikes to the downstream toe at the time of this Safety Factor Assessment Report was predominantly developed based

on water levels collected from results of porewater pressure dissipation tests conducted during CPT soundings, depth to water measurements within boreholes, and the Cooling Pond free water elevation. A temporary piezometer installed within the interior of Ash Pond B (PPZ-BS-1) indicates that the phreatic elevation within the CCR at the center of Ash Pond B has ranged between 34.4 and 35.0 ft NGVD29 since installation. Thus, the phreatic surface elevation within the center of Ash Pond B was considered to be the same as the normal operating pool level elevation of 34.9 ft NGVD29. The water level of the Cooling Pond was selected as 19.1 ft NGVD29 based on the operating level of the Cooling Pond required to manage runoff from the 25-yr, 24-hr rainfall event. The maximum free water elevation during and after the IDF within Ash Pond B was computed as 37.1 ft NGVD29 (Section 2), which was used to represent the “Maximum Surcharge Pool” level within this Safety Factor Assessment Report.

4.3 Coal Combustion Residuals (CCRs)

As noted in Sections 3.2.1 and 3.2.2, four soil test borings and several CPT soundings have been advanced within the interior of Ash Pond B during the geotechnical subsurface investigations. Numerous Geoprobe[®] borings have been advanced by Geosyntec within Ash Pond B to evaluate the location of the bottom of the surface impoundment and to estimate the volume of CCR contained within the surface impoundment. Ash Pond B contains predominantly fly ash, which was found to be soft, black, sandy silt with SPT blow counts between 0 (i.e., weight of hammer) or 2 blows per foot. The measured CPT tip resistances of the fly ash ranged between 5 tsf and 50 tsf, with most measured values below 15 tsf. It is noted that most of the higher tip resistance values and blow counts were observed within the upper 5 ft bgs.

4.4 Material Parameters

Representative parameters of subsurface materials were selected based on in-situ and laboratory testing results, as discussed in Attachment 5. Additionally, correlations based on in-situ testing methods were applied to supplement laboratory testing, in particular, the shear strength for the dike fill and foundation soils. Shear strength parameters were selected from these results, which correspond to the current range of overburden stresses experienced in the vicinity of Ash Pond B. A summary of the material parameters selected for the safety factor assessment are presented in Table 1.

Representative shear wave velocity (V_s) profiles were developed based on direct measurements from seismic CPT (SCPT) soundings and empirical correlations using the CPT sounding results. The development of these V_s profiles is presented in

Attachment 5 and subsequently applied in the site response analysis discussed in Section 5.2 of this Safety Factor Assessment Report.

5. SEISMIC HAZARD EVALUATION AND SITE RESPONSE ANALYSIS

This section presents the results of seismic hazard evaluation and site response analysis of the Ash Pond B perimeter dikes. Seismic hazard evaluation includes the selection of an appropriate hazard level and associated hazard parameters (e.g., Peak Ground Acceleration [PGA]). Site response analysis was performed to evaluate the local site effects on selected time history records propagated from the hypothetical firm ground outcrop to the ground surface at the Site. Details and results for these analyses are presented in Attachment 6 and summarized herein.

5.1 Seismic Hazard Evaluation

A seismic hazard evaluation typically consists of the selection of appropriate hazard level and associated earthquake parameters, which include the target acceleration response spectra and PGA and the controlling earthquake magnitude. The seismic hazard analysis also involves the selection of ground motions that envelop the target response spectrum.

5.1.1 Seismic Hazard Level

The appropriate hazard level is often expressed in probabilistic terms as a specific hazard level that has a certain probability of exceedance in a given time period. The CCR Rule states in §257.63(a) that:

“New CCR landfills, existing and new CCR surface impoundments, and all lateral expansions of CCR units must not be located in seismic impact zones, unless the owner or operator demonstrates by the dates specified in paragraph (c) of this section that all structural components including liners, leachate collection and removal systems, and surface water control systems, are designed to resist the maximum horizontal acceleration in lithified earth material for the site.”

§257.53 defines the maximum horizontal acceleration in lithified earth material as:

“... the maximum expected horizontal acceleration at the ground surface as depicted on a seismic hazard map, with a 98 percent or greater probability that the acceleration will not be exceeded in 50 years, or the maximum expected horizontal acceleration based on a site-specific seismic risk assessment.”

In accordance with the CCR Rule, the analysis presented in this Safety Factor Assessment Report was based on establishing seismic design parameters (i.e., PGA) consistent with a 98 percent or greater probability that the PGA will not be exceeded in

50 years. This results in a PGA with a return period of 2,475 years, which is commonly referred to as the 2,500-year event PGA.

5.1.2 Peak Ground Acceleration (PGA)

PGA values corresponding to different hazard levels and different site conditions, including firm ground outcrops, are published as seismic hazard maps. While United States Geological Survey (USGS) national seismic hazard maps are the most commonly used resources for the selection of PGA, regional seismic hazard maps developed by local experts consider regional geologic setting and seismicity and are often the preferred alternatives.

USGS national seismic hazard maps for a 2 percent probability of exceedance in 50 year ground motion (i.e., 2,475-year return period event) provide the PGA and spectral accelerations for a hypothetical firm ground outcrop at the Site. The software available at the USGS website (USGS, 2008) uses pre-calculated hazard values at nearby grid locations and interpolates the hazard value for a given site location. As discussed within Attachment 6, the USGS interpolated PGA is 0.469g for the Site.

The South Carolina Department of Transportation (SCDOT) Geotechnical Design Manual (GDM) (SCDOT, 2010) also provides seismic hazard maps for “geologically realistic” site conditions as well as for the hypothetical “hard-rock” conditions. The SCDOT seismic hazard maps were developed by Chapman and Talwani (2006) to incorporate their local experience and research over several decades for the Charleston Seismic Zone. The “geologically realistic” site condition is a hypothetical site condition that was included via a depth-dependent transfer (i.e., site amplification) function for Coastal Plain and non-Coastal Plain regions of SC. According to these hazard maps, the Site PGA is 0.16g for “geologically realistic” conditions.

As mentioned above, the SCDOT (2010) hazard maps were developed by local experts who have spent several decades studying the Charleston Seismic Zone. A review of V_s profiles developed for WGS indicates that use of “geologically realistic” conditions is more appropriate for the seismic analysis and site response. Therefore, the SCDOT hazard maps for “geologically realistic” conditions were used to select the PGA (i.e., 0.16g) for this Safety Factor Assessment Report. Additional discussion with respect to the selection of the PGA is provided in Attachment 6.

5.1.3 Earthquake Magnitude

In a probabilistic seismic hazard analysis, the PGA cannot be associated with a single

earthquake event due to the hazard contribution from multiple possible events. An earthquake moment magnitude (M_w) value is required to conduct liquefaction potential analyses and to select earthquake time histories. A process called deaggregation can be performed for sites that have multiple hazard sources using the USGS (2002) deaggregation tool. As discussed within Attachment 6, a 7.3 moment magnitude was selected for liquefaction potential analyses and time history selection for WGS by applying this deaggregation tool.

5.1.4 Target Acceleration Response Spectra and Time History Selection

A target acceleration response spectrum was selected using the SCDOT seismic hazard maps for a “geologically realistic” site at different spectral periods (or frequencies). The “geologically realistic” target acceleration response spectrum has a PGA (represented by a spectral period of 0.01 seconds) of 0.16g and a peak spectral acceleration of 0.48g at a spectral period of 0.2 seconds. As stated previously, the “geologically realistic” condition target acceleration response spectrum was selected for WGS.

Time histories of ground motions are used as input for site response analysis and are selected such that their response spectra match or envelope the target spectrum. While use of recorded ground motion time histories from earthquakes with similar source characteristics is preferred, synthetic motions may be used if recordings are not available for a particular seismic zone. Earthquake events with a moment magnitude, M_w , 7.0 or greater have not occurred in the stable continental tectonic environment of the Central and Eastern United States since the Charleston earthquake in 1886, so ground motion time history records matching the seismic source characteristics for WGS are generally not available. Two synthetic acceleration time histories were selected from the six synthetic acceleration time histories developed for the Site using the USGS Interactive Deaggregation tool (USGS, 2002). These time histories are referred to herein as Winyah1 and Winyah2, and provide a reasonable match to the short-period portion of the “geologically realistic” target acceleration response spectrum. Three time histories, BOS-T1, DEL090, and YER360, developed by McGuire et al. (2001) as part of a study for the Nuclear Regulatory Commission to provide time histories representative of expected earthquake events in the Central and Eastern United States were selected to provide a reasonable match with the long-period portion of the “geologically realistic” target acceleration response spectrum. One time history, RSN8529-HNE, from the Next Generation Attenuation – East database (Goulet et al., 2014), which provides a database of time histories recorded for earthquake events in the Central and Eastern United States, was selected to also provide a reasonable

match with the “geologically realistic” target acceleration response spectrum for longer periods.

5.2 Site Response Analysis

Site response analysis performed during the seismic evaluation computed the cyclic shear stresses within representative soil profiles located along the perimeter dike centerline. Computed cyclic shear stresses were applied for the liquefaction potential analysis, and were also utilized to evaluate the seismic safety factor as part of the safety factor assessment.

5.2.1 Analysis Model Setup

Site response analyses presented herein were conducted using DEEPSOIL[®] (Hashash et al., 2015), a one-dimensional, nonlinear site response analysis program. The program assumes that all the soil layers are perfectly horizontal (i.e., “layer cake”) and that ground response is mainly caused by vertically-propagating, horizontally polarized shear waves. This assumption is valid for many geotechnical cases including the site response analyses at the Site. Under these assumptions, the subsurface stratigraphy is modeled as a one-dimensional column of soil layers for the analyses. Two representative profiles were developed for the Ash Pond B perimeter dikes and are shown in Figure 4 and Attachment 6.

DEEPSOIL[®] employs a viscoelastic material model, described by its shear modulus (G), mass density (ρ) or unit weight (γ), and damping (D). Preliminary equivalent-linear site response analyses yielded calculated maximum cyclic shear strains greater than 5 percent in some layers, which is greater than the cyclic shear strains for which equivalent-linear analyses are considered applicable (i.e., 1 to 2 percent). Therefore, nonlinear site response analyses were performed. Additional discussion of input parameters, such as the V_s profile, soil plasticity, and shear modulus reduction/damping curves applied in the DEEPSOIL[®] program, are discussed in Attachment 6. The six selected ground motions used within these analyses are also provided within Attachment 6.

5.2.2 Site Response Analysis Results

Maximum horizontal accelerations, maximum shear strains, and maximum shear stresses within the representative soil profiles were computed, as presented in Attachment 6.

The maximum cyclic shear stresses at selected depths for each profile (Table 2) were

calculated and used to calculate Cyclic Stress Ratios (CSR) in the evaluation of liquefaction potential, presented in Section 6 of this Safety Factor Assessment Report. The maximum cyclic shear stresses were also used to calculate the horizontal seismic coefficient (k_h) as presented in Section 7 of this Safety Factor Assessment Report.

6. EVALUATION OF LIQUEFACTION POTENTIAL

This section presents the liquefaction potential evaluation for the Ash Pond B perimeter dikes and foundation soils underlying the perimeter dikes. The evaluation applies the cyclic shear stress computed as part of the site response analysis (Section 5) and the interpretation of the in-situ testing data (Section 3). Further details of the liquefaction potential evaluation are presented in Attachment 7.

6.1 Regulatory Framework

A periodic safety factor assessment is required by the CCR Rule to evaluate whether the existing CCR surface impoundments meet minimum safety factors (also referred to as “factors of safety”) in §257.73(e)(1). Specifically, §257.73(e)(1)(iv) requires that:

“embankments constructed of soils that have susceptibility to liquefaction, the calculated liquefaction factor of safety must equal or exceed 1.20.”

The purpose of this Section is to discuss the methodology, analysis, and results of the liquefaction potential analysis in order to evaluate if the Ash Pond B dike fill and foundation soils are susceptible to liquefaction. If soils are not found to be liquefiable within the dike, then the liquefaction factor of safety is not required and is not evaluated as a part of this periodic safety factor assessment.

6.2 Methodology

Liquefaction potential analysis was performed based on the Simplified Procedure recommended by Seed and Idriss (1971) and the subsequent update by Idriss and Boulanger (2008). This approach is based on comparing in-situ test results with case histories of occurrences and non-occurrences of liquefaction due to past earthquakes. The analyses presented herein were conducted for both the soil borings and the CPT soundings performed during the Geosyntec geotechnical subsurface investigations presented in Section 3. The criteria recommended by Bray and Sancio (2006) were applied to evaluate the susceptibility of fine-grained soils to cyclic softening. However, fine grained soils were not typically encountered within soil borings and representative samples were not typically collected in the vicinity of the Ash Pond B perimeter dikes. Thus, the criteria recommended by Bray and Sancio (2006) were not applicable or applied on samples collected from the Ash Pond B area.

6.2.1 Dike Phreatic Surface Conditions

The phreatic surface through the Ash Pond B perimeter dikes to the downstream dike

toe at the time of the liquefaction potential analysis was developed based on water levels measured from borehole and CPT porewater pressure (u_o) signatures and porewater pressure dissipation tests. Operations of Ash Pond B (i.e., CCR disposal and sluicing rates) have not changed significantly since the fall 2013 geotechnical subsurface investigation (Section 4.2.2), so these water level measurements were considered representative of steady state and anticipated phreatic surface conditions. Soil borings performed by PCRA (1993) were utilized to develop the subsurface profiles to evaluate liquefaction potential of dike fill and foundation soils; however, since the perimeter dikes and operating pool of Ash Pond B were increased after 1993, recent water level measurements from adjacent CPT soundings and soil borings were used during this liquefaction potential evaluation.

6.2.2 Age Correction Factor

Correlations associated with liquefaction potential analysis were developed based on case histories of relatively young soil deposits (i.e., Holocene Era). As described in SCDOT (2010), liquefaction resistance, as modeled by the Cyclic Resistance Ratio (CRR), may be adjusted to account for aging effects in older soils based on time from deposition (i.e., geologic age) and time from last occurrence of liquefaction (i.e., geotechnical age). As described in Attachment 7, an age correction factor (K_{dr}) of 1.3 was applied for the Pleistocene age soils at WGS (typically foundation soils below the base of the dike). The transition of dike fill into foundation soils was selected as the surveyed surface elevations of soil borings and soundings performed at the base of the Ash Pond B perimeter dikes or based on the elevation of the Cooling Pond when data was not available.

6.3 Evaluation Results

The factor of safety against liquefaction (FS_{liq}) was computed at each interval where in-situ data was collected for each soil test boring (2-ft or 5-ft intervals) and each CPT sounding (0.16-ft intervals) advanced in the vicinity of the Ash Pond B perimeter dikes. FS_{liq} values computed for dike fill soils were calculated to exceed 1.0 for the conditions described within this Safety Factor Assessment Report. Analysis results for each boring and CPT sounding analyzed are provided as figures within Attachment 7 of this Safety Factor Assessment Report. Based on these analyses, the dike fill and foundation soils underlying the Ash Pond B perimeter dikes were not found to be susceptible to liquefaction during the design earthquake and thus, the liquefaction safety factor of the perimeter dike is not required to be evaluated during the periodic safety factor assessment. It is noted that the post-liquefaction conditions of the foundations soils outside the footprint of the Ash Pond B perimeter dikes may be evaluated as part of the

assessment of “Unstable Areas” performed at a later time, depending on the liquefaction potential evaluation results of the foundation soils near the downstream perimeter dike toe.

7. SAFETY FACTOR ASSESSMENT

This section presents the first (i.e., initial) periodic safety factor evaluation for the Ash Pond B perimeter dikes. This evaluation is presented in detail in Attachment 8 and summarized herein.

7.1 Regulatory Framework

Slope stability analyses were conducted to assess whether Ash Pond B meets the safety factor (also referred to as “factor of safety”) requirements of §257.73(e)(1) of the CCR Rule. Specifically, §257.73(e)(1) requires that:

- (i) *“The calculated static factor of safety under the long-term, maximum storage pool loading condition must equal or exceed 1.50.*
- (ii) *The calculated static factor of safety under the maximum surcharge pool loading condition must equal or exceed 1.40.*
- (iii) *The calculated seismic factor of safety must equal or exceed 1.00.*
- (iv) *For embankments constructed of soils that have susceptibility to liquefaction, the calculated liquefaction factor of safety must equal or exceed 1.20.”*

The remainder of Section 7 describes the geometric model, methodology, and analysis results for each case.

7.2 Analysis Models

Subsurface cross sections were developed through the perimeter dikes of Ash Pond B based on the information obtained from several sources: (i) recent topographic surveys (Thomas and Hutton, 2012; Thomas and Hutton, 2016); (ii) surveyed Cooling Pond transects performed by Parker Land Surveying, LLC.; (iii) available engineering reports and drawings for WGS; (iv) subsurface stratigraphy developed from geotechnical subsurface investigations (Section 4); and (v) water level measurements (Section 4.2.2). Four representative cross sections (Cross Sections A through D) were selected based on geometric and subsurface conditions. Figures 5 through 9 present the locations of the cross sections within Ash Pond B and the geometry of each selected cross section, respectively.

7.3 Methodology

7.3.1 Static Slope Stability

Global slope stability analyses were performed using Spencer's method (Spencer, 1973), as implemented in the computer program SLIDE[®], version 6.037 (Rocscience, 2015). Spencer's method, which satisfies vertical and horizontal force equilibrium as well as moment equilibrium, is considered to be more rigorous than other methods, such as the simplified Janbu method (Janbu, 1973) and the simplified Bishop method (Bishop, 1955).

Both the rotational mode (i.e., the circular slip surfaces) and the non-rotational mode (i.e., the block slip surfaces) were considered during the factor of safety assessment analyses, and the slip mode resulting in the lowest calculated FS was reported. SLIDE[®] generates potential slip surfaces, calculates the FS for each of these surfaces, and identifies the most critical slip surface with the lowest calculated FS. Information required for these analyses includes the slope geometry, the subsurface soil stratigraphy, the phreatic surface elevation, the external loading conditions, and the properties of subsurface materials.

7.3.2 Seismic Slope Stability

Pseudo-static slope stability analyses were performed utilizing Spencer's method as described in Section 7.3.1 to evaluate the seismic performance of the perimeter dike structures and a procedure consistent with a guidance document prepared for the USEPA (USEPA, 1995) and recommendations made by Hynes-Griffin and Franklin (1984). The seismic factor of safety was evaluated by applying a seismic horizontal force coefficient (k_h) and an additional horizontal force ($F = k_h \times W$) to each slice during a seismic event based on the weight of the slice. The k_h for each evaluated cross section was developed from the Maximum Horizontal Equivalent Acceleration (MHEA) computed during the site response analysis (Section 5) at the depth of the anticipated critical slip surface for each cross section. The k_h value is dependent on the allowable displacement (u) for an embankment or dike structure. For the purpose of this Safety Factor Assessment Report, the allowable displacement of the Ash Pond B perimeter dikes was selected as 12 inches (30.48 cm). Based on this allowable displacement and the upper bound relation, Hynes-Griffin and Franklin (1984) was applied to adjust the MHEA at the target depth by 0.5 to compute the k_h applied within SLIDE[®].

7.4 Static Safety Factor – Maximum Normal Storage Pool

§257.73(e)(1)(i) requires that the static factor of safety meets or exceeds 1.50 for the maximum normal storage pool conditions within the surface impoundment. The static safety factor was evaluated for Cross Sections A through D assuming that the free water level within Ash Pond B was maintained at 34.9 ft NGVD29 by a concrete riser structure.

7.5 Static Safety Factor – Maximum Surge Pool

§257.73(e)(1)(ii) requires that the static factor of safety meets or exceeds 1.40 for the maximum surge pool conditions within the surface impoundment. The static safety factor was evaluated for Cross Sections A through D assuming that the free water level within Ash Pond B was maintained at 37.1 ft NGVD29 and steady state conditions had been established within the perimeter dikes. The maximum surge pool elevation of 37.1 NGVD29 was computed as the peak free water level within Ash Pond B during and following the IDF (Section 2).

7.6 Seismic Safety Factor – Maximum Normal Storage Pool

§§257.73(e)(1)(iii) requires that the seismic factor of safety meets or exceeds 1.00 for the maximum normal storage pool conditions within the surface impoundment. A seismic horizontal force coefficient of 0.034, 0.031, 0.32, and 0.29 was computed for Cross Section A through D, respectively. As described in section 7.4, the Ash Pond B free water level was assumed to be maintained at 34.9 ft NGVD29 by a concrete riser structure. During the evaluation of the seismic safety factor, the undrained shear strength of cohesive soils was reduced by 20% to account for the influence of cyclic degradation (Hynes-Griffin and Franklin, 1984).

7.7 Liquefaction Safety Factor - Maximum Normal Storage Pool

§257.73(e)(1)(iv) requires that the liquefaction factor of safety meet or exceed 1.20 for the maximum normal storage pool conditions within the surface impoundment if dike fill soils are potentially liquefiable. As described in Section 6 of this Safety Factor Assessment Report, the perimeter dike fill and underlying foundation soils of Ash Pond B were not found to be liquefiable. Thus, a liquefaction safety factor assessment is not required to be evaluated for these conditions.

7.8 Summary of Results

The calculated minimum safety factor for each analysis case and each of these Cross

Sections A through D are summarized in Table 3. Cross Section C was calculated to have the lowest safety factors for the static safety factor cases; while Cross Section D was calculated to have the lowest safety factor for the seismic safety factor case. The results corresponding to the lowest calculated safety factor for the three evaluated scenarios are provided in Figures 10 through 12. These results indicate that the perimeter dikes of Ash Pond B at WGS meet the periodic safety factor assessment criteria required by §257.73(e)(1) of the CCR Rule. Further details of the safety factor assessment for Ash Pond B can be found in Attachment 8.

8. SUMMARY AND GENERAL CONCLUSIONS

The following section provides a summary and general conclusions of the safety factor assessment presented in this Safety Factor Assessment Report:

- The hydrologic and hydraulic performance of Ash Pond B during the 100-yr rainfall event was evaluated and the calculated maximum surcharge pool elevation within the surface impoundment was used in the safety factor assessment.
- A desktop review of site history and engineering reports (when available), geotechnical subsurface investigations, and laboratory testing programs was carried out to evaluate the construction history, characterize the dike and subsurface soils, and understand the existing conditions of Ash Pond B.
- The seismic hazard evaluation resulted in the selection of the design “bedrock” PGA as 0.16g at the Site. This bedrock PGA corresponds to a seismic event with a 2 percent probability of exceedance in 50 years as required by the CCR Rule and represents a peak ground motion corresponding to “geologically realistic” conditions. Site response analyses were performed to compute the maximum cyclic shear stresses and maximum horizontal equivalent accelerations, which were applied to evaluate the liquefaction potential and seismic safety factors of the Ash Pond B perimeter dikes.
- The evaluation of liquefaction potential indicated that the dike fill soil and foundation soils underlying the Ash Pond B perimeter dikes were not found to be liquefiable and the evaluation of the liquefaction safety factor was not required during the periodic safety factor evaluation. Further evaluation of liquefaction within foundation soils near the downstream perimeter dike toe (i.e., outside the perimeter dike footprint) will be presented in a subsequent evaluation of “Unstable Areas” for Ash Pond B at a later time.
- Based on the safety factor assessment of four representative cross sections of the Ash Pond B perimeter dikes, Ash Pond B meets the required safety factors presented in §257.73(e)(1).

Based on the evaluations presented within this Safety Factor Assessment Report, Ash Pond B satisfies the periodic safety factor criteria for existing surface impoundments described within §257.73(e) of the CCR Rule.

9. REFERENCES

- Bishop, A. (1955), “*The Use of the Slip Circle in the Stability Analysis of Slopes,*” *Géotechnique*, Volume 5, No. 1, Jan 1955, pp. 7-17.
- Bray, J.D. and Sancio, R.B. (2006) “Assessment of the Liquefaction Susceptibility of Fine-Grained Soils”. *Journal of Geotechnical and Geoenvironmental Engineering*, 132 (9), 1165-1177.
- Campbell, B.G., and Coes, A.L. (2010), *Groundwater availability in the Atlantic Coastal Plain of North and South Carolina: U.S. Geological Survey Professional Paper 1773*, 241 p., 7 pls.
- Chapman, M.C. and Talwani, P. (2006), “Seismic Hazard Mapping for Bridge and Highway Design in South Carolina”, South Carolina Department of Transportation, FHWA-SC-06-09.
- Doar, W.R. III (2012), *Geologic Map of the Georgetown South 7.5-minute Quadrangle*, Georgetown County, South Carolina.
- Geosyntec Consultants, Inc. (2016), “Hazard Potential Classification Assessment: Ash Pond B”, Project No. GSC5242.
- HydroCAD (2011), *HydroCAD Stormwater Modeling*, HydroCAD Software Solutions, LLC, revised 2011.
- Hynes-Griffin, M. and Franklin, A. (1984), “Rationalizing the Seismic Coefficient Method”, Department of the Army, Waterways Experiment Station, Corps of Engineers, Vicksburg, Mississippi, Miscellaneous Paper GL-84-14.
- Goulet, C.A., Kishida, T., Ancheta, T.D., Cramer, C.H., Darragh, R.B., Silva, W.J., Hashash, Y.M.A., Harmon, J., Stewart, J.P., Wooddell, K.E., and Youngs, R.R., (2014), “PEER NGA-East Database”, Pacific Earthquake Engineering Research Center, PEER 2014/17.
- Hashash, Y.M.A., Musgrove, M.I., Harmon, J.A., Groholski, D.R., Phillips, C.A., and Park, D., (2015), “DEEPSOIL 6.1, User Manual”, Board of Trustees of University of Illinois at Urbana-Champaign, Urbana, Illinois.
- Idriss, I. M., and Boulanger, R. W. (2008) “Soil Liquefaction During Earthquakes”, *Earthquake Engineering Research Institute*, EERI Publication MNO-12.

- Janbu, N. (1973), "Slope Stability Computations in Embankment-Dam Engineering", R.C. Hirschfeld and S.J. Poulos, Eds. New York: Wiley, pp. 47-86.
- Lockwood-Greene, (1972), A Drawing Set for Santee Cooper Winyah Generating Station.
- McGuire, R.K., Silva, W.J., and Constantino, C.J., (2001), "Technical Basis for Revision of Regulatory Guidance on Design Ground Motions: Hazrad- and Risk-consistent Ground Motion Spectra Guidelines", United States Nuclear Regulatory Commission, NUREG/CR-6728.
- Muthig, M.G and D.J. Colquhoun (1988), Formal recognition of two members within the Rhems Formation in Calhoun County, South Carolina: South Carolina Geology, V. 32, nos. 1-2, p. 11-19.
- NOAA. (2006). *Precipitation-Frequency Atlas of the United States*. Atlas 14, Volume 2, Version 3.0. National Oceanic and Atmospheric Administration.
- Paul C. Rizzo Associates (1993), Inc., "Report: Ash Pond B Dike Elevation: Winyah Generating Station", December 1993.
- Rocscience (2015), "SLIDE[®] – 2-D Limit Equilibrium Slope Stability for Soil and Rock Slopes," User's Guide, Rocscience Software, Inc., Toronto, Ontario, Canada.
- Santee Cooper. (2012). *Inter-Office Communication - WGS Ash Pond B - Abandon Existing Drawdown Structure*.
- Seed, H.B and Idriss, I.M. (1971), "Simplified Procedure for Evaluation Soil Liquefaction Potential", *Journal of the Soil Mechanics and Foundations Division*, ASCE, Vol. 107, NO. SM9.
- Soil Conservation Service (1982), *Technical Release Number 20 (TR-20)*, National Technical Information Service.
- South Carolina Department of Transportation (SCDOT) (2010), "SCDOT Geotechnical Design Manual: Chapter 13: Geotechnical Seismic Hazards".
- Spencer, E. (1973), "The Thrust Line Criterion in Embankment Stability Analysis," *Géotechnique*, Vol. 23, No. 1, pp. 85-100, March 1973.
- Thomas and Hutton (2012). "Topographic Survey of A Portion of Santee Cooper Winyah Generating Station", prepared for Santee Cooper, 14 January 2014.

Thomas and Hutton. (2016). "Topographic Survey of the Dike Crests at Santee Cooper Winyah Generating Station."

USACE (2000), "Design and Construction of Levees", EM-1110-2-1913, Washington DC, April 30, 2000.

USEPA (1995). "RCRA Subtitle D (258) Seismic Design Guidance for Municipal Solid Waste Landfill Facilities", Office of Research and Development, EPA/600/R-95/051, April 1995.

USGS (2002), "2002 Interactive Deaggregation".
<https://geohazards.usgs.gov/deaggint/2002/index.php>

USGS (2008), "US Seismic Hazard 2008".
<http://earthquake.usgs.gov/hazards/products/conterminous/2008/maps/>

TABLES

Table 1. Summary of Selected Geotechnical Material Properties

Material	Total Unit Weight (pcf) ^[2]	Drained Parameters		Undrained Parameters ^[1]	
		ϕ' (°)	c' (psf)	S_u/σ'_{vo}	$S_{u,min}$ (psf)
Dike Fill	125	38 to 40 ^[4]	0	-	-
Clayey Foundation Soils	100	18	250	Varies ^[5]	100
Upper Sandy Foundation Soils	115	36 to 38 ^[4]	0	-	-
Lower Sandy Foundation Soils	115	30 to 32 ^[4]	0	-	-
Chicora	130	50 ^[3]	0	-	-
Williamsburg Formation Clay	105	50 ^[3]	-	-	-
Fly Ash	100	34 ^[3]	34	-	-

Notes:

1. pcf = pounds per cubic feet; ϕ' = effective friction angle; c' = cohesion intercept; S_u/σ'_v = undrained shear strength ratio; and $S_{u,min}$ = minimum undrained shear strength.
2. Undrained strength parameters for clayey foundation soils were applied for the seismic slope stability case only. Dike fill soils were observed to consist primarily of poorly graded to silty sands in the vicinity of Ash Pond B.
3. The selection of shear strength parameters for Chicora, Williamsburg Formation Clay, and Fly Ash, as well as total unit weights for all materials, is explained in the Attachment 5.
4. These drained shear strengths (ϕ') vary by location. Interpretation of in-situ results applied in the selection is provided in Attachment 8.
5. The selected undrained strength ratio (S_u/σ'_{vo}) varies between locations and ranges from 0.25 to 0.45 for the selected cross section. Interpretation of in-situ results applied in the selection is provided in Attachment 8. A more detailed explanation of the undrained strength ratio for clayey foundation soils is provided in Attachment 5.

Table 2. Summary of Calculated Cyclic Shear Stresses

Profile 1		Profile 2	
Depth (ft)	τ_{max} (psf)	Depth (ft)	τ_{max} (psf)
1.5	23.0	1.5	20.0
5	62.4	5	60.0
9	93.8	9	90.0
13	119.4	13	112.9
16	140.3	17	138.5
19.5	164.0	20.5	162.5
24.5	188.6	24.5	187.6
29.5	202.8	29.5	205.0
34.5	212.8	34.5	214.9
39.5	221.0	39.5	222.4
44.5	231.1	44.5	232.6
49.5	295.2	49.5	289.7
57	380.8	57	378.5
67	462.0	67	463.2
77	551.4	77	564.4
87	659.4	87	672.9
97	779.4	97	794.9
107	936.7	107	944.1

Notes:

1. Profiles were developed in the Site Response Package provided as Attachment 6.
2. For calculation points located in between the depth intervals listed above, the average τ_{max} was linearly interpolated for liquefaction potential computations.
3. Profile 1 corresponds to the Ash Pond B perimeter dikes adjacent to the Discharge Canals; while, Profile 2 corresponds to the Ash Pond B perimeter dikes adjacent to the Cooling Pond.

Table 3. Summary of Calculated Safety Factors

Factor of Safety Case	Target FS	Cross Section A	Cross Section B	Cross Section C	Cross Section D
Static FS- Maximum Normal Storage Pool	1.50	1.97	1.80	<i>1.55^[3]</i>	1.74
Static FS- Maximum Surcharge Pool	1.40	1.91	1.74	<i>1.52^[3]</i>	1.63
Seismic FS- Maximum Normal Storage Pool	1.00	1.72	1.67	<i>1.04^[3]</i>	1.11
Liquefaction FS ^[1]	1.20	-	-	-	-

Notes:

1. The liquefaction safety factor was not evaluated since embankment soils were not found to be liquefiable.
2. Safety factors between 1.80 and 1.86 for a veneer or surficial slip surface (i.e., less than 2-ft deep) for the Cross Section A static slope stability case were computed but not reported within the above table. Safety factors shown above correspond to deep (i.e., global) slip surfaces.
3. The lowest computed safety factor for each analysis case was italicized.

FIGURES



SITE LOCATION MAP
WINYAH GENERATING STATION
 GEORGETOWN, SOUTH CAROLINA



Geosyntec
 consultants

Figure
1a

Greenville, SC

February 2016

Services Layer Sources: Copyright © 2011 National Geographic Society, Esri, DeLorme, NAVTEQ, UNEP-WFP, USGS, NASA, ESA, METI, NRCAN, GEBCO, NOAA, IPC



**SITE VICINITY MAP
WINYAH GENERATING STATION
GEORGETOWN, SOUTH CAROLINA**

Geosyntec
consultants

Figure
1b

Greenville, SC

February 2016

Service Layer Source: Copyright © 2013
National Geographic Society, i-cubed



□ Pond Boundary
— Property Boundary

Service Layer Credits: Source: Esri,
 DigitalGlobe, GeoEye, iSat, USGS,
 AEX, Geomatics, Aerogrid, IGN, IGP, and the
 GIS User Community

SITE LAYOUT MAP
WINYAH GENERATING STATION
 GEORGETOWN, SOUTH CAROLINA

Geosyntec
 consultants

Greenville, SC February 2016


Figure
2



LEGEND

— GAS	— GAS	EXISTING GAS LINE
— 30	— 30	EXISTING MAJOR GRADE CONTOUR
—	—	EXISTING RAILROAD
■	■	EXISTING WATER
◆	◆	EXISTING STAFF GAUGE
▼	▼	GEOSYNTEC CONE PENETRATION TEST
●	●	GEOSYNTEC SOIL BORING
◆	◆	HISTORICAL BORING
⊕	⊕	GROUNDWATER MONITORING WELL
■	■	PIEZOMETER

- NOTES:**
1. TOPOGRAPHIC SURVEY PROVIDED BY THOMAS & HUTTON DATED 06/26/11 AND REVISED ON 01/14/12.
 2. ELEVATIONS FROM THIS SURVEY ARE REFERENCED TO NSVD 1929 DATUM AS DERIVED FROM NGS MONUMENT PIDR011957.
 3. THE POSITION OF UNDERGROUND UTILITIES SHOWN ON THIS DRAWING IS BASED UPON THE LOCATION OF SURFACE APPLICANCES AND/OR SURFACE MARKINGS AND SHOULD BE CONSIDERED APPROXIMATE.



BORING LOCATION MAP - ASH POND B



FIGURE

3

PROJECT NO. GSC5242 OCTOBER 2018

Dike Soil Profile Models





Figure 4. Representative Subsurface Profiles for Site Response Analysis


- LEGEND**
- GAS
 - EXISTING GAS LINE
 - EXISTING MAJOR GRADE CONTOUR
 - EXISTING RAILROAD
 - EXISTING WATER
 - EXISTING STAFF GAUGE
 - GEOSYNTEC CONE PENETRATION TEST
 - GEOSYNTEC SOIL BORING
 - HISTORICAL BORING
 - GROUNDWATER MONITORING WELL
 - PIEZOMETER

- W-SW-APB
- CPT-144
- SPT-111
- B-1
- W-65-9
- PRZ-S, PPZ-W80



NOTES:

1. TOPOGRAPHIC SURVEY PROVIDED BY THOMAS & HUTTON DATED 06/26/11 AND REVISED ON 01/14/12.
2. ELEVATIONS FROM THIS SURVEY ARE REFERENCED TO NSVD 1929 DATUM AS DERIVED FROM NGS MONUMENT PIDRDD1957.
3. THE POSITION OF UNDERGROUND UTILITIES SHOWN ON THIS DRAWING IS BASED UPON THE LOCATION OF SURFACE APERTURES AND/OR SURFACE MARKINGS AND SHOULD BE CONSIDERED APPROXIMATE.



BORING LOCATION MAP - ASH POND B

Creosyntec
consultants

PROJECT NO. GSC5242 OCTOBER 2018

FIGURE 5




Figure 6. Cross Section A Geometry during Maximum Normal Operating Pool Conditions

Notes:

1. The water level at WAP-10 (dike toe) was measured as 21.9 ft NGVD29 on 20 June 2016 (Attachment 5).
2. "Maximum Surchage Pool" (not shown in this Figure) was computed as 37.1 ft NGVD29 within the Ash Pond B interior, as shown in Attachment 1.




Figure 7. Cross Section B Geometry during Maximum Normal Operating Pool Conditions

- Notes:
1. "Maximum Surcharge Pool" (not shown in this Figure) was computed as 37.1 ft NGVD29 within the Ash Pond B interior, as shown in Attachment I.




Figure 8. Cross Section C Geometry during Maximum Normal Operating Pool Conditions

Notes:

1. The water level at WAP-21 (dike crest) was measured as 26.6 ft NGVD29 on 20 June 2016 (Attachment 5). WAP-21 total depth shown was approximated as well construction information was not available. Water level interpreted from CPT-135 in 2013.
2. "Maximum Surcharge Pool" (not shown in this Figure) was computed as 37.1 ft NGVD29 within the Ash Pond B interior, as shown in Attachment 1.




Figure 9. Cross Section D Geometry during Maximum Normal Operating Pool Conditions

Notes:

1. The water level at WAP-20 (dike crest) was measured as 24.0 ft NGVD29 on 20 June 2016 (Attachment 5). WAP-20 total depth shown was approximated as well construction information was not available. Water level interpreted from CPT-136 in 2013.
2. "Maximum Surcharge Pool" (not shown in this Figure) was computed as 37.1 ft NGVD29 within the Ash Pond B interior, as shown in Attachment 1.




Figure 10. Critical FS for Cross Section C: Static FS - Maximum Normal Storage Pool




Figure 11. Critical FS for Cross Section C: Static FS - Maximum Surcharge Pool




Figure 12. Critical FS for Cross Section C: Seismic FS - Maximum Normal Storage Pool

ATTACHMENT 1

Hydrologic and Hydraulic (H&H) Analysis

COMPUTATION COVER SHEET

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242
Task No. 01

Title of Computations Hydrologic and Hydraulic Analysis for Ash Pond B

Computations by: Signature *Sarah M. Herr* Date 2/10/16

Printed Name Sarah Herr Date _____
Title Senior Staff Engineer

Assumptions and Procedures Checked by: Signature *Brianna L. Wallace* Date 10/11/16
(senior reviewer)

Printed Name Brianna Wallace Date _____
Title Senior Engineer

Computations, Assumptions, and Procedures Checked by: Signature *Hari Parthasarathy* Date 10/11/16
(peer reviewer)

Printed Name Hari Parthasarathy Date _____
Title Senior Staff Engineer

Computations backchecked by: Signature *Sarah M. Herr* Date 10/11/16
(originator)

Printed Name Sarah Herr Date _____
Title Senior Staff Engineer

Approved by: Signature *Brianna L. Wallace* Date 10/11/16
(pm or designate)

Printed Name Brianna Wallace Date _____
Title Senior Engineer

Approval notes: _____

Revisions (number and initial all revisions)

No.	Sheet	Date	By	Checked by	Approval
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____

Written by: S. Herr Date: 10/11/16 Reviewed by: B. Wallace Date: 10/11/16
 Client: **Santee** Project: **Winyah** Project/ Proposal No.: **GSC5242** Task No.: **01**
Cooper **Generating Station**

TABLE OF CONTENTS

PURPOSE AND BACKGROUND2
 METHODOLOGY3
 RESULTS8
 REFERENCES10

LIST OF TABLES

- Table 1 – Watershed Areas and Curve Numbers
- Table 2 – Input Parameters Describing Sheet Flow and Open Channel Flow
- Table 3 – Open Channel Dimensions
- Table 4 – Times of Concentration
- Table 5 – Stage Storage Table
- Table 6 – Peak Elevation and Volume

LIST OF FIGURES

- Figure 1 – Site Map
- Figure 2 – Ash Pond A Flow Path
- Figure 3 – Ash Pond B Flow Path
- Figure 4 – Photographs of Unit 2 Slurry Pond Pump

LIST OF APPENDICES

- Appendix A – *HydroCAD* Report – Final Model with Spillway

Written by: <u>S. Herr</u>	Date: <u>10/11/16</u>	Reviewed by: <u>B. Wallace</u>	Date: <u>10/11/16</u>
Client: Santee Cooper	Project: Winyah Generating Station	Project/ Proposal No.: GSC5242	Task No.: 01

PURPOSE AND BACKGROUND

Winyah Generating Station (WGS or the Site) is a coal-fired, electric generating facility located in Georgetown County, South Carolina. The Site is located between Pennyroyal and Turkey Creeks, tributaries to the Sampit River, and is approximately four miles southwest of Georgetown.

The purpose of this computation package is to evaluate the hydraulic capacity of Ash Pond B to support spillway capacity assessment requirements, static factor of safety analyses, and hazard rankings required by the United States Environmental Protection Agency’s (USEPA’s) Coal Combustion Residual (CCR) Rule. Ash Pond B is regulated by the CCR Rule as an existing CCR surface impoundment. Under the CCR Rule, a low hazard ranking classification is associated with the 100 year (yr) precipitation event. Since Ash Pond B is a low hazard surface impoundment, the 100 yr storm frequency is analyzed herein.

Ash Pond B, encompassing approximately 66 acres (ac), is located east of the power block. (Note that 66 ac is the area contained within the dike crest boundary. The area of the limits of CCR is slightly less at approximately 65 ac.) Ash Pond B is bounded by Ash Pond A to the north, the Cooling Pond to the east and south, and the Discharge Canal to the west. Ash Pond B is bounded by perimeter dikes ranging from 12.0 feet (ft) to 15.0 ft high on the west to 20.0 ft to 24.5 ft high on the east (Thomas and Hutton, 2012). The minimum crest elevation of the Ash Pond B perimeter dikes is 39.68 ft National Geodetic Vertical Datum of 1929 (NGVD 29) (Thomas and Hutton, 2016). A Site Map including the surface impoundments and hydraulic features associated with Ash Pond B is provided in **Figure 1**.

Ash Pond A does not have an outfall structure but routes water southward through rim ditches and culverts to Ash Pond B. Ash Ponds A and B are hydraulically connected through a 30 inch (in.) diameter corrugated metal pipe (CMP), a 48 in. diameter smooth steel pipe, and a 42 in. diameter smooth steel pipe (Thomas and Hutton, 2016; Thomas and Hutton, 2012).

Ash Pond B currently receives decanted ash sluice water, low volume wastewater, and Unit 2 Slurry Pond stormwater from Ash Pond A. Water is discharged through a riser

Written by: <u>S. Herr</u>	Date: <u>10/11/16</u>	Reviewed by: <u>B. Wallace</u>	Date: <u>10/11/16</u>
Client: Santee Cooper	Project: Winyah Generating Station	Project/ Proposal No.: GSC5242	Task No.: 01

structure with a horizontal outlet pipe approximately 100 linear ft in length to the Discharge Canal (Santee Cooper, 2012b; Thomas and Hutton, 2016).

METHODOLOGY

Stormwater runoff volumes and associated discharges to Ash Ponds A and B were modeled using *HydroCAD Version 10.0* software (HydroCAD, 2011). *HydroCAD* utilizes frequency-based precipitation events, in conjunction with watershed properties, to calculate peak runoff by several accepted methods. The Soil Conservation System (SCS) Technical Release 20 (TR-20) method was applied in *HydroCAD* to calculate stormwater runoff volumes (SCS, 1982).

The following parameters and assumptions were selected for calculating stormwater runoff volumes for Ash Ponds A and B.

Rainfall

The 72 hour (hr) duration precipitation event was used in this analysis. The rainfall depth corresponding to the 72 hr duration precipitation event for the 100 yr frequency return period for the site is 12.8 in. (NOAA, 2006). The design storm hyetograph was developed using SCS Type III rainfall distribution and was directly input into the *HydroCAD* model.

Drainage Areas and Curve Numbers

The contributing watershed areas for Ash Ponds A and B are 90.6 ac and 65.7 ac, respectively. These areas were delineated using the dike crests to correspond to the ponds' direct drainage areas. Each pond was assigned a curve number (CN) based on guidance provided in Technical Release 55 (TR-55) (SCS, 1986) representing the type of ground cover in that area. Ash Ponds A and B were assumed to be 90% CCR and 10% water (Weighted CN = 87) (Santee Cooper, 2012a). The contributing watershed areas and CNs are summarized in **Table 1** and were directly input to the *HydroCAD* model.

Time of Concentration Calculations

The time of concentration represents the time required for runoff to flow from the most hydraulically remote point of the drainage area to the point under investigation. The flow

Written by: <u>S. Herr</u>	Date: <u>10/11/16</u>	Reviewed by: <u>B. Wallace</u>	Date: <u>10/11/16</u>
Client: Santee Cooper	Project: Winyah Generating Station	Project/ Proposal No.: GSC5242	Task No.: 01

path from the most remote point within Ash Pond A is characterized by sheet flow and channel flow (shown in **Figure 2**).

HydroCAD applied the Overton and Meadows formulation to calculate travel time for sheet flow for distances less than 300 ft (NRCS, 2010):

$$T_t = \frac{0.007(nL)^{0.8}}{P_{2-24}^{0.5} S^{0.4}}$$

where:

- T_t = travel time for over land sheet flow (hr);
- n = Manning's roughness coefficient for sheet flow (--);
- L = flow length (ft);
- P_{2-24} = 2 yr, 24 hr rainfall (in.); and
- S = slope of hydraulic grade line (or land slope) (feet per foot [ft/ft]).

A Manning's roughness coefficient of 0.020 was used to represent sheet flow in Ash Pond A. The rainfall depth for the 2 yr, 24 hr frequency storm event is 4.38 in. (NOAA, 2006). The parameters used to model sheet flow within Ash Pond A are shown in **Table 2**.

Open channel flow travel time was calculated as:

$$T_t = \frac{L}{V}$$

where:

- T_t = travel time (seconds [s]);
- L = flow length (ft); and
- V = average velocity (feet per second [ft/s]).

Written by: <u>S. Herr</u>	Date: <u>10/11/16</u>	Reviewed by: <u>B. Wallace</u>	Date: <u>10/11/16</u>
Client: Santee Cooper	Project: Winyah Generating Station	Project/ Proposal No.: GSC5242	Task No.: 01

The open channel flow velocity was calculated using Manning's equation. The average velocity was computed assuming bank-full elevation as:

$$V = \frac{1.49}{n} R^{2/3} S^{1/2}$$

where: V = average velocity (ft/s);
 n = Manning's roughness coefficient (--);
 R = hydraulic radius (ft); and
 S = slope of hydraulic grade line (or longitudinal channel slope for normal flow conditions) (ft/ft).

A Manning's roughness coefficient of 0.020 was used to represent open channel flow in Ash Pond A. Channel dimensions were estimated using topographic data, and these dimensions are summarized in **Table 3** (Thomas and Hutton, 2012). The hydraulic radius was computed as:

$$R = \frac{A}{P_w}$$

where: R = hydraulic radius (ft);
 A = cross sectional flow area (square feet [sq ft]); and
 P_w = wetted perimeter (ft).

The cross sectional flow area was calculated by:

$$A = (B + DZ)D$$

where: A = cross sectional flow area (sq ft);
 B = bottom width of the channel (ft);
 D = depth of the channel (ft); and

Written by: <u>S. Herr</u>	Date: <u>10/11/16</u>	Reviewed by: <u>B. Wallace</u>	Date: <u>10/11/16</u>
Client: Santee Cooper	Project: Winyah Generating Station	Project/ Proposal No.: GSC5242	Task No.: 01

Z = side slope of the channel (horizontal run divided by vertical rise) (ft/ft).

The wetted perimeter was calculated by:

$$P_w = B + 2D\sqrt{1 + Z^2}$$

where: P_w = wetted perimeter (ft);

B = bottom width of the channel (ft);

D = depth of the channel (ft); and

Z = side slope of the channel (horizontal run divided by vertical rise) (ft/ft).

The parameters used to describe open channel flow in Ash Pond A are presented in **Table 2**. The computed times of concentration for Ash Pond A are summarized in **Table 4**.

Flow within Ash Pond B is characterized entirely as open channel flow (shown in **Figure 3**). Open channel flow within Ash Pond B was characterized using the method previously described for Ash Pond A. The flow velocity was calculated using Manning's equation. A Manning's roughness coefficient of 0.020 was used to represent open channel flow in Ash Pond B. Channel dimensions were estimated using topographic data, and these dimensions are summarized in **Table 3** (Thomas and Hutton, 2012). The parameters used to describe flow within Ash Pond B are presented in **Table 2**. The resulting time of concentration is presented in **Table 4**.

Inflows

In the *HydroCAD* model, stormwater inflows associated with Ash Ponds A and B are represented by Sub-Catchments 1S and 2S, respectively. Ponds 3P and 4P represent Ash Ponds A and B, respectively. In addition to direct stormwater inflow, Ash Pond A receives contact stormwater from the Unit 2 Slurry Pond. As shown in **Figure 4**, the Unit 2 Slurry Pond is equipped with a 6JSVE Thompson pump (Thompson Pump, 2016). The maximum pump capacity, 2,600 gallons per minute (gpm) (5.79 cubic feet per second [cfs]), is utilized in the *HydroCAD* model since the design operating point is unavailable.

Written by: <u>S. Herr</u>	Date: <u>10/11/16</u>	Reviewed by: <u>B. Wallace</u>	Date: <u>10/11/16</u>
Client: Santee Cooper	Project: Winyah Generating Station	Project/ Proposal No.: GSC5242	Task No.: 01

This base flow is modeled as Node 5L in *HydroCAD* and contributes to the inflow to Pond 3P.

Ash Pond A also receives Units 1 and 2 low volume wastewater (550 gpm), Units 1 and 2 hydroveyor water and fly ash sluice (3,364 gpm), Units 1 and 2 bottom ash sluice water (725 gpm), and Units 3 and 4 bottom ash sluice water (1,460 gpm). The base flow considers process water when all four units are operational, resulting in an inflow of 6,099 gpm (13.59 cfs) (Santee Cooper, 2015). This base flow is modeled as Node 6L in *HydroCAD* and contributes to the inflow to Pond 3P. The *HydroCAD* model routing diagram is provided in **Appendix A**.

Storage Capacities

The available stormwater storage volume of Ash Pond A between elevations 34.0 ft and 38.8 ft NGVD 29 was calculated by developing an area-volume curve based on topographic data (Thomas and Hutton, 2012; Thomas and Hutton, 2016). The minimum crest elevation of the Ash Pond A perimeter dikes is 38.8 ft NGVD 29. The surface area of each contour was measured and tabulated at each elevation. The available surface water volume in each 2 ft depth increment was calculated by averaging the surface area of the upper and lower contour and multiplying by the change in elevation between each contour. The cumulative storage volume of Ash Pond A between these elevations is 12.5 acre-feet (ac-ft). The area-volume data are presented in **Table 5**.

Similarly, the available stormwater storage volume of Ash Pond B between elevations 34.0 ft and 39.7 ft NGVD 29 was calculated by developing an area-volume curve based on topographic and bathymetric data (Thomas and Hutton, 2012; Thomas and Hutton, 2016). A bathymetric survey has not been completed for Ash Pond B. The average operating elevation provided by the plant from February 2011 through January 2016 is 34.1 ft (Santee Cooper, WGS, 2016). Elevation 34.1 is used as the starting water surface elevation for Pond B in the model. The minimum crest elevation of the Ash Pond B perimeter dikes is 39.7 ft NGVD 29. The surface area of each contour was measured and tabulated at each elevation. Next, the available surface water volume at each 2 ft depth increment was calculated by averaging the surface area of the upper and lower contour and multiplying by the change in elevation between each contour. The cumulative storage volume of Ash Pond B between these elevations is 220.3 ac-ft. The area-volume data are presented in **Table 5**.

Written by: <u>S. Herr</u>	Date: <u>10/11/16</u>	Reviewed by: <u>B. Wallace</u>	Date: <u>10/11/16</u>
Client: Santee Cooper	Project: Winyah Generating Station	Project/ Proposal No.: GSC5242	Task No.: 01

Outlet Structures

The outlets from Ash Pond A to Ash Pond B are a 30 in. diameter CMP culvert with an upstream invert at 37.50 ft NGVD 29 and a downstream invert at 36.52 ft NGVD 29, a 48 in. diameter smooth steel pipe with an upstream invert at 35.49 ft NGVD 29 and a downstream invert at 35.28 ft NGVD 29, and a 42 in. diameter smooth steel pipe with an upstream invert at 36.20 ft NGVD 29 and a downstream invert at 35.70 ft NGVD 29 (Thomas and Hutton, 2016; Thomas and Hutton, 2012). These outlet pipes allow water to drain from Ash Pond A to Ash Pond B.

The operating level in Ash Pond B is maintained by a concrete riser structure with an internal length of 4 ft and an internal width of 4 ft (Santee Cooper, 2012b). The concrete riser structure has 4 ft long stop logs on a single face, and the top stop log elevation is 34.90 ft NGVD 29 (Santee Cooper, 2012b; Thomas and Hutton, 2016). A 24 in. diameter smooth interior, corrugated exterior high density polyethylene pipe culvert with a downstream invert elevation of 17.99 ft NGVD 29 conveys water from the riser structure to the Discharge Canal of the Cooling Pond (Santee Cooper, 2012b; Thomas and Hutton, 2016).

The tailwater effects associated with discharge from Ash Pond B to the Discharge Canal were modeled using a fixed water surface elevation within the Discharge Canal and Cooling Pond. This tailwater surface elevation was estimated by conservatively assuming 2.5 ft depth of water over the Cooling Pond emergency spillway during the 100 yr storm event. The top of the stop log bolted to the top of the concrete spillway of the Cooling Pond is at elevation 21.65 ft NGVD 29 (Thomas and Hutton, 2015). The water surface of the Discharge Canal and Cooling Pond was assumed to be at 24.15 ft NGVD 29 (21.65 ft NGVD 29 plus an additional 2.5 ft of water). The tailwater effects associated with the Discharge Canal and Cooling Pond were represented by Node 7L in the *HydroCAD* model.

RESULTS

As currently operated, Ash Pond A will not contain the 100 yr storm event. Ash Pond A does not have an existing emergency spillway. The construction of a spillway on the divider dike between Ash Ponds A and B is required to convey stormwater from Ash

Written by: S. Herr Date: 10/11/16 Reviewed by: B. Wallace Date: 10/11/16
 Client: **Santee Cooper** Project: **Winyah Generating Station** Project/Proposal No.: **GSC5242** Task No.: **01**

Pond A to Ash Pond B so the ponds contain the 100 yr storm event. A proposed spillway is included in the *HydroCAD* model and report in **Appendix A**.

Ash Pond A contains the 100 yr, 72 hr storm event given the following assumption:

- Santee Cooper will construct a 100 ft wide spillway with an invert elevation of 37.0 ft NGVD 29 in the divider dike between Ash Ponds A and B. The spillway will be constructed with 10H:1V (Horizontal:Vertical) side slopes and will be located between the 48 in. diameter smooth steel pipe and the 42 in. diameter smooth steel pipe.

The spillway is currently under construction. Operational Plans are in place in case the design storm event occurs before the construction of the spillway is completed.

The resulting peak water surface elevation and storage volume for the 100 yr storm event is shown in **Table 6**. During this storm event, Ash Ponds A and B will effectively operate as a single pond as the culverts and spillway provide a hydraulic connection between the storage areas in both ponds.

Written by: S. Herr Date: 10/11/16 Reviewed by: B. Wallace Date: 10/11/16
 Client: **Santee Cooper** Project: **Winyah Generating Station** Project/Proposal No.: **GSC5242** Task No.: **01**

REFERENCES

HydroCAD. (2011). *HydroCAD Stormwater Modeling*. HydroCAD Software Solutions, LLC.

NOAA. (2006). *Precipitation-Frequency Atlas of the United States*. Atlas 14, Volume 2, Version 3.0. National Oceanic and Atmospheric Administration.

NRCS. (2010). National Engineering Handbook, Part 630: Hydrology.

Santee Cooper. (2012a). *Hydrologic and Hydraulic Analysis for Winyah Generating Station: Ash Ponds A & B*.

Santee Cooper. (2012b). *Inter-Office Communication - WGS Ash Pond B - Abandon Existing Drawdown Structure*.

Santee Cooper. (2015). *Winyah Generating Station - NPDES Flowchart*.

Santee Cooper, WGS. (2016, 01 12). Email correspondence, LIMS data for Ash Pond B Water Surface Elevations from 2/1/11 through 1/11/2016.

SCS. (1982). *Technical Release Number 20 (TR-20)*. Soil Conservation Service. National Technical Information Service.

SCS. (1986). *Technical Release Number 55 (TR-55)*. Soil Conservation Service. National Technical Information Service.

Thomas and Hutton. (2012). *Topographic Survey of a Portion of Santee Cooper Winyah Generating Station*.

Thomas and Hutton. (2015). *Topographic Survey of the Cooling Pond at Santee Cooper Winyah Generating Station*.

Thomas and Hutton. (2016). *Topographic Survey of the Dike Crests at Santee Cooper Winyah Generating Station*.

Thomas and Hutton. (2016). *Topographic Survey of the Dike Crests at Santee Cooper Winyah Generating Station*.

Written by: S. Herr Date: 10/11/16 Reviewed by: B. Wallace Date: 10/11/16
Client: **Santee** Project: **Winyah** Project/ Task
Cooper **Generating Station** Proposal No.: **GSC5242** No.: **01**

Thompson Pump. (2016, February). *Oil-less Vacuum Prime High Head Solids Handling Pumps Dry Prime*. Retrieved from Thompson Pump:
<https://www.thompsonpump.com/Oil-less-Vacuum-Prime-High-Head-Solids-Handling-Pumps-Dry-Prime--JSV--10-51.html>

TABLES

Table 1 – Watershed Areas and Curve Numbers

Drainage Basin	Area (ac)	Weighted Curve Number (--)
Ash Pond A	88.954	87
Ash Pond B	65.693	87

Table 2 – Input Parameters Describing Sheet Flow and Open Channel Flow

Flow Path	Sheet Flow			Open Channel Flow					
	Land Slope (ft/ft)	Manning's Roughness Coefficient (-)	Flow Length (ft)	2 Yr. 2 Hr Rainfall (in)	Cross Sectional Area (sq ft)	Wetted Perimeter (ft)	Channel Slope (ft/ft)	Manning's Roughness Coefficient (-)	Flow Length (ft)
<i>Ash Pond A</i>									
Sheet	0.0663	0.020	60	4.38	--	--	--	--	--
Channel	--	--	--	--	147	59.0	0.0025	0.020	3.100
<i>Ash Pond B</i>									
Channel	--	--	--	--	78	33.4	0.0025	0.020	3.650

Table 3 – Open Channel Dimensions

Flow Path	Channel Configuration	Side Slope Ratio (H:V) (ft:ft)	Bottom Width of the Channel (ft)	Depth of the Channel (ft)
<i>Ash Pond A</i>				
Channel	Trapezoidal	3:1	40	3
<i>Ash Pond B</i>				
Channel	Trapezoidal	2:1	20	3

Table 4 – Times of Concentration

Flow Path	Time of Concentration (minutes [min])
<i>Ash Pond A</i>	
Sheet	0.7
Channel	7.6
<i>Ash Pond B</i>	
Channel	9.3

Table 5 – Stage Storage Table (Thomas and Hutton, 2012; Thomas and Hutton, 2016)

Ash Pond A				Ash Pond B			
<i>Elevation (NGVD 29) (ft)</i>	<i>Area (ac)</i>	<i>Volume (ac-ft)</i>	<i>Cumulative Volume (ac-ft)</i>	<i>Elevation (NGVD 29) (ft)</i>	<i>Area (ac)</i>	<i>Volume (ac-ft)</i>	<i>Cumulative Volume (ac-ft)</i>
38.8	8.529	5.3	12.5	39.68	62.066	101.6	220.3
38	4.726	5.7	7.2	38	58.863	88.8	118.7
36	1.014	1.5	1.5	36	29.915	29.9	29.9
34	0.460	0.0	0.0	34	0.006	0.0	0.0

Table 6 – Peak Elevation and Volume


Storm Event	Ash Pond B		
	<i>Elevation (ft)</i>	<i>Volume (ac-ft)</i>	<i>Time (hr)</i>
100 Yr, 72 Hr	37.17	74.828	41.98

FIGURES



LEGEND

- POND BOUNDARY
- BOTTOM ASH SLUICE AND BOILER SLAG
- CONTACT STORMWATER FROM UNIT 2 SLURRY POND
- FLY ASH SLUICE AND LOW VOLUME WASTEWATER




WINYAH GENERATING STATION
SITE MAP



FIGURE

1

PROJECT NO. GSC5242 OCTOBER 2016



LEGEND

- SHEET FLOW
- CHANNEL FLOW
- ~ GENERAL FLOW DIRECTION




WINYAH GENERATING STATION
ASH POND A FLOW PATH

Geosyntec
consultants

PROJECT NO. GSC5242 OCTOBER 2016

FIGURE
2



LEGEND

- CHANNEL FLOW
- ~ GENERAL FLOW DIRECTION



WINYAH GENERATING STATION
ASH POND B FLOW PATH

Geosyntec
consultants

FIGURE

3


PROJECT NO. GSC5242 OCTOBER 2016



Figure 4 – Photographs of Unit 2 Slurry Pond Pump

APPENDICES

APPENDIX A



Ash Pond A B - Spillway Revision

Prepared by Geosyntec Consultants

HydroCAD® 10.00-16 s/n 00939 © 2015 HydroCAD Software Solutions LLC

Printed 10/12/2016

Page 2

Area Listing (all nodes)

Area (acres)	CN	Description (subcatchment-numbers)
154.647	87	90% Ash and 10% Water Surface (1S, 2S)
154.647	87	TOTAL AREA

Time span=0.00-600.00 hrs, dt=0.01 hrs, 60001 points
Runoff by SCS TR-20 method, UH=SCS, Weighted-CN
Reach routing by Sim-Route method - Pond routing by Sim-Route method

Subcatchment1S: Ash Pond A Runoff Area=88.954 ac 0.00% Impervious Runoff Depth=11.17"
Flow Length=3,160' Tc=8.3 min CN=87 Runoff=403.49 cfs 82.775 af

Subcatchment2S: Ash Pond B Runoff Area=65.693 ac 0.00% Impervious Runoff Depth=11.17"
Flow Length=3,650' Slope=0.0025 '/ Slope=0.0025 '/ Tc=9.3 min CN=87 Runoff=294.30 cfs 61.130 af

Pond 3P: Ash Pond A Peak Elev=38.13' Storage=7.875 af Inflow=422.87 cfs 1,043.751 af
Primary=55.02 cfs 839.100 af Secondary=320.83 cfs 206.216 af Outflow=375.85 cfs 1,045.316 af

Pond 4P: Ash Pond B Peak Elev=37.17' Storage=74.828 af Inflow=347.09 cfs 900.215 af
Primary=0.00 cfs 0.000 af Secondary=0.00 cfs 0.000 af Tertiary=21.76 cfs 865.546 af Outflow=21.76 cfs 865.546 af

Link 5L: Unit 2 Slurry Pond Manual Hydrograph Inflow=5.79 cfs 287.112 af
Primary=5.79 cfs 287.107 af

Link 6L: Process Water Manual Hydrograph Inflow=13.59 cfs 673.896 af
Primary=13.59 cfs 673.884 af

Link 7L: Discharge Canal Inflow=21.76 cfs 865.531 af
Primary=21.76 cfs 865.531 af

Total Runoff Area = 154.647 ac Runoff Volume = 143.905 af Average Runoff Depth = 11.17"
100.00% Pervious = 154.647 ac 0.00% Impervious = 0.000 ac

Summary for Subcatchment 1S: Ash Pond A

Runoff = 403.49 cfs @ 36.12 hrs, Volume= 82.775 af, Depth=11.17"


Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-600.00 hrs, dt= 0.01 hrs
 Type III 24-hr 72.00 hrs 100-YR, 72-HR Rainfall=12.80"

Area (ac)	CN	Description
* 88.954	87	90% Ash and 10% Water Surface
88.954		100.00% Pervious Area

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
0.7	60	0.0663	1.45		Sheet Flow, Sheet Flow n= 0.020 P2= 4.38"
7.6	3,100	0.0025	6.83	1,003.66	Channel Flow, Channel Flow Area= 147.0 sf Perim= 59.0' r= 2.49' n= 0.020
8.3	3,160	Total			

Subcatchment 1S: Ash Pond A

Hydrograph



Summary for Subcatchment 2S: Ash Pond B

Runoff = 294.30 cfs @ 36.13 hrs, Volume= 61.130 af, Depth=11.17"


Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-600.00 hrs, dt= 0.01 hrs
 Type III 24-hr 72.00 hrs 100-YR, 72-HR Rainfall=12.80"

Area (ac)	CN	Description
* 65.693	87	90% Ash and 10% Water Surface
65.693		100.00% Pervious Area

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
9.3	3,650	0.0025	6.54	510.06	Channel Flow, Channel Flow Area= 78.0 sf Perim= 33.4' r= 2.34' n= 0.020

Subcatchment 2S: Ash Pond B

Hydrograph



Runoff

**Type III 24-hr 72.00 hrs
 100-YR
 72-HR Rainfall=12.80"
 Runoff Area=65.693 ac
 Runoff Volume=61.130 af
 Runoff Depth=11.17"
 Flow Length=3,650'
 Slope=0.0025 '/'
 Tc=9.3 min
 CN=87**

Summary for Pond 3P: Ash Pond A

Inflow = 422.87 cfs @ 36.12 hrs, Volume= 1,043.751 af
 Outflow = 375.85 cfs @ 36.22 hrs, Volume= 1,045.316 af, Atten= 11%, Lag= 6.3 min
 Primary = 55.02 cfs @ 36.22 hrs, Volume= 839.100 af
 Secondary = 320.83 cfs @ 36.22 hrs, Volume= 206.216 af

Routing by Sim-Route method, Time Span= 0.00-600.00 hrs, dt= 0.01 hrs
 Starting Elev= 37.50' Surf.Area= 3.798 ac Storage= 5.083 af
 Peak Elev= 38.13' @ 36.22 hrs Surf.Area= 5.350 ac Storage= 7.875 af (2.792 af above start)

Plug-Flow detention time= 123.4 min calculated for 1,040.233 af (100% of inflow)
 Center-of-Mass det. time= (not calculated: outflow precedes inflow)

Volume	Invert	Avail.Storage	Storage Description
#1	34.00'	12.516 af	Custom Stage Data (Prismatic) Listed below (Recalc)
Elevation (feet)	Surf.Area (acres)	Inc.Store (acre-feet)	Cum.Store (acre-feet)
34.00	0.460	0.000	0.000
36.00	1.014	1.474	1.474
38.00	4.726	5.740	7.214
38.80	8.529	5.302	12.516

Device	Routing	Invert	Outlet Devices
#1	Primary	37.50'	30.0" Round Culvert 1 L= 40.8' CMP, projecting, no headwall, Ke= 0.900 Inlet / Outlet Invert= 37.50' / 36.52' S= 0.0240 '/ Cc= 0.900 n= 0.025 Corrugated metal, Flow Area= 4.91 sf
#2	Primary	35.49'	48.0" Round Culvert 2 L= 30.9' CMP, projecting, no headwall, Ke= 0.900 Inlet / Outlet Invert= 35.49' / 35.28' S= 0.0068 '/ Cc= 0.900 n= 0.012 Steel, smooth, Flow Area= 12.57 sf
#3	Primary	36.20'	42.0" Round Culvert 3 L= 24.6' CMP, projecting, no headwall, Ke= 0.900 Inlet / Outlet Invert= 36.20' / 35.70' S= 0.0203 '/ Cc= 0.900 n= 0.012 Steel, smooth, Flow Area= 9.62 sf
#4	Secondary	37.00'	100.0' long x 12.0' breadth Broad-Crested Rectangular Weir Head (feet) 0.20 0.40 0.60 0.80 1.00 1.20 1.40 1.60 Coef. (English) 2.57 2.62 2.70 2.67 2.66 2.67 2.66 2.64

Primary OutFlow Max=55.01 cfs @ 36.22 hrs HW=38.13' TW=36.80' (Dynamic Tailwater)


- ↑ 1=Culvert 1 (Inlet Controls 2.08 cfs @ 2.14 fps)
- ↑ 2=Culvert 2 (Barrel Controls 32.60 cfs @ 5.25 fps)
- ↑ 3=Culvert 3 (Inlet Controls 20.33 cfs @ 3.74 fps)

Secondary OutFlow Max=320.77 cfs @ 36.22 hrs HW=38.13' (Free Discharge)

- ↑ 4=Broad-Crested Rectangular Weir (Weir Controls 320.77 cfs @ 2.84 fps)

Pond 3P: Ash Pond A

Hydrograph



Summary for Pond 4P: Ash Pond B

Inflow = 347.09 cfs @ 36.14 hrs, Volume= 900.215 af
 Outflow = 21.76 cfs @ 41.98 hrs, Volume= 865.546 af, Atten= 94%, Lag= 350.4 min
 Primary = 0.00 cfs @ 0.00 hrs, Volume= 0.000 af
 Secondary = 0.00 cfs @ 0.00 hrs, Volume= 0.000 af
 Tertiary = 21.76 cfs @ 41.98 hrs, Volume= 865.546 af

Routing by Sim-Route method, Time Span= 0.00-600.00 hrs, dt= 0.01 hrs
 Starting Elev= 34.14' Surf.Area= 2.100 ac Storage= 0.147 af
 Peak Elev= 37.17' @ 41.98 hrs Surf.Area= 46.848 ac Storage= 74.828 af (74.681 af above start)

Plug-Flow detention time= 1,529.0 min calculated for 865.384 af (96% of inflow)
 Center-of-Mass det. time= 799.9 min (18,019.4 - 17,219.6)


Volume	Invert	Avail.Storage	Storage Description
#1	34.00'	220.274 af	Custom Stage Data (Prismatic) Listed below (Recalc)
Elevation (feet)	Surf.Area (acres)	Inc.Store (acre-feet)	Cum.Store (acre-feet)
34.00	0.006	0.000	0.000
36.00	29.915	29.921	29.921
38.00	58.860	88.775	118.696
39.68	62.066	101.578	220.274

Device	Routing	Invert	Outlet Devices
#1	Tertiary	31.21'	21.6" Round Culvert L= 113.3' CPP, projecting, no headwall, Ke= 0.900 Inlet / Outlet Invert= 31.21' / 17.99' S= 0.1167 '/ Cc= 0.900 n= 0.013 Corrugated PE, smooth interior, Flow Area= 2.54 sf
#2	Device 1	34.90'	4.0' long Sharp-Crested Rectangular Weir 2 End Contraction(s)
#3	Primary	37.50'	30.0" Round Culvert 1 L= 40.8' CMP, projecting, no headwall, Ke= 0.900 Inlet / Outlet Invert= 36.52' / 37.50' S= -0.0240 '/ Cc= 0.900 n= 0.025 Corrugated metal, Flow Area= 4.91 sf
#4	Primary	35.49'	48.0" Round Culvert 2 L= 30.9' CMP, projecting, no headwall, Ke= 0.900 Inlet / Outlet Invert= 35.28' / 35.49' S= -0.0068 '/ Cc= 0.900 n= 0.012 Steel, smooth, Flow Area= 12.57 sf
#5	Primary	36.20'	42.0" Round Culvert 3 L= 24.6' CMP, projecting, no headwall, Ke= 0.900 Inlet / Outlet Invert= 35.70' / 36.20' S= -0.0203 '/ Cc= 0.900 n= 0.012 Steel, smooth, Flow Area= 9.62 sf
#6	Secondary	37.00'	100.0' long x 12.0' breadth Broad-Crested Rectangular Weir Head (feet) 0.20 0.40 0.60 0.80 1.00 1.20 1.40 1.60 Coef. (English) 2.57 2.62 2.70 2.67 2.66 2.67 2.66 2.64

- Primary OutFlow Max=0.00 cfs @ 0.00 hrs HW=34.14' TW=37.50' (Dynamic Tailwater)
 - 3=Culvert 1 (Controls 0.00 cfs)
 - 4=Culvert 2 (Controls 0.00 cfs)
 - 5=Culvert 3 (Controls 0.00 cfs)
- Secondary OutFlow Max=0.00 cfs @ 0.00 hrs HW=34.14' TW=37.50' (Dynamic Tailwater)
 - 6=Broad-Crested Rectangular Weir (Controls 0.00 cfs)
- Tertiary OutFlow Max=21.76 cfs @ 41.98 hrs HW=37.17' TW=24.15' (Dynamic Tailwater)
 - 1=Culvert (Inlet Controls 21.76 cfs @ 8.55 fps)
 - 2=Sharp-Crested Rectangular Weir (Passes 21.76 cfs of 39.66 cfs potential flow)

Pond 4P: Ash Pond B

Hydrograph



Summary for Link 5L: Unit 2 Slurry Pond

Inflow = 5.79 cfs @ 0.00 hrs, Volume= 287.112 af
 Primary = 5.79 cfs @ 0.01 hrs, Volume= 287.107 af, Atten= 0%, Lag= 0.6 min


Primary outflow = Inflow, Time Span= 0.00-600.00 hrs, dt= 0.01 hrs

61 Point manual hydrograph, To= 0.00 hrs, dt= 10.00 hrs, cfs =

5.79	5.79	5.79	5.79	5.79	5.79	5.79	5.79	5.79	5.79
5.79	5.79	5.79	5.79	5.79	5.79	5.79	5.79	5.79	5.79
5.79	5.79	5.79	5.79	5.79	5.79	5.79	5.79	5.79	5.79
5.79	5.79	5.79	5.79	5.79	5.79	5.79	5.79	5.79	5.79
5.79	5.79	5.79	5.79	5.79	5.79	5.79	5.79	5.79	5.79
5.79	5.79	5.79	5.79	5.79	5.79	5.79	5.79	5.79	5.79
5.79	5.79	5.79	5.79	5.79	5.79	5.79	5.79	5.79	5.79
5.79	5.79	5.79	5.79	5.79	5.79	5.79	5.79	5.79	5.79
5.79	5.79	5.79	5.79	5.79	5.79	5.79	5.79	5.79	5.79
5.79	5.79	5.79	5.79	5.79	5.79	5.79	5.79	5.79	5.79

Link 5L: Unit 2 Slurry Pond

Hydrograph



Summary for Link 6L: Process Water

Inflow = 13.59 cfs @ 0.00 hrs, Volume= 673.896 af
 Primary = 13.59 cfs @ 0.01 hrs, Volume= 673.884 af, Atten= 0%, Lag= 0.6 min


Primary outflow = Inflow, Time Span= 0.00-600.00 hrs, dt= 0.01 hrs

61 Point manual hydrograph, To= 0.00 hrs, dt= 10.00 hrs, cfs =

13.59	13.59	13.59	13.59	13.59	13.59	13.59	13.59	13.59	13.59
13.59	13.59	13.59	13.59	13.59	13.59	13.59	13.59	13.59	13.59
13.59	13.59	13.59	13.59	13.59	13.59	13.59	13.59	13.59	13.59
13.59	13.59	13.59	13.59	13.59	13.59	13.59	13.59	13.59	13.59
13.59	13.59	13.59	13.59	13.59	13.59	13.59	13.59	13.59	13.59
13.59	13.59	13.59	13.59	13.59	13.59	13.59	13.59	13.59	13.59
13.59	13.59	13.59	13.59	13.59	13.59	13.59	13.59	13.59	13.59
13.59	13.59	13.59	13.59	13.59	13.59	13.59	13.59	13.59	13.59
13.59	13.59	13.59	13.59	13.59	13.59	13.59	13.59	13.59	13.59
13.59	13.59	13.59	13.59	13.59	13.59	13.59	13.59	13.59	13.59

Link 6L: Process Water

Hydrograph




Summary for Link 7L: Discharge Canal

Inflow = 21.76 cfs @ 41.98 hrs, Volume= 865.531 af
Primary = 21.76 cfs @ 41.99 hrs, Volume= 865.531 af, Atten= 0%, Lag= 0.6 min

Primary outflow = Inflow, Time Span= 0.00-600.00 hrs, dt= 0.01 hrs

Fixed water surface Elevation= 24.15'

Link 7L: Discharge Canal



ATTACHMENT 2

Boring Logs

ATTACHMENT 2-A
Geosyntec Boring Logs

BOREHOLE ID: SPT-114

GENERAL INFORMATION

PROJECT NAME: Winyah Generating Station
PROJECT NO: GSC5242
SITE LOCATION: Georgetown, South Carolina
BORING DATE: 9/25/2013
GEOSYNTec REPRESENTATIVE: J. McNash
DRILLING CONTRACTOR: Soil Consultants, Inc.
DRILLER NAME: M. Grimball

TECHNICAL INFORMATION

DRILLING METHOD: Mud Rotary
RIG TYPE: CME 550 X
BOREHOLE DIA: 4"
SAMPLING METHOD: SPT w/ split spoon
NORTHING: 544064.6303
EASTING: 2503599.4656
GROUND ELEVATION: 41.48 ft NGVD29

Elev. (ft NGVD 29)	Depth (ft)	Lithologic Description	Pattern	SPT Blows	N-Value					Recovery	Comments
					0	10	20	30	40		
0	0										Surface of perimeter dike appears to be bottom ash.
40											
	-5	Medium dense, light brown to gray, clayey SAND (SC).		6-10-11						16"	MC = 15.8%; Gravel = 0.3%; Sand = 72.8%; Silt = 7.4%; Clay = 19.5%. LL = NP; PL = NP; PI = NP.
35											
	-10	Dense, black to brown to gray layered, fine SAND, slightly silty (SP).		11-21-16						12"	
30											
	-15	Very dense, gray to dark brown, fine SAND (SP), slightly silty.		8-31-33						14"	N-value = 64 blows/ft.
25											
	-20	Very dense, brown to light gray, clean, fine SAND (SP).		11-23-28						12"	Water level measured as 19.10 ft bgs on 9/26/2013. N-value = 51 blows/ft.
20											
	-25	Dense, gray to dark brown, fine SAND (SP) with silt.		8-17-15						10"	MC = 23.2%; Fines = 9.2%.
15				ST-1						11"	Shelby Tube advanced 24" from 26.50 to 28.50 ft bgs.
	-30	Medium dense, dark brown, fine SAND (SP), slightly silty.		4-7-10						11"	Borehole collapsed at 30.00 ft bgs. Tremie grouted from 30.00 ft bgs.
10											













All depths referenced to ground surface.

Total Depth: 61.00 ft bgs

BORING LOG

Borehole ID: SPT-114

Project No: GSC5242

Elev. (ft NGVD29)	Depth (ft)	Lithologic Description	Pattern	SPT Blows	N-Value					Recovery	Comments
					0	10	20	30	40		
	-35	Loose, brown, fine SAND (SP) with silt.		2-2-5						8"	MC = 25.7%; Fines = 7.0%. Shelby Tube advanced 24" from 36.50 to 38.50 ft bgs. No Recovery.
5				ST-2						NR	
	-40	Loose, gray, clayey fine SAND (SC).		1-3-3						11"	MC= 26.6%; Gravel = 0.4%; Sand = 85.5%; Fines = 14.1%.
0											
	-45	Medium dense, gray, clayey, fine to medium SAND (SC) with some shells.		2-5-6						15"	
-5											
	-50	Medium dense, gray, clayey, fine SAND (SC) with some shells, some silt, and clean sand lenses.		8-4-9						13"	MC= 20.5%; Gravel = 5.5%; Sand = 80.6%; Fines = 13.9%.
-10											
	-55	Medium dense, gray, clayey, fine to medium SAND (SC), slightly silty to clean lenses.		5-11-14						13"	MC = 26.7%; Fines = 14.7%.
-15											
	-60	Very dense, gray, clayey, fine to medium SAND (SC). Boring terminated at 61.00 ft bgs.		24-50/5"						7"	N-value = 50+ blows/ft.
-20											
	-65										
	-70										
	-75										

All depths referenced to ground surface.

Total Depth: 61.00 ft bgs

BORING LOG

BOREHOLE ID: SPT-115

GENERAL INFORMATION

PROJECT NAME: Winyah Generating Station
PROJECT NO: GSC5242
SITE LOCATION: Georgetown, South Carolina
BORING DATE: 9/29/2013
GEOSYNTec REPRESENTATIVE: J. McNash
DRILLING CONTRACTOR: Soil Consultants, Inc.
DRILLER NAME: M. Grimball

TECHNICAL INFORMATION

DRILLING METHOD: Mud Rotary
RIG TYPE: CME 550 X
BOREHOLE DIA: 4"
SAMPLING METHOD: SPT w/ split spoon
NORTHING: 545998.2801
EASTING: 2504990.8299
GROUND ELEVATION: 40.90 ft NGVD29

Elev. (ft NGVD 29)	Depth (ft)	Lithologic Description	Pattern	SPT Blows	N-Value					Recovery	Comments
					0	10	20	30	40		
40	0										
35	-5	Medium dense, light brown, sandy clay to clayey SAND (SC).		4-5-6						14"	
30	-10	Dense, gray, fine SAND (SP) with silt.		11-23-24						15"	MC = 7.6%; Fines = 8.2%.
25	-15	Medium dense, black to light brown layered, fine SAND (SP), slightly silty.		7-10-18						15"	Water level measured as 15.00 ft bgs on 9/27/2013.
20	-20	Medium dense, gray to black, fine SAND (SP), slightly silty.		8-17-12						12"	Borehole collapsed prior to abandonment at 18.00 ft bgs. Tremie grouted from 18.00 ft bgs.
15	-25	Dense, gray, fine SAND (SP), slightly silty.		8-22-20						13"	
				ST-1						NR	Shelby Tube advanced 12" from 26.50 to 27.50 ft bgs. No Recovery.
10	-30	Medium dense, gray, fine SAND (SP), slightly silty.		8-11-11						10"	

All depths referenced to ground surface.

Total Depth: 72.00 ft bgs

BORING LOG

Borehole ID: SPT-115

Project No: GSC5242

Elev. (ft NGVD29)	Depth (ft)	Lithologic Description	Pattern	SPT Blows	N-Value					Recovery	Comments
					0	10	20	30	40		
5	-35	Loose, brown, fine SAND (SP) with silt.		2-3-3						10"	MC = 27.6%; Gravel = 0.0%; Sand = 89.8%; Fines = 10.2%. Shelby Tube advanced 24" from 36.50 to 38.50 ft bgs. No Recovery.
0	-40	Loose, dark gray to black, fine SAND (SP), slightly silty.		2-4-6						8"	
-5	-45	Loose, gray (blue tint), fine, clayey, fine SAND (SC) with some shells.		1-1-3						18"	MC = 26.1%; Gravel = 11.5%; Sand = 71.5%; Fines = 17.0%. LL = 61%; PL = 24%; PI=37%.
-10	-50	Medium dense, gray, clayey, fine SAND (SC) with some shells.		7-6-23						18"	
-15	-55			50/1"						NR	Hard drilling between 54.50 and 55.90 ft bgs.
-20	-60	Very dense, gray, clayey, fine to medium SAND (SC) with fine gravel and shells; slightly silty.		15-20-50/3"						15"	N-value = 70 blows/ft. MC = 16.0%; Gravel = 23.8%; Sand = 58.3%; Fines = 17.9%. Hard drilling between 63.50 and 64.50 ft bgs.
-25	-65	Dense, gray, fine SAND (SC) with some fine gravel, slightly clayey.		13-23-12						8"	MC = 15.0%; Fines = 18.3%. Intermittent hard layers.
-30	-70	Stiff, dark gray CLAY (CH), dry, high plasticity, slightly sandy (Black Mingo Formation). Boring terminated at 72.00 ft bgs.		5-6-7 ST-2						18" NR	Shelby Tube is sheared from rods during extraction. No Recovery.

All depths referenced to ground surface.

Total Depth: 72.00 ft bgs

BOREHOLE ID: SPT-121

GENERAL INFORMATION

PROJECT NAME: Winyah Generating Station
PROJECT NO: GSC5242
SITE LOCATION: Georgetown, South Carolina
BORING DATE: 9/30/2013
GEOSYNTec REPRESENTATIVE: J. McNash
DRILLING CONTRACTOR: Soil Consultants, Inc.
DRILLER NAME: M. Grimball

TECHNICAL INFORMATION

DRILLING METHOD: Mud Rotary
RIG TYPE: CME 550 X
BOREHOLE DIA: 4"
SAMPLING METHOD: SPT w/ split spoon
NORTHING: 546076.8677
EASTING: 2503720.3193
GROUND ELEVATION: 40.82 ft NGVD29

Elev. (ft NGVD 29)	Depth (ft)	Lithologic Description	Pattern	SPT Blows	N-Value						Recovery	Comments
					0	10	20	30	40	50		
40	0											
35	-5	Dense, light brown with brown layering, clean, fine SAND (SP).		9-16-24							12"	
30	-10	Very dense, light brown with brown layering, fine SAND (SP) with silt.		15-27-33							12"	N-value = 60 blows/ft; MC = 14.8%; Fines = 10.7%. Water level measured as 11.50 ft bgs on 10/1/2013.
25	-15	Dense, light brown with some black, fine SAND (SP), slightly silty.		15-21-27							12"	
20	-20	Very dense, dark brown, fine SAND (SP), slightly silty.		10-27-38							13"	N-value = 65 blows/ft. Borehole collapsed prior to abandonment at 20.00 ft bgs. Tremie grouted from 20.00 ft bgs.
15	-25	Dense, dark brown, fine SAND (SP), slightly silty.		16-23-17							11"	
10	-30	Loose, brown, clayey, fine SAND (SP) with silt.		1-2-3							10"	MC = 27.8%; Gravel = 0.0%; Sand = 92.6%; Fines = 7.4%.

All depths referenced to ground surface.

Total Depth: 60.00 ft bgs

BORING LOG

Borehole ID: SPT-121

Project No: GSC5242

Elev. (ft NGVD29)	Depth (ft)	Lithologic Description	Pattern	SPT Blows	N-Value					Recovery	Comments
					0	10	20	30	40		
5	-35	Loose, gray to dark gray, fine SAND (SC).		1-3-4						12"	MC = 36.0%; Fines = 14.3%.
0	-40	Loose, gray, clayey, fine SAND (SC) with some shells.		8-3-2						7"	MC = 17.3%; Gravel = 11.0%; Sand = 73.7%; Fines = 15.3%.
-5	-45	Loose, gray, clayey fine GRAVEL and shells (GC), some fine sand.		3-4-4						18"	MC = 31.1%; Fines = 14.5%.
-10	-50	Medium dense, gray, clayey, fine GRAVEL and shells (GC), some fine sand.		13-15-8						15"	
-15	-55	Dense, clayey, fine SAND (SC), some fine gravel.		11-10-26						14"	
-20	-60	Boring terminated at 60.00 ft bgs.		50/0"						NR	Hard drilling between 52.50 and 54.75 ft bgs.
-25	-65										
-30	-70										
-35	-75										

All depths referenced to ground surface.

Total Depth: 60.00 ft bgs

BORING LOG

BOREHOLE ID: SPT-122 / SPT-122A

GENERAL INFORMATION

PROJECT NAME: Winyah Generating Station
PROJECT NO: GSC5242
SITE LOCATION: Georgetown, South Carolina
BORING DATE: 9/30/2013
GEOSYNTec REPRESENTATIVE: J. McNash
DRILLING CONTRACTOR: Soil Consultants, Inc.
DRILLER NAME: M. Grimball

TECHNICAL INFORMATION

DRILLING METHOD: Mud Rotary
RIG TYPE: CME 550 X
BOREHOLE DIA: 4"
SAMPLING METHOD: SPT w/ split spoon
NORTHING: 546542.7145
EASTING: 2504656.9458
GROUND ELEVATION: 41.11 ft NGVD29

Elev. (ft NGVD 29)	Depth (ft)	Lithologic Description	Pattern	SPT Blows	N-Value					Recovery	Comments
					0	10	20	30	40		
	0										
40											
	-5	Very soft, black SILT (ML) (Fly Ash), slightly sandy.		1-1-1						8"	
35											
	-10	Very soft, black SILT (ML) (Fly Ash), slightly sandy.		WOR- WOR- WOR						15"	
30				ST-1						24"	Water level measured as 11.50 ft bgs on 10/9/2013. Shelby Tube advanced 24" from 12.00 to 14.00 ft bgs. Gravel = 0.0%; Sand = 26.3%; Silt = 54.6%; Clay = 19.1%. LL = NP; PL = NP; PI = NP; S.G. = 2.243; pH = 5.8. Carbonate = 0%.
	-15	Very soft, black SILT (ML) (Fly Ash), slightly sandy.		WOR- WOR- WOR						3"	
25				ST-2/ ST-3						NR / 24"	Shelby Tube advanced 24" from 18.00 to 20.00 ft bgs. No Recovery. SPT 122A was offset 5.00 ft south of SPT-122. Shelby Tube advanced by means of a Piston Sampler 24" from 18.00 to 20.00 ft bgs.
	-20	Very soft, black SILT (ML) (Fly Ash), slightly sandy.		WOR- WOR- WOR						11"	Gravel = 0.0%; Sand = 1.0%; Silt = 79.4%; Clay = 19.6%. LL = NP; PL = NP; PI = NP.
20											
	-25	Brown, fine to medium SAND (SP). Boring terminated at 25.00 ft bgs.									Borehole did not collapse prior to abandonment. Tremie grouted from 25.00 ft bgs.
15											
	-30										
10											

All depths referenced to ground surface.

Total Depth: 25.00 ft bgs

BOREHOLE ID: SPT-307

GENERAL INFORMATION

PROJECT NAME: Winyah Generating Station
PROJECT NO: GSC5242
SITE LOCATION: Georgetown, South Carolina
BORING DATE: 3/31/2016
GEOSYNTec REPRESENTATIVE: A. Sivashanthan
DRILLING CONTRACTOR: Carolina Drilling, Co.
DRILLER NAME: J. Anderson

TECHNICAL INFORMATION

DRILLING METHOD: Mud Rotary
RIG TYPE: CME 45C
BOREHOLE DIA: 4"
SAMPLING METHOD: SPT w/ split spoon
NORTHING: 546425.2087
EASTING: 2504125.939
GROUND ELEVATION: 38.07 ft NGVD29

Elev. (ft NGVD 29)	Depth (ft)	Lithologic Description	Pattern	SPT Blows	N-Value					Recovery	Comments	
					0	10	20	30	40			50
0	0	Very soft, black, sandy SILT(ML) (Fly Ash), dry		1-1-1							14"	Water level was measured 2.19 ft bgs at 8.49 am on 03/31/2016
	35	No recovery		WOH/18"							0"	
	-5											
	30	Very soft, black, sandy SILT(ML) (Fly Ash), dry		1-1-1							11"	
	-10											
	25	Very soft, black, sandy SILT(ML) (Fly Ash), dry		WOH/18"							18"	
	-15											
	20	No recovery		6-12-13							0"	
	-20											
	15	Very dense, reddish brown, SAND (SP), moist		38-50/3"							12"	N-value = 50 blows/3"
	-25											
	10	Dense, reddish brown, SAND (SP), moist		10-17-14-10							14"	
	-30	Medium dense, reddish brown, SAND (SP), moist		4-5-7-8							14"	
	5	Loose, reddish brown, SAND (SP), moist		6-4-5-5							10"	MC = 29%; Fines = 2.0%
	5	Very loose, reddish brown, SAND (SP), moist		3-2-2-3							16"	

All depths referenced to ground surface.

Total Depth: 50.0 ft bgs

Elev. (ft NGVD29)	Depth (ft)	Lithologic Description	Pattern	SPT Blows	N-Value					Recovery	Comments
					0	10	20	30	40		
	-35	Loose, gray, SAND (SP), moist		3-3-4-5						13"	MC = 23%; LL = NP; PL = NP; PI = NP; Fines = 3.7%
		Medium dense, gray, SAND (SP), moist		7-7-5-5						14"	
	0	Very loose, gray, clayey SAND (SC), moist		2-1-2-2						18"	MC = 26%; Fines = 6.4%
	-40	Very loose, gray, clayey SAND (SC), moist, with shell fragments		2-1-2-3						17"	
	-5	Loose, gray, clayey SAND (SC), moist, with shell fragments		2-3-4-4						17"	
	-45	Medium dense, gray, clayey SAND(SC), moist, with shell fragments		8-8-11-14						12"	
	-10	Very dense, gray, clayey SAND(SC), moist, with crushed rock fragments		50/3"						4"	N-value = 50 blows/3" (Chicora)
	-50	Boring terminated at 50 feet.									
	-15										
	-55										
	-20										
	-60										
	-25										
	-65										
	-30										
	-70										
	-35										
	75										

BOREHOLE ID: SPT-308

GENERAL INFORMATION

PROJECT NAME: Winyah Generating Station
PROJECT NO: GSC5242
SITE LOCATION: Georgetown, South Carolina
BORING DATE: 3/31/2016
GEOSYNTec REPRESENTATIVE: A. Sivashanthan
DRILLING CONTRACTOR: Carolina Drilling, Co.
DRILLER NAME: J. Anderson






TECHNICAL INFORMATION

DRILLING METHOD: Mud Rotary
RIG TYPE: CME 45C
BOREHOLE DIA: 4"
SAMPLING METHOD: SPT w/ split spoon
NORTHING: 545576.0172
EASTING: 2503682.58
GROUND ELEVATION: 35.29 ft NGVD29

Elev. (ft NGVD 29)	Depth (ft)	Lithologic Description	Pattern	SPT Blows	N-Value					Recovery	Comments	
					0	10	20	30	40			50
35	0	No recovery		WOH/18"							0"	Water level was measured 1.5 ft bgs at 8.34 am on 03/31/2016
		Very soft, black, sandy SILT(ML) (Fly Ash), dry		WOH/18"							11"	
	-5											
	-10	No recovery		WOR/18"							0"	
	-15	Very stiff, reddish brown, sandy SILT(ML) (Fly Ash), moist		5-8-10							14"	
	-20	Medium dense, reddish brown, SAND (SP), moist		8-7-8							9"	
	-20	Medium dense, reddish brown, SAND (SP), moist		5-5-6-5							15"	
	-22	Very loose, reddish brown, SAND (SP), moist		2-2-2-2							11"	
	-25	Very loose, reddish brown to brown, SAND (SP), moist		1-2-2-4							16"	
	-25	Loose, brown to light gray, SAND (SP), moist		3-3-4-5							12"	
	-28	Very loose to very soft, gray, clayey SAND (SC) to fat CLAY (CH), moist, with shell fragments		1/12"-1/12"							16"	
	-30	Very soft, gray, fat CLAY (CH) with sand, moist		WOH-1-1-1							18"	MC = 76%; LL = 63; PL = 21; PI = 42; Fines = 61.9%
	-30	Shelby tube (Not extruded)		ST-1							24"	MC = 76%; LL = 98; PL = 31; PI = 67; Gravel = 0.0%; Sand = 12.0%; Silt = 22.7%; Clay = 65.3%;

All depths referenced to ground surface.

Total Depth: 50.0 ft bgs

Elev. (ft NGVD29)	Depth (ft)	Lithologic Description	Pattern	SPT Blows	N-Value					Recovery	Comments	
					0	10	20	30	40			50
0	-35	Very soft to very loose to , gray, fat CLAY (CH) to clayey SAND (SC), moist		2-2-2-2	0	0	0	0	0	0	17"	MC = 30%; LL = 28; PL = 16; PI = 12; Fines = 11.8%
		Very loose, gray, clayey SAND (SC), moist, with shell fragments		2-2-2/12"	0	0	0	0	0	0	18"	
-5	-40	Loose, gray, clayey SAND (SC), moist, with rock fragments		5-4-6-8	0	0	0	0	0	0	18"	
-10	-45	Medium dense, gray, clayey SAND (SC), moist, with rock fragments		8-11-10	0	0	0	0	0	0	12"	
-15	-50	Very dense, gray, clayey SAND (SC), moist, with rock fragments, Boring terminated at 50 feet.		50/0"	0	0	0	0	0	0	2"	
-20	-55											
-25	-60											
-30	-65											
-35	-70											
	-75											

All depths referenced to ground surface.

Total Depth: 50.0 ft bgs

BOREHOLE ID: SPT-309

GENERAL INFORMATION

PROJECT NAME: Winyah Generating Station
PROJECT NO: GSC5242
SITE LOCATION: Georgetown, South Carolina
BORING DATE: 3/2/2016
GEOSYNTec REPRESENTATIVE: A. Sivashanthan
DRILLING CONTRACTOR: Mid Atlantic Drilling, Inc.
DRILLER NAME: B. Fowler

TECHNICAL INFORMATION

DRILLING METHOD: Mud Rotary
RIG TYPE: CME 45C
BOREHOLE DIA: 4"
SAMPLING METHOD: SPT w/ split spoon
NORTHING: 544483.2439
EASTING: 2504249.313
GROUND ELEVATION: 39.88461

Elev. (ft NGVD 29)	Depth (ft)	Lithologic Description	Pattern	SPT Blows	N-Value	Recovery	Comments
	0	Medium dense, orange to l. brown SAND (SP), dry		7-6-6-9		14"	
				7-13-10-13		20"	
35	-5	Medium dense, reddish brown with gray pockets SAND (SP), dry		4-6-10-11		20"	
				10-8-10-11		21"	
30	-10	Medium dense, gray to black, clayey fine SAND (SC), moist		5-6-5-5		10"	MC = 17.6%; Gravel = 0.0%; Sand = 78.5%; Fines = 21.5%.
		Medium dense, dark brown to gray-brown, clayey fine SAND (SC), moist		2-3-12-14		14"	
		Dense, light to dark brown to black, fine SAND (SP), moist		11-15-17-31		17"	
25	-15	Dense, black, fine SAND (SP), moist		15-23-28-32		17"	Water level measured as 14.05 ft bgs on 3/3/2016.
		Dense, black, fine silty SAND (SM), moist		13-18-21-20		14"	MC = 22.0%; Fines = 9.6%.
		Medium dense, black, fine silty SAND (SM), moist		3-4-8-10		14"	
20	-20						
15	-25	Medium dense, tan to yellow, fine sand; moist		3-7-12		10.5"	
10	-30	Medium dense, black, fine SAND (SP) with silt, moist		13-12-16		16"	MC = 31.6%; Fines = 7.3%.

All depths referenced to ground surface.

Total Depth: 60.00 ft bgs

BORING LOG

Borehole ID: SPT-309

Project No: GSC5242

Elev. (ft NGVD29)	Depth (ft)	Lithologic Description	Pattern	SPT Blows	N-Value					Recovery	Comments	
					0	10	20	30	40			50
5	-35	Loose, black, fine SAND (SP) with silt, moist	[Pattern]	2-2-3	0	10	20	30	40	50	12"	MC = 30.7%; Gravel = 0.1%; Sand = 88.0%; Fines = 11.9%
0	-40	Medium dense, gray SAND (SP), moist	[Pattern]	4-6-9	0	10	20	30	40	50	12"	
-5	-45	Very loose, gray, clayey coarse SAND (SC), moist, some rock fragments	[Pattern]	3-2-2	0	10	20	30	40	50	20"	MC = 27.5%; Fines = 11.1%.
-10	-50	Medium dense, gray, coarse SAND (SP), moist, some rock fragments	[Pattern]	13-10-20	0	10	20	30	40	50	17"	
-15	-55	Loose, gray clayey SAND (SC), moist	[Pattern]	5-3-4	0	10	20	30	40	50	18"	MC = 29.8%; Fines = 29.5%.
-20	-60	Very dense, clayey gray SAND (SC), moist, some rock fragments Boring terminated at 60.0 ft bgs.	[Pattern]	50/5"	0	10	20	30	40	50	9"	
-25	-65											
-30	-70											
-35	-75											

All depths referenced to ground surface.

Total Depth: 60.00 ft bgs

BOREHOLE ID: SPT-310

GENERAL INFORMATION

PROJECT NAME: Winyah Generating Station
PROJECT NO: GSC5242
SITE LOCATION: Georgetown, South Carolina
BORING DATE: 3/2/2016
GEOSYNTec REPRESENTATIVE: A. Sivashanthan
DRILLING CONTRACTOR: Mid Atlantic Drilling, Inc.
DRILLER NAME: B. Fowler

TECHNICAL INFORMATION

DRILLING METHOD: Mud Rotary
RIG TYPE: CME 45C
BOREHOLE DIA: 4"
SAMPLING METHOD: SPT w/ split spoon
NORTHING: 545156.0104
EASTING: 2503426.601
GROUND ELEVATION: 40.0123

Elev. (ft NGVD 29)	Depth (ft)	Lithologic Description	Pattern	SPT Blows	N-Value					Recovery	Comments	
					0	10	20	30	40			50
40	0	Medium dense, black to orange SAND (SP), dry		5-5-10-11							24"	
		Medium dense, orange to gray SAND (SP), dry		10-11-13-16							20"	
35	-5	Medium dense, gray to red-gray, clayey SAND (SC), dry		9-5-6-10							15"	
		Medium dense, orange, clayey SAND (SC), dry		4-7-7-11							24"	
		Medium dense, orange clayey SAND (SC), moist		8-9-11-12							20"	
30	-10	Medium dense, orange to yellow and gray, clayey SAND (SC), moist		4-4-5-6							16"	Water level measured as 9.1ft bgs on 3/3/2016. MC = 23.5%; Fines = 22.8%.
		Medium dense, black fine SAND (SP); moist		4-8-11-16							14"	
25	-15	Medium dense, black fine SAND (SP) with silt; moist		7-7-11-11							14"	
		Medium dense, black fine SAND (SP) with silt; moist		7-14-22-23							14"	MC = 21.7%; Fines = 10.5%.
		Medium dense, black fine SAND (SP) with silt; moist		2-6-13-14							13"	
20	-20											
		Medium dense, black fine SAND (SP) with silt; moist		11-14-14							15"	
15	-25											
		Very loose, black fine SAND (SP) with silt; moist		1-2-1							18"	MC = 33.7%; Gravel = 0.0%; Sand = 94.7%; Fines = 5.3%.
10	-30											





All depths referenced to ground surface.

Total Depth: 50.00 ft bgs

BORING LOG

Borehole ID: SPT-310

Project No: GSC5242

Elev. (ft NGVD29)	Depth (ft)	Lithologic Description	Pattern	SPT Blows	N-Value					Recovery	Comments	
					0	10	20	30	40			50
5	-35	Very loose, light gray, clayey fine SAND (SC); moist		3-1-1	0	10	20	30	40	50	10"	MC = 34.4%; Fines = 12.7%.
0	-40	Medium dense, light gray to gray, fine SAND (SP) with silt, moist		6-5-8	0	10	20	30	40	50	9"	MC = 27.2%; Fines = 6.3%.
-5	-45	Loose, gray, coarse SAND (SP), some rock fragments		4-4-4	0	10	20	30	40	50	20"	
-10	-50	No Recovery; Boring terminated at 50.0 ft bgs.		50/1"	0	10	20	30	40	50	NR	
-15	-55											
-20	-60											
-25	-65											
-30	-70											
-35	-75											

All depths referenced to ground surface.

Total Depth: 50.00 ft bgs

ATTACHMENT 2-B

PCRA Boring Logs (PCRA, 1993)



WINYAH GENERATING STATION—ASH POND B LOG OF BORING NO. B-1

ELEV. (FEET M.S.L.)	DEPTH (FEET)	SAMPLE NO. AND TYPE	PROFILE	LOCATION	USCS SYMBOL	PENETRATION RESISTANCE (BLOWS PER FOOT)			REMARKS
				STATION: <u>~46+00</u> DISTANCE: <u>19'</u> SURFACE EL: <u>33.6'</u>		DESCRIPTION	10	30	
	0	1 20	16	MEDIUM DENSE, REDDISH BROWN TO DARK GRAY, FINE, CLAYEY SAND, MOIST	sc				0'-15' FILL
30	5	2 40	19		5.5'	sc			
	10	3 36	20	DENSE, LIGHT TO DARK GRAY, FINE SAND, TRACE SILT, WET	sp				15.0'-30.0' FOUNDATION SOILS
20	15	4 37	18		15.0'	sp			
	20	5 12	22	MEDIUM DENSE, BROWNISH GRAY TO DARK BLACKISH BROWN, FINE SAND, TRACE TO SOME SILT, WET	sp				SLIGHT ORGANIC ODOR
10	25	6 12	20		28.0'	sp			
	30	7 9	24	LOOSE, DARK BROWNISH GRAY, FINE SAND, TRACE SILT, WET	sp				SLIGHT ORGANIC ODOR
3.6	30				30.0'				
				BOTTOM OF BORING 30.0'					
	35								

PROJECT NO.: 93-1386
 DATE STARTED: 10-21-93
 DATE COMPLETED: 10-21-93
 FIELD GEOLOGIST: JDH
 CHECKED BY: JTO

0820

GWL: DEPTH ~11' DATE/TIME 10-21-93
 GWL: DEPTH _____ DATE/TIME _____
 DRILLING METHOD: 4 1/4" I.D. H.S.A.,
SPT SAMPLING (140 lb HAMMER, 30"
DROP, 2 WRAPS ON CATHEAD)

NOTES:
 CONTRACTOR: **S&ME**
 RIG: CME 55
 DRILLER: Chris Simril
 Distance under location is
 from ash pond water edge.
 All elevations are from NGVD.



WINYAH GENERATING STATION—ASH POND B LOG OF BORING NO. B-2

ELEV. (FEET M.S.L.)	DEPTH (FEET)	SAMPLE NO. AND TYPE	PROFILE	LOCATION	USCS SYMBOL	PENETRATION RESISTANCE (BLOWS PER FOOT)			REMARKS
				STATION: <u>~37+50</u> DISTANCE: <u>20.5'</u> SURFACE EL: <u>33.7'</u>		10	30	50	
				DESCRIPTION					
	0	1 18 12	//	MEDIUM DENSE, REDDISH BROWN AND GRAY, FINE TO MEDIUM CLAYEY SAND, SOME CLAY LENSES, MOIST	sc				0'-15' FILL
	30		}	2.0'					
	5	2 24 32	}	DENSE, GRAY, FINE TO MEDIUM SAND, TRACE SILT, MOIST TO WET	sp				15.0'-27.0' FOUNDATION SOILS
	10	3 20 31	}		sp				
	15	4 17 10	//	LOOSE, TANNISH GRAY, FINE TO MEDIUM, CLAYEY TO VERY CLAYEY SAND AND STIFF CLAY, WET	sc cl				
	20	5 24 24	//	MEDIUM DENSE, TANNISH TO PALE GRAY, FINE TO MEDIUM SAND, TRACE CLAY, WET	sp				
	25	6 24 7	}	LOOSE, GRAY TO DARK GRAY, FINE TO MEDIUM SAND, WET	sp				
	27.0			BOTTOM OF BORING 27.0'					
	30								
	35								

PROJECT NO.: 93-1356
 DATE STARTED: 10-21-93
 DATE COMPLETED: 10-21-93
 FIELD GEOLOGIST: JDH
 CHECKED BY: JTO

GWL: DEPTH ~13' DATE/TIME 10-21-93
 GWL: DEPTH _____ DATE/TIME _____
 DRILLING METHOD: 4 1/4" I.D. H.S.A.,
SPT SAMPLING (140 lb HAMMER, 30"
DROP, 2 WRAPS ON CATHEAD)

NOTES:
 CONTRACTOR: S&ME
 RIG: CME 55
 DRILLER: Chris Simril
 Distance under location is from ash pond water edge.
 All elevations are from NGVD.



WINYAH GENERATING STATION—ASH POND B LOG OF BORING NO. B-3

ELEV. (FEET M.S.L.)	DEPTH (FEET)	SAMPLE NO. AND TYPE	PROFILE	LOCATION		USCS SYMBOL	PENETRATION RESISTANCE (BLOWS PER FOOT)	REMARKS
				STATION: <u>~29+50</u>	DISTANCE: <u>19'</u>			
				SURFACE EL: <u>33.8'</u>				
				DESCRIPTION				
	0	1 15 16	/ /	MEDIUM STIFF, REDDISH BROWN, SANDY CLAY, MOIST 0.5'		cl sc		0'-17' FILL CUTTINGS TURNING BLACK
30				MEDIUM DENSE, GRAYISH BROWN, MEDIUM SAND, MOIST 3.0'				
	5	2 51 20	/ /	VERY DENSE, DARK GRAY TO BLACK, FINE TO MEDIUM SAND, TRACE CLAY LENSES, MOIST 10.0'		sp		17.0'-30.0' FOUNDATION SOILS
10				MEDIUM DENSE, TAN, LIGHT TO DARK GRAY AND BLACK, FINE SAND, TRACE SILT, MOIST TO WET		sp		
20		4 29 17	}	MEDIUM DENSE, TAN, LIGHT TO DARK GRAY AND BLACK, FINE SAND, TRACE SILT, MOIST TO WET 17.0'		sp		
15				LOOSE TO MEDIUM DENSE, DARK GRAY TO DARK GRAYISH BROWN AND BLACK, FINE, SILTY SAND, WET		sm		
	20	5 24 20	}	LOOSE TO MEDIUM DENSE, DARK GRAY TO DARK GRAYISH BROWN AND BLACK, FINE, SILTY SAND, WET		sm		
10				LOOSE TO MEDIUM DENSE, DARK GRAY TO DARK GRAYISH BROWN AND BLACK, FINE, SILTY SAND, WET		sm		
	25	6 10 24	}	LOOSE TO MEDIUM DENSE, DARK GRAY TO DARK GRAYISH BROWN AND BLACK, FINE, SILTY SAND, WET		sm		
	30	7 7 24		LOOSE TO MEDIUM DENSE, DARK GRAY TO DARK GRAYISH BROWN AND BLACK, FINE, SILTY SAND, WET		sm		
3.8				BOTTOM OF BORING 30.0'				

PROJECT NO.: 93-1356
 DATE STARTED: 10-21-93
 DATE COMPLETED: 10-21-93
 FIELD GEOLOGIST: JDH
 CHECKED BY: JTO

GWL: DEPTH ~13' DATE/TIME 1300 10-21-93
 GWL: DEPTH _____ DATE/TIME _____
 DRILLING METHOD: 4 1/4" I.D. H.S.A., SPT SAMPLING (140 lb HAMMER, 30" DROP, 2 WRAPS ON CATHEAD)

NOTES:
 CONTRACTOR: S&ME
 RIG: CME 55
 DRILLER: Chris Simril
 Distance under location is from ash pond water edge.
 All elevations are from NGVD.



WINYAH GENERATING STATION—ASH POND B LOG OF BORING NO. B-4

ELEV. (FEET M.S.L.)	DEPTH (FEET)	SAMPLE NO. AND TYPE	PROFILE	LOCATION	USCS SYMBOL	PENETRATION RESISTANCE (BLOWS PER FOOT)			REMARKS
				STATION: <u>~20+00</u> DISTANCE: <u>17.5'</u> SURFACE EL: <u>33.8'</u>		10	30	50	
				DESCRIPTION					
	0	1 18 13	}	MEDIUM DENSE TO DENSE, DARK GRAY, TAN, AND BROWNISH GRAY, FINE SAND, TRACE SILT, MOIST	sp	●			0'-12' FILL
30	5	2 18 24	//		sp	●			TRACE CLAY LENSES WOOD FRAGMENTS
	10	3 20 45	}		sp	●		12.0'	WOOD FRAGMENTS
20	15	4 16 9	//	LOOSE TO MEDIUM DENSE, DARK GRAY TO BLACK, FINE TO MEDIUM, CLAYEY SAND, WET	sc	●			12.0'-30.0' FOUNDATION SOILS
	20	5 0 14	//		-	●			NO SAMPLE WOOD FRAGMENT BLOCKING SPOON
10	25	6 16 5	}	LOOSE TO MEDIUM DENSE, DARK GRAY TO BLACK, FINE SILTY SAND, WET	sm	●			2" WOOD FRAGMENTS
	30	7 16 11	}		sm	●		30.0'	
3.8	30			BOTTOM OF BORING 30.0'					
	35								

PROJECT NO.: <u>93-1356</u> DATE STARTED: <u>10-21-93</u> DATE COMPLETED: <u>10-21-93</u> FIELD GEOLOGIST: <u>JDH</u> CHECKED BY: <u>JTO</u>	GWL: DEPTH <u>~12'</u> DATE/TIME <u>10-21-93</u> GWL: DEPTH _____ DATE/TIME _____ DRILLING METHOD: <u>4 1/4" I.D. H.S.A.,</u> <u>SPT SAMPLING (140 lb HAMMER, 30"</u> <u>DROP, 2 WRAPS ON CATHEAD)</u>	NOTES: CONTRACTOR: <u>S&ME</u> RIG: <u>CME 55</u> DRILLER: <u>Chris Simril</u> Distance under location is from ash pond water edge. All elevations are from NGVD.
--	--	--



WINYAH GENERATING STATION—ASH POND B LOG OF BORING NO. B-5

ELEV. (FEET M.S.L.)	DEPTH (FEET)	SAMPLE NO. AND TYPE	PROFILE	LOCATION		USCS SYMBOL	PENETRATION RESISTANCE (BLOWS PER FOOT)			REMARKS
				STATION: ~10+50	DISTANCE: 16'		SURFACE EL: 34.3'	10	30	
				DESCRIPTION						
	0	1 17 19	//	MEDIUM DENSE, BROWN TO GRAY BROWN, FINE SAND, TRACE CLAY LENSES, MOIST		sp				0'-12' FILL 1/2" CLAY LENS
	30									
	5	2 24 37	}	DENSE, BROWN TO BLACK, FINE SAND, TRACE SILT, MOIST TO WET		sp				WOOD FRAGMENTS
	10									
	15	3 15 47	}	DENSE, BROWN TO BLACK, FINE SAND, TRACE SILT, MOIST TO WET		sp				WOOD FRAGMENTS 12.0'-27.0' FOUNDATION SOILS
	20									
	15	4 24 2	}	LOOSE, DARK BROWN TO BLACK, SILTY SAND, WET		sm				TRACE ROOTS IRON STAINING
	20									
	20	5 24 29	}	MEDIUM DENSE TO DENSE, BROWN, GRAYISH BROWN, AND BLACK, FINE SAND, TRACE SILT, WET		sp				WOOD FRAGMENTS SAND HEAVING INTO AUGER
	25									
	25	6 24 38	}	MEDIUM DENSE TO DENSE, BROWN, GRAYISH BROWN, AND BLACK, FINE SAND, TRACE SILT, WET		sp				SAND HEAVING INTO AUGER
	27.3									
				BOTTOM OF BORING 27.0'						
	30									
	35									

PROJECT NO.: 93-1356
 DATE STARTED: 10-22-93
 DATE COMPLETED: 10-22-93
 FIELD GEOLOGIST: JDH/ADM
 CHECKED BY: JTO

GWL: DEPTH ~12' DATE/TIME 10-22-93
 GWL: DEPTH _____ DATE/TIME _____
 DRILLING METHOD: 4 1/4" I.D. H.S.A.,
SPT SAMPLING (140 lb HAMMER, 30"
DROP, 2 WRAPS ON CATHEAD)

NOTES:
 CONTRACTOR: S&ME
 RIG: CME 55
 DRILLER: Chris Simril
 Distance under location is
 from ash pond water edge.
 All elevations are from NGVD.



WINYAH GENERATING STATION—ASH POND B LOG OF BORING NO. B-6

ELEV. (FEET M.S.L.)	DEPTH (FEET)	SAMPLE NO. AND TYPE	PROFILE	LOCATION	USCS SYMBOL	PENETRATION RESISTANCE (BLOWS PER FOOT)	REMARKS
				STATION: <u>~4+75</u> DISTANCE: <u>17'</u> SURFACE EL: <u>33.8'</u>			
	0	1 20 24	//		sp		0'-8' FILL TRACE CLAY LENSES
30	5	2 19 31		MEDIUM DENSE TO DENSE, BROWNISH GRAY, DARK GRAY, AND BLACK, FINE SAND, TRACE CLAY, MOIST TO WET	sp		
				8.0'			8.0'-30.0' FOUNDATION SOILS
	10	3 17 29	//	MEDIUM TO VERY DENSE, DARK GRAY TO BLACK, FINE SAND, TRACE SILT, WET	sp		WOOD FRAGMENTS AND ROOTS
20	15	4 19 62			sp		62 IRON STAINING
	20	5 24 11		LOOSE TO MEDIUM DENSE, DARK GRAYISH BLACK, FINE SAND, TRACE SILT, WET	sp		
10	25	6 24 8			sp		SAND HEAVING INTO AUGER
	30	7 24 16			sp		
3.8				30.0'			
	30			BOTTOM OF BORING 30.0'			
	35						


PROJECT NO.: <u>93-1356</u> DATE STARTED: <u>10-22-93</u> DATE COMPLETED: <u>10-22-93</u> FIELD GEOLOGIST: <u>JDH/ADM</u> CHECKED BY: <u>JTO</u>	GWL: DEPTH <u>~10'</u> DATE/TIME <u>10-22-93</u> GWL: DEPTH _____ DATE/TIME _____ DRILLING METHOD: <u>4 1/4" I.D. H.S.A.,</u> <u>SPT SAMPLING (140 lb HAMMER, 30"</u> <u>DROP, 2 WRAPS ON CATHEAD)</u>	NOTES: CONTRACTOR: <u>S&ME</u> RIG: <u>CME 55</u> DRILLER: <u>Chris Simril</u> Distance under location is from ash pond water edge. All elevations are from NGVD.
--	--	---

ATTACHMENT 3

CPT Sounding Data

ATTACHMENT 3-A

CPT Sounding Logs
(Provided by Mid-Atlantic Drilling)



Maximum Depth = 48.23 feet


Depth Increment = 0.066 feet

- 1 sensitive fine grained
- 2 organic material
- 3 clay

- 4 silty clay to clay
- 5 clayey silt to silty clay
- 6 sandy silt to clayey silt

- 7 silty sand to sandy silt
- 8 sand to silty sand
- 9 sand


- 10 gravelly sand to sand
- 11 very stiff fine grained (*)
- 12 sand to clayey sand (*)




Maximum Depth = 47.51 feet

Depth Increment = 0.066 feet

- | | | | |
|--------------------------|-----------------------------|----------------------------|--------------------------------|
| 1 sensitive fine grained | 4 silty clay to clay | 7 silty sand to sandy silt | 10 gravelly sand to sand |
| 2 organic material | 5 clayey silt to silty clay | 8 sand to silty sand | 11 very stiff fine grained (*) |
| 3 clay | 6 sandy silt to clayey silt | 9 sand | 12 sand to clayey sand (*) |




*Soil behavior type and SPT based on data from UBC-1983




Maximum Depth = 48.23 feet

Depth Increment = 0.066 feet


- | | | | |
|--------------------------|-----------------------------|----------------------------|--------------------------------|
| 1 sensitive fine grained | 4 silty clay to clay | 7 silty sand to sandy silt | 10 gravelly sand to sand |
| 2 organic material | 5 clayey silt to silty clay | 8 sand to silty sand | 11 very stiff fine grained (*) |
| 3 clay | 6 sandy silt to clayey silt | 9 sand | 12 sand to clayey sand (*) |




*Soil behavior type and SPT based on data from UBC-1983



*Soil behavior type and SPT based on data from UBC-1983



*Soil behavior type and SPT based on data from UBC-1983



*Soil behavior type and SPT based on data from UBC-1983

CPT LOG NO. SCPT-217


PROJECT: Winyah Generation Station

CLIENT: Santee Cooper
Moncks Corner, South Carolina

TEST LOCATION: See Exhibit A-2

SITE: Georgetown, South Carolina

Latitude: 33.3218°
Longitude: -79.3518°



Dead weight of rig used as reaction force.
CPT sensor calibration reports available upon request.

1 Sensitive, fine grained
2 Organic soils - clay
3 Silty - silty clay to clay
4 Silty sand to sandy silt
5 Sand mixtures - silty sand to sandy silt
6 Sands - clean sand to silty sand
7 Gravely sand to dense sand
8 Very stiff sand to clayey sand
9 Very stiff fine grained

See Exhibit A-3 for description of field procedures.
See Appendix C for explanation of symbols and abbreviations.

WATER LEVEL OBSERVATION	CPT Started: 3/22/2016	CPT Completed: 3/22/2016
4 ft estimated water depth (used in normalizations and correlations; see Appendix C)	Rig: Pagani TG73-200	Operator: JB
	Project No.: EN165065	Exhibit: A-4



Probe no. 4526 with net area ratio of 0.83
U2 pore pressure transducer location
Manufactured by Geotech A.B.; calibrated 12/7/2015
Tip and sleeve areas of 10 cm² and 150 cm²
Ring friction reducer with O.D. of 1.875 in

CPT LOG NO. CPT-218


PROJECT: Winyah Generation Station

CLIENT: Santee Cooper
Moncks Corner, South Carolina

TEST LOCATION: See Exhibit A-2

SITE: Georgetown, South Carolina

Latitude: 33.3244°
Longitude: -79.3496°



See Exhibit A-3 for description of field procedures.
See Appendix C for explanation of symbols and abbreviations.

Dead weight of rig used as reaction force.
CPT sensor calibration reports available upon request.

- 1 Sensitive, fine grained
- 2 Organic soils - clay
- 3 Silty - silty clay to clay
- 4 Silty - silty sand to silty silt
- 5 Sand mixtures - silty sand to sandy silt
- 6 Sands - clean sand to silty sand
- 7 Gravely sand to dense sand
- 8 Very stiff sand to clayey sand
- 9 Very stiff fine grained

WATER LEVEL OBSERVATION
5 ft estimated water depth
(used in normalizations and correlations; see Appendix C)

Probe no. 4675 with net area ratio of 0.84
U2 pore pressure transducer location
Manufactured by Geotech A.B.; calibrated 10/22/2015
Tip and sleeve areas of 10 cm² and 150 cm²
Ring friction reducer with O.D. of 1.875 in



CPT Started: 3/23/2016
Rig: Pagani TG73-200
Project No.: EN165065

CPT Completed: 3/23/2016
Operator: BR
Exhibit: A-4

CPT LOG NO. CPT-219


PROJECT: Winyah Generation Station

CLIENT: Santee Cooper
Moncks Corner, South Carolina

TEST LOCATION: See Exhibit A-2

SITE: Georgetown, South Carolina

Latitude: 33.3254°
Longitude: -79.3481°



See Exhibit A-3 for description of field procedures.
See Appendix C for explanation of symbols and abbreviations.

Dead weight of rig used as reaction force.
CPT sensor calibration reports available upon request.

- 1 Sensitive, fine grained
- 2 Organic soils - clay
- 3 Silty - silty clay to clay
- 4 Silty clay to silty sand
- 5 Sand mixtures - silty sand to sandy silt
- 6 Sands - clean sand to silty sand
- 7 Gravely sand to dense sand
- 8 Very stiff sand to clayey sand
- 9 Very stiff fine grained

WATER LEVEL OBSERVATION
5 ft estimated water depth
(used in normalizations and correlations; see Appendix C)

Probe no. 4675 with net area ratio of 0.84
U2 pore pressure transducer location
Manufactured by Geotech A.B.; calibrated 10/22/2015
Tip and sleeve areas of 10 cm² and 150 cm²
Ring friction reducer with O.D. of 1.875 in



CPT Started: 3/23/2016
Rig: Pagani TG73-200
Project No.: EN165065

CPT Completed: 3/23/2016
Operator: BR
Exhibit: A-4

CPT LOG NO. SCPT-220


PROJECT: Winyah Generation Station

CLIENT: Santee Cooper
Moncks Corner, South Carolina

TEST LOCATION: See Exhibit A-2

SITE: Georgetown, South Carolina

Latitude: 33.3257°
Longitude: -79.3467°



Dead weight of rig used as reaction force.
CPT sensor calibration reports available upon request.

- 1 Sensitive, fine grained
- 2 Organic soils - clay
- 3 Silty - silty clay to clay
- 4 Silty clay to silty sand
- 5 Sand mixtures - silty sand to sandy silt
- 6 Sands - clean sand to silty sand
- 7 Gravely sand to dense sand
- 8 Very stiff sand to clayey sand
- 9 Very stiff fine grained

CPT Started: 3/22/2016
CPT Completed: 3/22/2016

Rig: Pagani TG73-200
Operator: BR

Project No.: EN165065
Exhibit: A-4

Probe no. 4675 with net area ratio of 0.84
U2 pore pressure transducer location
Manufactured by Geotech A.B.; calibrated 10/22/2015
Tip and sleeve areas of 10 cm² and 150 cm²
Ring friction reducer with O.D. of 1.875 in

WATER LEVEL OBSERVATION
8.5 ft measured water depth
(used in normalizations and correlations; see Appendix C)



CPT Started: 3/22/2016
Rig: Pagani TG73-200
Operator: BR
Project No.: EN165065
Exhibit: A-4

CPT LOG NO. CPT-221


PROJECT: Winyah Generation Station

CLIENT: Santee Cooper
Moncks Corner, South Carolina

TEST LOCATION: See Exhibit A-2

SITE: Georgetown, South Carolina

Latitude: 33.3229°
Longitude: -79.3492°



See Exhibit A-3 for description of field procedures.
See Appendix C for explanation of symbols and abbreviations.

Dead weight of rig used as reaction force.
CPT sensor calibration reports available upon request.

- 1 Sensitive, fine grained
- 2 Organic soils - clay
- 3 Silty - silty clay to clay
- 4 Silty sand
- 5 Sand mixtures - silty sand to sandy silt
- 6 Sands - clean sand to silty sand
- 7 Gravelly sand to dense sand
- 8 Very stiff sand to clayey sand
- 9 Very stiff fines grained

WATER LEVEL OBSERVATION
6 ft estimated water depth
(used in normalizations and correlations;
see Appendix C)

Probe no. 4526 with net area ratio of 0.83
U2 pore pressure transducer location
Manufactured by Geotech A.B.; calibrated 12/7/2015
Tip and sleeve areas of 10 cm² and 150 cm²
Ring friction reducer with O.D. of 1.875 in



CPT Started: 3/23/2016
Rig: Pagani TG73-200
Project No.: EN165065

CPT Completed: 3/23/2016
Operator: JB
Exhibit: A-4

CPT LOG NO. CPT-222


PROJECT: Winyah Generation Station

CLIENT: Santee Cooper
Moncks Corner, South Carolina

TEST LOCATION: See Exhibit A-2

SITE: Georgetown, South Carolina

Latitude: 33.3236°
Longitude: -79.3477°



See Exhibit A-3 for description of field procedures.
See Appendix C for explanation of symbols and abbreviations.

Dead weight of rig used as reaction force.
CPT sensor calibration reports available upon request.

- 1 Sensitive, fine grained
- 2 Organic soils - clay
- 3 Silty - silty clay to clay
- 4 Silty - silty silt to silty clay
- 5 Sand mixtures - silty sand to sandy silt
- 6 Sands - clean sand to silty sand
- 7 Gravely sand to dense sand
- 8 Very stiff sand to clayey sand
- 9 Very stiff fines grained

WATER LEVEL OBSERVATION
5 ft estimated water depth
(used in normalizations and correlations; see Appendix C)

Probe no. 4675 with net area ratio of 0.84
U2 pore pressure transducer location
Manufactured by Geotech A.B.; calibrated 10/22/2015
Tip and sleeve areas of 10 cm² and 150 cm²
Ring friction reducer with O.D. of 1.875 in



CPT Started: 3/23/2016
Rig: Pagani TG73-200
Project No.: EN165065

CPT Completed: 3/23/2016
Operator: BR
Exhibit: A-4

CPT LOG NO. CPT-223


PROJECT: Winyah Generation Station

CLIENT: Santee Cooper
Moncks Corner, South Carolina

TEST LOCATION: See Exhibit A-2

SITE: Georgetown, South Carolina

Latitude: 33.3218°
Longitude: -79.3473°



See Exhibit A-3 for description of field procedures.
See Appendix C for explanation of symbols and abbreviations.

Dead weight of rig used as reaction force.
CPT sensor calibration reports available upon request.

WATER LEVEL OBSERVATION
4 ft measured water depth
(used in normalizations and correlations; see Appendix C)

Probe no. 4675 with net area ratio of 0.84
U2 pore pressure transducer location
Manufactured by Geotech A.B.; calibrated 10/22/2015
Tip and sleeve areas of 10 cm² and 150 cm²
Ring friction reducer with O.D. of 1.875 in



CPT Started: 3/23/2016
Rig: Pagani TG73-200
Project No.: EN165065

CPT Completed: 3/23/2016
Operator: BR
Exhibit: A-4

CPT LOG NO. CPT-223A


PROJECT: Winyah Generation Station

CLIENT: Santee Cooper
Moncks Corner, South Carolina

TEST LOCATION: See Exhibit A-2

SITE: Georgetown, South Carolina

Latitude: 33.3218°
Longitude: -79.3473°



See Exhibit A-3 for description of field procedures.
See Appendix C for explanation of symbols and abbreviations.

Dead weight of rig used as reaction force.
CPT sensor calibration reports available upon request.

- 1 Sensitive, fine grained
- 2 Organic soils - clay
- 3 Silty - silty clay to clay
- 4 Silty clay to silty sand
- 5 Sand mixtures - silty sand to sandy silt
- 6 Sands - clean sand to silty sand
- 7 Gravelly sand to dense sand
- 8 Very stiff sand to clayey sand
- 9 Very stiff fine grained

WATER LEVEL OBSERVATION
3.75 ft measured water depth
(used in normalizations and correlations;
see Appendix C)

Probe no. 4675 with net area ratio of 0.84
U2 pore pressure transducer location
Manufactured by Geotech A.B.; calibrated 10/22/2015
Tip and sleeve areas of 10 cm² and 150 cm²
Ring friction reducer with O.D. of 1.875 in



CPT Started: 3/23/2016
Rig: Pagani TG73-200
Project No.: EN165065

CPT Completed: 3/23/2016
Operator: BR
Exhibit: A-4

CPT LOG NO. CPT-224


PROJECT: Winyah Generation Station

CLIENT: Santee Cooper
Moncks Corner, South Carolina

TEST LOCATION: See Exhibit A-2

SITE: Georgetown, South Carolina

Latitude: 33.321°
Longitude: -79.3491°



See Exhibit A-3 for description of field procedures.
See Appendix C for explanation of symbols and abbreviations.

Dead weight of rig used as reaction force.
CPT sensor calibration reports available upon request.

- 1 Sensitive, fine grained
- 2 Organic soils - clay
- 3 Silty - silty clay to clay
- 4 Silty clay to silty silt
- 5 Sand mixtures - silty sand to sandy silt
- 6 Sands - clean sand to silty sand
- 7 Gravely sand to dense sand
- 8 Very stiff sand to clayey sand
- 9 Very stiff fine grained

WATER LEVEL OBSERVATION
5 ft estimated water depth
(used in normalizations and correlations; see Appendix C)

Probe no. 4675 with net area ratio of 0.84
U2 pore pressure transducer location
Manufactured by Geotech A.B.; calibrated 10/22/2015
Tip and sleeve areas of 10 cm² and 150 cm²
Ring friction reducer with O.D. of 1.875 in



CPT Started: 3/23/2016
Rig: Pagani TG73-200
Project No.: EN165065

CPT Completed: 3/23/2016
Operator: BR
Exhibit: A-4

CPT LOG NO. CPT-225


PROJECT: Winyah Generation Station

CLIENT: Santee Cooper
Moncks Corner, South Carolina

TEST LOCATION: See Exhibit A-2

SITE: Georgetown, South Carolina

Latitude: 33.3176°
Longitude: -79.351°



See Exhibit A-3 for description of field procedures.
See Appendix C for explanation of symbols and abbreviations.

Dead weight of rig used as reaction force.
CPT sensor calibration reports available upon request.

- 1 Sensitive, fine grained
- 2 Organic soils - clay
- 3 Silty - silty clay to clay
- 4 Silty clay to silty clay
- 5 Sand mixtures - silty sand to sandy silt
- 6 Sands - clean sand to silty sand
- 7 Gravely sand to dense sand
- 8 Very stiff sand to clayey sand
- 9 Very stiff fine grained

WATER LEVEL OBSERVATION
1 ft measured water depth
(used in normalizations and correlations; see Appendix C)

Probe no. 4675 with net area ratio of 0.84
U2 pore pressure transducer location
Manufactured by Geotech A.B.; calibrated 10/22/2015
Tip and sleeve areas of 10 cm² and 150 cm²
Ring friction reducer with O.D. of 1.875 in



CPT Started: 3/23/2016
Rig: Pagani TG73-200
Project No.: EN165065

CPT Completed: 3/23/2016
Operator: BR
Exhibit: A-4

CPT LOG NO. CPT-226


PROJECT: Winyah Generation Station

CLIENT: Santee Cooper
Moncks Corner, South Carolina

TEST LOCATION: See Exhibit A-2

SITE: Georgetown, South Carolina

Latitude: 33.3211°
Longitude: -79.3472°



See Exhibit A-3 for description of field procedures.
See Appendix C for explanation of symbols and abbreviations.

Dead weight of rig used as reaction force.
CPT sensor calibration reports available upon request.

- 1 Sensitive, fine grained
- 2 Organic soils - clay
- 3 Silty - silty clay to clay
- 4 Silty clay to silty sand
- 5 Sand mixtures - silty sand to sandy silt
- 6 Sands - clean sand to silty sand
- 7 Gravely sand to dense sand
- 8 Very stiff sand to clayey sand
- 9 Very stiff fine grained

WATER LEVEL OBSERVATION
5 ft estimated water depth
(used in normalizations and correlations; see Appendix C)

Probe no. 4675 with net area ratio of 0.84
U2 pore pressure transducer location
Manufactured by Geotech A.B.; calibrated 10/22/2015
Tip and sleeve areas of 10 cm² and 150 cm²
Ring friction reducer with O.D. of 1.875 in



CPT Started: 3/23/2016
Rig: Pagani TG73-200
Project No.: EN165065

CPT Completed: 3/23/2016
Operator: BR
Exhibit: A-4


CPT LOG NO. CPT-227

PROJECT: Winyah Generation Station
CLIENT: Santee Cooper
 Moncks Corner, South Carolina

SITE: Georgetown, South Carolina

TEST LOCATION: See Exhibit A-2

Latitude: 33.324°
 Longitude: -79.3467°



Dead weight of rig used as reaction force.
 CPT sensor calibration reports available upon request.

See Exhibit A-3 for description of field procedures.
 See Appendix C for explanation of symbols and abbreviations.


WATER LEVEL OBSERVATION	Probe no. 4675 with net area ratio of 0.84 U2 pore pressure transducer location Manufactured by Geotech A.B.; calibrated 10/22/2015 Tip and sleeve areas of 10 cm ² and 150 cm ² Ring friction reducer with O.D. of 1.875 in see Appendix C	CPT Started: 3/23/2016	CPT Completed: 3/23/2016
5 ft estimated water depth (used in normalizations and correlations; see Appendix C)		Rig: Pagani TG73-200	Operator: BR
		Project No.: EN165065	Exhibit: A-4



ATTACHMENT 3-B


**Shear Wave Velocity Test Data
(Provided by Mid-Atlantic Drilling)**

Mid-Atlantic Drilling CPT-135




Hammer to Rod String Distance 1 (m)
* - Not Determined

Mid-Atlantic Drilling CPT-150



Hammer to Rod String Distance 1 (m)
* = Not Determined

Mid-Atlantic Drilling CPT-152



Hammer to Red String Distance l (m)
* - Not Determined

ATTACHMENT 3-C

Dissipation Test Data
(Provided by Mid-Atlantic Drilling)


Mid-Atlantic Drilling Inc.

Operator Cory Robison
Sounding: CPT-150
Cone Used: DDG1195

CPT Date/Time: 10/2/2013 4:08:10 PM
Location: Georgetown S.C.
Job Number: GSC-5242

Selected Depth(s)
(feet)

35.499



Maximum Pressure = 9.278 psi
Hydrostatic Pressure = 15.407 psi


Mid-Atlantic Drilling Inc.

Operator Cory Robison
Sounding: CPT-152
Cone Used: DDG1195

CPT Date/Time: 9/25/2013 12:08:19 PM
Location: Georgetown S.C.
Job Number: GSC-5242

Selected Depth(s)
(feet)

15.42



Maximum Pressure = 14.147 psi
Hydrostatic Pressure = 6.692 psi


Mid-Atlantic Drilling Inc.

Operator Cory Robison
Sounding: CPT-153
Cone Used: DDG1195

CPT Date/Time: 9/25/2013 11:25:11 AM
Location: Georgetown S.C.
Job Number: GSC-5242

Selected Depth(s)
(feet)

14.928



Maximum Pressure = 11.693 psi
Hydrostatic Pressure = 6.479 psi

ATTACHMENT 4

Laboratory Testing Results
(provided by Excel Geotechnical Testing and
Terracon)

Index Testing



Excel Geotechnical Testing, Inc.
"Excellence in Testing"

953 Forrest Street, Roswell, Georgia 30075
 Tel: (770) 910 7537 Fax: (770) 910 7538

Test Results Summary

Project Name: Winyah Generating Station

Ponds A & B

Project No.: 618

Sample Information		Test Information										Remarks
Site ID	Lab No.	Moisture Content ASTM D 2216 (%)	Grain Size Analysis ASTM D 422					Atterberg Limits ASTM D 4318			Engineering Classification ASTM D 2487	
			Gravel Content (%)	Sand Content (%)	Fines Content (%)	Silt Content (%)	Clay Content (%)	LL (-)	PL (-)	PI (-)	SC	
			(-)	(-)	(-)	(-)	(-)	(-)	(-)	(-)		
SPT-114, SS-01 (5.0-6.5')	13J227	15.8	0.3	72.8	26.9	7.4	19.5	NP	NP	NP	SC	
SPT-114, SS-02 (10.0-11.5')	13J228											
SPT-114, SS-03 (15.0-16.5')	13J229											
SPT-114, SS-04 (20.0-21.5')	13J230											
SPT-114, SS-05 (25.0-26.5')	13J231	23.2			9.2							
SPT-114, ST-01 (26.5-28.5')	13J370											
SPT-114, SS-06 (30.0-31.5')	13J232											
SPT-114, SS-07 (35.0-36.5')	13J233	25.7			7.0							
SPT-114, SS-08 (40.0-41.5')	13J234	26.6	0.4	85.5	14.1							
SPT-114, SS-09 (45.0-46.5')	13J235											
SPT-114, SS-10 (50.0-51.5')	13J236	20.5	5.5	80.6	13.9							
SPT-114, SS-11 (55.0-56.5')	13J237	26.7			14.7							
SPT-114, SS-12 (60.0-61.5')	13J238											
SPT-115, SS-01 (5.0-6.5')	13J239											
SPT-115, SS-02 (10.0-11.5')	13J240	7.6			8.2							
SPT-115, SS-03 (15.0-16.5')	13J241											
SPT-115, SS-04 (20.0-21.5')	13J242											
SPT-115, SS-05 (25.0-26.5')	13J243											
SPT-115, SS-06 (30.0-31.5')	13J244											
SPT-115, SS-07 (35.0-36.5')	13J245	27.6	0.0	89.8	10.2							
SPT-115, SS-08 (40.0-41.5')	13J246											
SPT-115, SS-09 (45.0-46.5')	13J247	26.1	11.5	71.5	17.0			61	24	37	SC	
SPT-115, SS-10 (50.0-51.5')	13J248											
SPT-115, SS-11 (55.0-56.5')	13J249											
SPT-115, SS-12 (60.0-61.5')	13J250	16.0	23.8	58.3	17.9							
SPT-115, SS-13 (65.0-66.5')	13J251	15.0			18.3							
SPT-115, SS-14 (70.0-71.5')	13J252											

Notes:

1-16-14
 PD, NSR



Excel Geotechnical Testing, Inc.
 "Excellence in Testing"

953 Forrest Street, Roswell, Georgia 30075
 Tel: (770) 910 7537 Fax: (770) 910 7538

Test Results Summary

Project Name: Winyah Generating Station

Ponds A & B

Project No.: 618

Sample Information		Test Information										Remarks	
Site ID	Lab No.	Moisture Content ASTM D 2216 (%)	Grain Size Analysis ASTM D 422					Atterberg Limits ASTM D 4318			Engineering Classification ASTM D 2487 (-)		
			Gravel Content (%)	Sand Content (%)	Fines Content (%)	Silt Content (%)	Clay Content (%)	LL (-)	PL (-)	PI (-)			
			(-)	(-)	(-)	(-)	(-)	(-)	(-)	(-)			
SPT-121, SS-01 (5.0-6.5')	13J310												
SPT-121, SS-02 (10.0-11.5')	13J311	14.8			10.7								
SPT-121, SS-03 (15.0-16.5')	13J312												
SPT-121, SS-04 (20.0-21.5')	13J313												
SPT-121, SS-05 (25.0-26.5')	13J314												
SPT-121, SS-06 (30.0-31.5')	13J315	27.8	0.0	92.6	7.4								
SPT-121, SS-07 (35.0-36.5')	13J316	36.0			14.3								
SPT-121, SS-08 (40.0-41.5')	13J317	17.3	11.0	73.7	15.3								
SPT-121, SS-09 (45.0-46.5')	13J318	31.1			14.5								

Note:

1-16-14
 PD, NSR



Excel Geotechnical Testing, Inc.
"Excellence in Testing"

953 Forrest Street, Roswell, Georgia 30075
 Tel: (770) 910 7537 Fax: (770) 910 7538

Test Results Summary

Project Name: Winyah Generating Station

Project No.: 771

Sample Information		Test Information											Remarks		
Site ID	Lab No.	Moisture Content ASTM D 2216 (%)	Grain Size Analysis ASTM D 422					Atterberg Limits ASTM D 4318			Dry Unit Weight ⁽¹⁾ Modified ASTM D 2937			Engin. Classif. ASTM D 2487 (-)	
			Gravel Content (%)	Sand Content (%)	Fines Content (%)	Silt Content (%)	Clay Content (%)	LL (-)	PL (-)	PI (-)	Moisture Content (%)	Dry Unit Weight (pcf)			
(-)	(-)	(%)	(%)	(%)	(%)	(%)	(%)	(%)	(-)	(-)	(-)	(%)	(pcf)	(-)	
SPT-309-S-1 (0-2')	16C055														
SPT-309-S-2 (2-4')	16C056														
SPT-309-S-3 (4-6')	16C057														
SPT-309-S-4 (6-8')	16C058														
SPT-309-S-5 (8-10')	16C059	17.6		78.5	21.5										
SPT-309-S-6 (10-12')	16C060														
SPT-309-S-7 (12-14')	16C061														
SPT-309-S-8 (14-16')	16C062														
SPT-309-S-9 (16-18')	16C063	22.0			9.6										
SPT-309-S-10 (18-20')	16C064														
SPT-309-S-11 (23.5-25')	16C065														
SPT-309-S-12 (28.5-30')	16C066	31.6			7.3										
SPT-309-S-13 (33.5-35')	16C067	30.7	0.1	88.0	11.9										
SPT-309-S-14 (38.5-40')	16C068														
SPT-309-S-15 (43.5-45')	16C069	27.5			11.1										
SPT-309-S-16 (48.5-50')	16C070														
SPT-309-S-17 (53.5-55')	16C071	29.8			29.5										
SPT-309-S-18 (58.5-60')	16C072														
SPT-310-S-1 (0-2')	16C073														
SPT-310-S-2 (2-4')	16C074														
SPT-310-S-3 (4-6')	16C075														
SPT-310-S-4 (6-8')	16C076														
SPT-310-S-5 (8-10')	16C077														
SPT-310-S-6 (10-12')	16C078	23.5			22.8										
SPT-310-S-7 (12-14')	16C079														
SPT-310-S-8 (14-16')	16C080														
SPT-310-S-9 (16-18')	16C081	21.7			10.5										

Notes:

*4-14-16
APK, NSR*



Excel Geotechnical Testing, Inc.
"Excellence in Testing"


953 Forrest Street, Roswell, Georgia 30075
 Tel: (770) 910 7537 Fax: (770) 910 7538

Project Name: Winyah Generating Station
Project No: 618
Client Sample ID: SPT-114, SS-01 (5.0-6.5')
Lab Sample No: 13J227

ASTM C 136, D-422, D 854,
 D 1140, D 2216, D 2487, D 4318

SOIL INDEX PROPERTIES

Grain Size, Spec. Gravity, Moist. Cont.,
 Eng. Classification, Atterberg Limits




Sieve No.	Size (mm)	% Finer
3"	75	100.0
2"	50	100.0
1.5"	37.5	100.0
1"	25	100.0
3/4"	19	100.0
3/8"	9.5	100.0
#4	4.75	99.7
#10	2.00	99.7
#20	0.850	99.2
#40	0.425	97.8
#60	0.250	93.6
#100	0.150	54.0
#200	0.075	26.9

Hydrometer Particle Diameter (mm)	% Finer
0.0312	23.9
0.0116	22.1
0.0059	19.9
0.0029	18.0
0.0012	16.5

Gravel (%):	0.3
Sand (%):	72.8
Fines (%):	26.9
Silt (%):	7.4
Clay (%):	19.5

Coeff. Unif. (Cu):	
Coeff. Curv. (Cc):	

Specific Gravity (-):	2.70
-----------------------	------



Client Sample ID	Lab Sample No.	Moisture Content (%)	Fines Content < No. 200 (%)	Atterberg Limits			Engineering Classification
				LL (-)	PL (-)	PI (-)	
SPT-114, SS-01 (5.0-6.5')	13J227	15.8	26.9	NP	NP	NP	SC - Clayey sand

Note(s): An assumed specific gravity of 2.70 was used when analyzing the hydrometer test results.
 Engineering classification is based on the assumption that the fines are either CL or CH.

11-08-13
 TR, NSR



Excel Geotechnical Testing, Inc.
"Excellence in Testing"


953 Forrest Street, Roswell, Georgia 30075
 Tel: (770) 910 7537 Fax: (770) 910 7538

Project Name: Winyah Generating Station
Project No: 618
Client Sample ID: SPT-114, SS-08 (40.0-41.5')
Lab Sample No: 13J234

ASTM C 136, D 422, D 854,
 D 1146, D2216, D 2497, D4318

SOIL INDEX PROPERTIES

Grain Size, Spec. Gravity, Moist. Content,
 Eng. Classification, Atterberg Limits




Sieve No.	Size (mm)	% Finer
3"	75	100.0
2"	50	100.0
1.5"	37.5	100.0
1"	25	100.0
3/4"	19	100.0
3/8"	9.5	100.0
#4	4.75	99.6
#10	2.00	98.9
#20	0.850	95.4
#40	0.425	87.2
#60	0.250	68.2
#100	0.150	19.2
#200	0.075	14.1

Hydrometer Particle Diameter (mm)	% Finer

Gravel (%):	0.4
Sand (%):	85.5
Fines (%):	14.1
Silt (%):	
Clay (%):	

Coeff. Unif. (Cu):	
Coeff. Curv. (Cc):	



Specific Gravity (-):	
-----------------------	--

Client Sample ID.	Lab Sample No.	Moisture Content (%)	Fines Content < No. 200 (%)	Atterberg Limits			Engineering Classification
				LL (-)	PL (-)	PI (-)	
SPT-114, SS-08 (40.0-41.5')	13J234	26.6	14.1				

Note(s):

11-0813
 TR, NSR



Excel Geotechnical Testing, Inc.
"Excellence in Testing"


953 Forrest Street, Roswell, Georgia 30075
 Tel: (770) 910 7537 Fax: (770) 910 7538

Project Name: Winyah Generating Station
Project No: 618
Client Sample ID: SPT-114, SS-10 (50.0-51.5')
Lab Sample No: 13J236

ASTM C 136, D 422, D 854,
 D 1140, D2216, D 2487, D4318

SOIL INDEX PROPERTIES

Grain Size, Spec. Gravity, Moist. Content,
 Eng. Classification, Atterberg Limits




Sieve No.	Size (mm)	% Finer
3"	75	100.0
2"	50	100.0
1.5"	37.5	100.0
1"	25	100.0
3/4"	19	100.0
3/8"	9.5	98.9
#4	4.75	94.5
#10	2.00	83.9
#20	0.850	71.8
#40	0.425	59.1
#60	0.250	39.3
#100	0.150	16.1
#200	0.075	13.9

Hydrometer Particle Diameter (mm)	% Finer

Gravel (%):	5.5
Sand (%):	80.6
Fines (%):	13.9
Silt (%):	
Clay (%):	

Coeff. Unif. (Cu):	
Coeff. Curv. (Cc):	

Specific Gravity (-):	
-----------------------	--



Client Sample ID.	Lab Sample No.	Moisture Content (%)	Fines Content < No. 200 (%)	Atterberg Limits			Engineering Classification
				LL (-)	PL (-)	PI (-)	
SPT-114, SS-10 (50.0-51.5')	13J236	20.5	13.9				

Note(s):

11-08-13
 TR, NSR



Excel Geotechnical Testing, Inc.
"Excellence in Testing"


953 Forrest Street, Roswell, Georgia 30075
 Tel: (770) 910 7537 Fax: (770) 910 7538

Project Name: Winyah Generating Station
Project No: 618
Client Sample ID: SPT-115, SS-07 (35.0-36.5')
Lab Sample No: 13J245

ASTM C 136, D 422, D 854,
 D 1140, D2216, D 2487, D4319

SOIL INDEX PROPERTIES

Grain Size, Spec. Gravity, Moist. Content,
 Eng. Classification, Atterberg Limits




Sieve No.	Size (mm)	% Finer
3"	75	100.0
2"	50	100.0
1.5"	37.5	100.0
1"	25	100.0
3/4"	19	100.0
3/8"	9.5	100.0
#4	4.75	100.0
#10	2.00	99.9
#20	0.850	95.3
#40	0.425	90.7
#60	0.250	83.8
#100	0.150	65.9
#200	0.075	10.2

Hydrometer Particle Diameter (mm)	% Finer

Gravel (%):	
Sand (%):	89.8
Fines (%):	10.2
Silt (%):	
Clay (%):	

Coeff. Unit. (Cu):	
Coeff. Curv. (Cc):	

Specific Gravity (-):	
-----------------------	--



Client Sample ID.	Lab Sample No.	Moisture Content (%)	Fines Content < No. 200 (%)	Atterberg Limits			Engineering Classification
				LL (-)	PL (-)	PI (-)	
SPT-115, SS-07 (35.0-36.5')	13J245	27.6	10.2				

Note(s):

11-08-13
 TR JSR



Excel Geotechnical Testing, Inc.
"Excellence in Testing"

953 Forrest Street, Roswell, Georgia 30075
 Tel: (770) 910 7537 Fax: (770) 910 7538

Project Name: Winyah Generating Station
Project No: 618
Client Sample ID: SPT-115, SS-09 (45.0-46.5')
Lab Sample No: 13J247


ASTM C 136, D 422, D 854,
 D 1140, D2216, D 2487, D4318

SOIL INDEX PROPERTIES

Grain Size, Spes. Gravity, Moist. Content,
 Eng. Classification, Atterberg Limits

Boulder	Cobbles	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
		Gravel		Sand				

U.S. Standard Sieve Sizes and Numbers													
12"	3"	2"	1.5"	1 3/4"	1 1/2"	3/8"	#4	#10	#20	#40	#60	#100	#200




Sieve No.	Size (mm)	% Finer
3"	75	100.0
2"	50	100.0
1.5"	37.5	100.0
1"	25	100.0
3/4"	19	100.0
3/8"	9.5	98.2
#4	4.75	88.5
#10	2.00	68.8
#20	0.850	51.8
#40	0.425	40.0
#60	0.250	29.0
#100	0.150	20.0
#200	0.075	17.0

Hydrometer Particle Diameter (mm)	% Finer

Gravel (%):	11.5
Sand (%):	71.5
Fines (%):	17.0
Silt (%):	
Clay (%):	

Coeff. Unif. (Cu):	
Coeff. Curv. (Cc):	

Specific Gravity (-):	
-----------------------	--



Client Sample ID.	Lab Sample No.	Moisture Content (%)	Fines Content < No. 200 (%)	Atterberg Limits			Engineering Classification
				LL (-)	PL (-)	PI (-)	
SPT-115, SS-09 (45.0-46.5')	13J247	26.1	17.0	61	24	37	SC - Clayey sand

Note(s): Engineering classification is based on the assumption that the fines are either CL or CH.

11-08-13
 TR NSR



Excel Geotechnical Testing, Inc.
"Excellence in Testing"


953 Forrest Street, Roswell, Georgia 30075
 Tel: (770) 910 7537 Fax: (770) 910 7538

Project Name: Winyah Generating Station
Project No: 618
Client Sample ID: SPT-115, SS-12 (60.0-61.5')
Lab Sample No: 13J250

ASTM C 136, D 421, D 854,
 D 1148, D 2216, D 2487, D 4318

SOIL INDEX PROPERTIES

Grain Size, Spec. Gravity, Moist. Content,
 Eng. Classification, Atterberg Limits




Sieve No.	Size (mm)	% Finer
3"	75	100.0
2"	50	100.0
1.5"	37.5	100.0
1"	25	100.0
3/4"	19	91.4
3/8"	9.5	84.5
#4	4.75	76.2
#10	2.00	66.4
#20	0.850	60.8
#40	0.425	57.1
#60	0.250	49.7
#100	0.150	20.4
#200	0.075	17.9

Hydrometer Particle Diameter (mm)	% Finer

Gravel (%):	23.8
Sand (%):	58.3
Fines (%):	17.9
Silt (%):	
Clay (%):	

Coeff. Univ. (Cu):	
Coeff. Curv. (Cc):	

Specific Gravity (-):	
-----------------------	--



Client Sample ID.	Lab Sample No.	Moisture Content (%)	Fines Content < No. 200 (%)	Atterberg Limits			Engineering Classification
				LL (-)	PL (-)	PI (-)	
SPT-115, SS-12 (60.0-61.5')	13J250	16.0	17.9				

Note(s):

11-08-13
 TR, VSR



Excel Geotechnical Testing, Inc.
"Excellence in Testing"

953 Forrest Street, Roswell, Georgia 30075
 Tel: (770) 910 7537 Fax: (770) 910 7538

Project Name: Winyah Generating Station
Project No: 618
Client Sample ID: SPT-121, SS-06 (30.0-31.5')
Lab Sample No: 13J315


ASTM C 136, D 432, D 854,
 D 1140, D 2216, D 2487, D 4318

SOIL INDEX PROPERTIES

Grain Size, Spec. Gravity, Mois. Content,
 Eng. Classification, Atterberg Limits

Boulder	Cobbles	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
		Gravel		Sand				

U.S. Standard Sieve Sizes and Numbers													
12"	3"	2"	1.5"	1 3/4"	1 1/2"	3/8"	#4	#10	#20	#40	#60	#100	#200




Sieve No.	Size (mm)	% Finer
3"	75	100.0
2"	50	100.0
1.5"	37.5	100.0
1"	25	100.0
3/4"	19	100.0
3/8"	9.5	100.0
#4	4.75	100.0
#10	2.00	99.9
#20	0.850	99.2
#40	0.425	98.8
#60	0.250	96.7
#100	0.150	45.2
#200	0.075	7.4

Hydrometer Particle Diameter (mm)	% Finer

Gravel (%):	
Sand (%):	92.6
Fines (%):	7.4
Silt (%):	
Clay (%):	

Coeff. Unif. (Cu):	
Coeff. Curv. (Cc):	



Specific Gravity (-):	
-----------------------	--

Client Sample ID.	Lab Sample No.	Moisture Content (%)	Fines Content < No. 200 (%)	Atterberg Limits			Engineering Classification
				LL (-)	PL (-)	PI (-)	
SPT-121, SS-06 (30.0-31.5')	13J315	27.8	7.4				

Note(s):

11-08-13
 TR, NSR



Excel Geotechnical Testing, Inc.
"Excellence in Testing"


953 Forrest Street, Roswell, Georgia 30075
 Tel: (770) 910 7537 Fax: (770) 910 7538

Project Name: Winyah Generating Station
Project No: 618
Client Sample ID: SPT-121, SS-08 (40.0-41.5')
Lab Sample No: 13J317

ASTM C 136, D 422, D 854,
 D 1140, D2216, D 2487, D4318

SOIL INDEX PROPERTIES

Grain Size, Spec. Gravity, Moist. Content,
 Eng. Classification, Atterberg Limits




Sieve No.	Size (mm)	% Finer
3"	75	100.0
2"	50	100.0
1.5"	37.5	100.0
1"	25	100.0
3/4"	19	100.0
3/8"	9.5	98.1
#4	4.75	89.0
#10	2.00	76.6
#20	0.850	61.0
#40	0.425	46.6
#60	0.250	33.5
#100	0.150	17.9
#200	0.075	15.3

Hydrometer Particle Diameter (mm)	% Finer

Gravel (%):	11.0
Sand (%):	73.7
Fines (%):	15.3
Silt (%):	
Clay (%):	

Coeff. Unif. (Cu):	
Coeff. Curv. (Cc):	



Specific Gravity (-):	
-----------------------	--

Client Sample ID.	Lab Sample No.	Moisture Content (%)	Fines Content < No. 200 (%)	Atterberg Limits			Engineering Classification
				LL (-)	PL (-)	PI (-)	
SPT-121, SS-08 (40.0-41.5')	13J317	17.3	15.3				

Note(s):

11-88-13
 DR, VSR



Excel Geotechnical Testing, Inc.
"Excellence in Testing"


953 Forrest Street, Roswell, Georgia 30075
 Tel: (770) 910 7537 Fax: (770) 910 7538

Project Name: Winyah Generating Station
Project No: 618
Client Sample ID: SPT-122, ST-01 (12.0-14.0')
Lab Sample No: 13J375

ASTM C 136, D 422, D 454,
 D 1148, D 2216, D 2487, D 4318

SOIL INDEX PROPERTIES

Grain Size, Spec. Gravity, Moist. Cont.,
 Eng. Classification, Atterberg Limits




Sieve No.	Size (mm)	% Finer
3"	75	100.0
2"	50	100.0
1.5"	37.5	100.0
1"	25	100.0
3/4"	19	100.0
3/8"	9.5	100.0
#4	4.75	100.0
#10	2.00	99.9
#20	0.850	98.9
#40	0.425	96.6
#60	0.250	92.7
#100	0.150	85.3
#200	0.075	73.7

Hydrometer Particle Diameter (mm)	% Finer
0.0352	62.5
0.0141	39.7
0.0073	27.6
0.0037	15.4
0.0016	10.9

Gravel (%):	
Sand (%):	26.3
Fines (%):	73.7
Silt (%):	54.6
Clay (%):	19.1

Coeff. Unif. (Cu):	
Coeff. Curv. (Cc):	

Specific Gravity (-):	2.243
-----------------------	-------



Client Sample ID:	Lab Sample No:	Moisture Content (%)	Fines Content < No. 200 (%)	Atterberg Limits			Engineering Classification
				LL (-)	PL (-)	PI (-)	
SPT-122, ST-01 (12.0-14.0')	13J375		73.7	NP	NP	NP	ML - Silt with sand

Note(s):
 Test material is fly ash.

12-08-13
 NSR



Excel Geotechnical Testing, Inc.
"Excellence In Testing"


953 Forrest Street, Roswell, Georgia 30075
Tel: (770) 910 7537 Fax: (770) 910 7538

Project Name: Winyah Generating Station
Project No: 618
Client Sample ID: SPT-122, ST-03 (18.0-20.0')
Lab Sample No: 131376

ASTM C 136, D 422, D 854,
D 1140, D 2216, D 2487, D 4318

SOIL INDEX PROPERTIES

Grain Size, Spet. Gravity, Moiss. Cont.,
Eng. Classification, Atterberg Limits




Sieve No.	Size (mm)	% Finer
3"	75	100.0
2"	50	100.0
1.5"	37.5	100.0
1"	25	100.0
3/4"	19	100.0
3/8"	9.5	100.0
#4	4.75	100.0
#10	2.00	100.0
#20	0.850	100.0
#40	0.425	100.0
#60	0.250	99.8
#100	0.150	99.0
#200	0.075	99.0

Hydrometer Particle Diameter (mm)	% Finer
0.0226	76.5
0.0115	45.2
0.0066	25.0
0.0035	13.5
0.0015	5.6

Gravel (%)	
Sand (%)	1.0
Fines (%)	99.0
Silt (%)	79.4
Clay (%)	19.6

Specific Gravity (-):	2.3
-----------------------	-----

Coeff. Unif. (Cu):	
Coeff. Curv. (Cc):	



Client Sample ID	Lab Sample No.	Moisture Content (%)	Fines Content < No. 200 (%)	Atterberg Limits			Engineering Classification
				LL (-)	PL (-)	PI (-)	
SPT-122, ST-03 (18.0-20.0')	131376		99.0	NP	NP	NP	ML - Silt

Note(s): An assumed specific gravity of 2.3 was used when analyzing the hydrometer test results.

Test material is fly ash.

12-20-13
MSR



Excel Geotechnical Testing, Inc.
"Excellence in Testing"


953 Forrest Street, Roswell, Georgia 30075
 Tel: (770) 910 7537 Fax: (770) 910 7538

Project Name: Winyah Generating Station
 Project No: 771
 Client Sample ID: SPT-309-S-13 (33.5-35)
 Lab Sample No: 16C067

ASTM C 136, D 422, D 654,
 D 1140, D2156, D 2487, D4318

SOIL INDEX PROPERTIES

Grain Size, Spec. Gravity, Moist. Content,
 Eng. Classification, Atterberg Limits




Sieve No.	Size (mm)	% Finer
3"	75	100.0
2"	50	100.0
1.5"	37.5	100.0
1"	25	100.0
3/4"	19	100.0
3/8"	9.5	100.0
#4	4.75	99.9
#10	2.00	99.4
#20	0.850	96.5
#40	0.425	94.4
#60	0.250	90.2
#100	0.150	64.6
#200	0.075	11.9

Hydrometer Particle Diameter (mm)	% Finer

Gravel (%):	0.1
Sand (%):	88.0
Fines (%):	11.9
Silt (%):	
Clay (%):	

Coeff. UniE. (Cu):	
Coeff. Curv. (Cc):	



Specific Gravity (-):

Client Sample ID.	Lab Sample No.	Moisture Content (%)	Fines Content < No. 200 (%)	Atterberg Limits			Engineering Classification
				LL (-)	PL (-)	PI (-)	
SPT-309-S-13 (33.5-35)	16C067	30.7	11.9				

Notes:

4-08-16
NSA



Excel Geotechnical Testing, Inc.
"Excellence in Testing"


953 Forrest Street, Roswell, Georgia 30075
 Tel: (770) 910 7537 Fax: (770) 910 7538

Project Name: Winyah Generating Station
 Project No: 771
 Client Sample ID: SPT-310-S-12 (28.5-30")
 Lab Sample No: 16C084

ASTM C 136, D 422, D #54,
 D 1140, D2216, D 2487, D4318

SOIL INDEX PROPERTIES

Grain Size, Spec. Gravity, Moist. Content,
 Eng. Classification, Atterberg Limits




Sieve No.	Size (mm)	% Finer
3"	75	100.0
2"	50	100.0
1.5"	37.5	100.0
1"	25	100.0
3/4"	19	100.0
3/8"	9.5	100.0
#4	4.75	100.0
#10	2.00	99.4
#20	0.850	93.5
#40	0.425	82.4
#60	0.250	71.8
#100	0.150	27.7
#200	0.075	5.3

Hydrometer Particle Diameter (mm)	% Finer

Gravel (%):	
Sand (%):	94.7
Fines (%):	5.3
Silt (%):	
Clay (%):	

Coeff. Unif. (Cu):	
Coeff. Curv. (Cc):	



Specific Gravity (G_s):


Client Sample ID	Lab Sample No	Moisture Content (%)	Fines Content < No. 200 (%)	Atterberg Limits			Engineering Classification
				LL (-)	PL (-)	PI (-)	
SPT-310-S-12 (28.5-30")	16C084	33.7	5.3				

Note(s):

4-08-16
 NDR

GRAIN SIZE DISTRIBUTION

ASTM D422 / ASTM C136



COBBLES	GRAVEL		SAND			SILT OR CLAY	
	coarse	fine	coarse	medium	fine		

BORING ID	DEPTH	% COBBLES	% GRAVEL	% SAND	% SILT	% FINES	% CLAY	USCS
● SPT-307	30 - 32					2.8		

<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th colspan="2" style="text-align: center;">GRAIN SIZE</th> </tr> <tr> <td style="width: 50%; text-align: center;">●</td> <td></td> </tr> <tr> <td style="text-align: center;">D₆₀</td> <td></td> </tr> <tr> <td style="text-align: center;">D₃₀</td> <td></td> </tr> <tr> <td style="text-align: center;">D₁₀</td> <td></td> </tr> <tr> <th colspan="2" style="text-align: center;">COEFFICIENTS</th> </tr> <tr> <td style="text-align: center;">C_c</td> <td></td> </tr> <tr> <td style="text-align: center;">C_u</td> <td></td> </tr> </table>	GRAIN SIZE		●		D ₆₀		D ₃₀		D ₁₀		COEFFICIENTS		C _c		C _u		<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 15%;">SIEVE (size)</th> <th colspan="2" style="width: 35%;">PERCENT FINER</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;">●</td> <td></td> <td></td> </tr> <tr> <td>1 1/2"</td> <td></td> <td></td> </tr> <tr> <td>1"</td> <td></td> <td></td> </tr> <tr> <td>3/4"</td> <td></td> <td></td> </tr> <tr> <td>1/2"</td> <td></td> <td></td> </tr> <tr> <td>3/8"</td> <td></td> <td></td> </tr> <tr> <td>#4</td> <td></td> <td></td> </tr> <tr> <td>#10</td> <td></td> <td></td> </tr> <tr> <td>#20</td> <td></td> <td></td> </tr> <tr> <td>#40</td> <td></td> <td></td> </tr> <tr> <td>#60</td> <td></td> <td></td> </tr> <tr> <td>#100</td> <td></td> <td></td> </tr> <tr> <td>#200</td> <td style="text-align: center;">2.76</td> <td></td> </tr> </tbody> </table>	SIEVE (size)	PERCENT FINER		●			1 1/2"			1"			3/4"			1/2"			3/8"			#4			#10			#20			#40			#60			#100			#200	2.76		<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th style="text-align: center;">SOIL DESCRIPTION</th> </tr> <tr> <td style="text-align: center;">●</td> </tr> <tr> <th style="text-align: center;">REMARKS</th> </tr> <tr> <td style="text-align: center;">●</td> </tr> </table>	SOIL DESCRIPTION	●	REMARKS	●
GRAIN SIZE																																																																
●																																																																
D ₆₀																																																																
D ₃₀																																																																
D ₁₀																																																																
COEFFICIENTS																																																																
C _c																																																																
C _u																																																																
SIEVE (size)	PERCENT FINER																																																															
●																																																																
1 1/2"																																																																
1"																																																																
3/4"																																																																
1/2"																																																																
3/8"																																																																
#4																																																																
#10																																																																
#20																																																																
#40																																																																
#60																																																																
#100																																																																
#200	2.76																																																															
SOIL DESCRIPTION																																																																
●																																																																
REMARKS																																																																
●																																																																

PROJECT: Winyah Generation Station

SITE: Georgetown, South Carolina



1450 Fifth St W
North Charleston, SC

PROJECT NUMBER: EN165065


CLIENT: Santee Cooper
Moncks Corner, South Carolina

EXHIBIT: B-31

LABORATORY TESTS ARE NOT VALID IF SEPARATED FROM ORIGINAL REPORT. GRAIN SIZE: USCS 1 EN165065 WINYAH GENERATION STATION.GPJ 5/13/16

GRAIN SIZE DISTRIBUTION

ASTM D422 / ASTM C136



COBBLES	GRAVEL		SAND			SILT OR CLAY	
	coarse	fine	coarse	medium	fine		

BORING ID	DEPTH	% COBBLES	% GRAVEL	% SAND	% SILT	% FINES	% CLAY	USCS
● SPT-307	38 - 40					3.7		

<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th colspan="2" style="text-align: center;">GRAIN SIZE</th> </tr> <tr> <td style="width: 50%; text-align: center;">●</td> <td></td> </tr> <tr> <td style="text-align: center;">D₆₀</td> <td></td> </tr> <tr> <td style="text-align: center;">D₃₀</td> <td></td> </tr> <tr> <td style="text-align: center;">D₁₀</td> <td></td> </tr> <tr> <th colspan="2" style="text-align: center;">COEFFICIENTS</th> </tr> <tr> <td style="text-align: center;">C_c</td> <td></td> </tr> <tr> <td style="text-align: center;">C_u</td> <td></td> </tr> </table>	GRAIN SIZE		●		D ₆₀		D ₃₀		D ₁₀		COEFFICIENTS		C _c		C _u		<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 15%;">SIEVE (size)</th> <th style="width: 15%;">PERCENT FINER</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;">●</td> <td></td> </tr> <tr> <td>1 1/2"</td> <td></td> </tr> <tr> <td>1"</td> <td></td> </tr> <tr> <td>3/4"</td> <td></td> </tr> <tr> <td>1/2"</td> <td></td> </tr> <tr> <td>3/8"</td> <td></td> </tr> <tr> <td>#4</td> <td></td> </tr> <tr> <td>#10</td> <td></td> </tr> <tr> <td>#20</td> <td></td> </tr> <tr> <td>#40</td> <td></td> </tr> <tr> <td>#60</td> <td></td> </tr> <tr> <td>#100</td> <td></td> </tr> <tr> <td>#200</td> <td style="text-align: center;">3.66</td> </tr> </tbody> </table>	SIEVE (size)	PERCENT FINER	●		1 1/2"		1"		3/4"		1/2"		3/8"		#4		#10		#20		#40		#60		#100		#200	3.66	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th style="text-align: center;">SOIL DESCRIPTION</th> </tr> <tr> <td style="text-align: center;">●</td> </tr> <tr> <th style="text-align: center;">REMARKS</th> </tr> <tr> <td style="text-align: center;">●</td> </tr> </table>	SOIL DESCRIPTION	●	REMARKS	●
GRAIN SIZE																																																		
●																																																		
D ₆₀																																																		
D ₃₀																																																		
D ₁₀																																																		
COEFFICIENTS																																																		
C _c																																																		
C _u																																																		
SIEVE (size)	PERCENT FINER																																																	
●																																																		
1 1/2"																																																		
1"																																																		
3/4"																																																		
1/2"																																																		
3/8"																																																		
#4																																																		
#10																																																		
#20																																																		
#40																																																		
#60																																																		
#100																																																		
#200	3.66																																																	
SOIL DESCRIPTION																																																		
●																																																		
REMARKS																																																		
●																																																		

PROJECT: Winyah Generation Station

SITE: Georgetown, South Carolina



1450 Fifth St W
North Charleston, SC

PROJECT NUMBER: EN165065


CLIENT: Santee Cooper
Moncks Corner, South Carolina

EXHIBIT: B-32

LABORATORY TESTS ARE NOT VALID IF SEPARATED FROM ORIGINAL REPORT. GRAIN SIZE: USCS 1 EN165065 WINYAH GENERATION STATION.GPJ 5/13/16

GRAIN SIZE DISTRIBUTION

ASTM D422 / ASTM C136



COBBLES	GRAVEL		SAND			SILT OR CLAY			
	coarse	fine	coarse	medium	fine				

BORING ID	DEPTH	% COBBLES	% GRAVEL	% SAND	% SILT	% FINES	% CLAY	USCS
● SPT-307	40 - 42					6.4		

<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th colspan="2" style="text-align: center;">GRAIN SIZE</th> </tr> <tr> <td style="width: 50%; text-align: center;">●</td> <td style="width: 50%;"></td> </tr> <tr> <td style="text-align: center;">D₆₀</td> <td></td> </tr> <tr> <td style="text-align: center;">D₃₀</td> <td></td> </tr> <tr> <td style="text-align: center;">D₁₀</td> <td></td> </tr> <tr> <th colspan="2" style="text-align: center;">COEFFICIENTS</th> </tr> <tr> <td style="text-align: center;">C_c</td> <td></td> </tr> <tr> <td style="text-align: center;">C_u</td> <td></td> </tr> </table>	GRAIN SIZE		●		D ₆₀		D ₃₀		D ₁₀		COEFFICIENTS		C _c		C _u		<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 15%;">SIEVE (size)</th> <th colspan="2" style="width: 35%;">PERCENT FINER</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;">●</td> <td></td> <td></td> </tr> <tr> <td>1 1/2"</td> <td></td> <td></td> </tr> <tr> <td>1"</td> <td></td> <td></td> </tr> <tr> <td>3/4"</td> <td></td> <td></td> </tr> <tr> <td>1/2"</td> <td></td> <td></td> </tr> <tr> <td>3/8"</td> <td></td> <td></td> </tr> <tr> <td>#4</td> <td></td> <td></td> </tr> <tr> <td>#10</td> <td></td> <td></td> </tr> <tr> <td>#20</td> <td></td> <td></td> </tr> <tr> <td>#40</td> <td></td> <td></td> </tr> <tr> <td>#60</td> <td></td> <td></td> </tr> <tr> <td>#100</td> <td></td> <td></td> </tr> <tr> <td>#200</td> <td style="text-align: center;">6.39</td> <td></td> </tr> </tbody> </table>	SIEVE (size)	PERCENT FINER		●			1 1/2"			1"			3/4"			1/2"			3/8"			#4			#10			#20			#40			#60			#100			#200	6.39		<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th style="text-align: center;">SOIL DESCRIPTION</th> </tr> <tr> <td style="text-align: center;">●</td> </tr> <tr> <th style="text-align: center;">REMARKS</th> </tr> <tr> <td style="text-align: center;">●</td> </tr> </table>	SOIL DESCRIPTION	●	REMARKS	●
GRAIN SIZE																																																																
●																																																																
D ₆₀																																																																
D ₃₀																																																																
D ₁₀																																																																
COEFFICIENTS																																																																
C _c																																																																
C _u																																																																
SIEVE (size)	PERCENT FINER																																																															
●																																																																
1 1/2"																																																																
1"																																																																
3/4"																																																																
1/2"																																																																
3/8"																																																																
#4																																																																
#10																																																																
#20																																																																
#40																																																																
#60																																																																
#100																																																																
#200	6.39																																																															
SOIL DESCRIPTION																																																																
●																																																																
REMARKS																																																																
●																																																																

PROJECT: Winyah Generation Station

SITE: Georgetown, South Carolina



PROJECT NUMBER: EN165065


CLIENT: Santee Cooper
Moncks Corner, South Carolina

EXHIBIT: B-33

LABORATORY TESTS ARE NOT VALID IF SEPARATED FROM ORIGINAL REPORT. GRAIN SIZE: USCS 1 EN165065 WINYAH GENERATION STATION.GPJ 5/13/16

GRAIN SIZE DISTRIBUTION

ASTM D422 / ASTM C136



COBBLES	GRAVEL		SAND			SILT OR CLAY	
	coarse	fine	coarse	medium	fine		

BORING ID	DEPTH	% COBBLES	% GRAVEL	% SAND	% SILT	% FINES	% CLAY	USCS
● SPT-308	20 - 22					2.1		

<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th style="width: 15%;">GRAIN SIZE</th> <td style="width: 15%; text-align: center;">●</td> <td style="width: 15%;"></td> <td style="width: 15%;"></td> </tr> <tr> <td>D₆₀</td> <td></td> <td></td> <td></td> </tr> <tr> <td>D₃₀</td> <td></td> <td></td> <td></td> </tr> <tr> <td>D₁₀</td> <td></td> <td></td> <td></td> </tr> <tr> <th style="width: 15%;">COEFFICIENTS</th> <td style="width: 15%;"></td> <td style="width: 15%;"></td> <td style="width: 15%;"></td> </tr> <tr> <td>C_c</td> <td></td> <td></td> <td></td> </tr> <tr> <td>C_u</td> <td></td> <td></td> <td></td> </tr> </table>	GRAIN SIZE	●			D ₆₀				D ₃₀				D ₁₀				COEFFICIENTS				C _c				C _u				<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th style="width: 15%;">SIEVE (size)</th> <th style="width: 15%;">PERCENT FINER</th> <td style="width: 15%; text-align: center;">●</td> <td style="width: 15%;"></td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> </tr> </table>	SIEVE (size)	PERCENT FINER	●						<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th style="width: 100%;">SOIL DESCRIPTION</th> <td style="width: 100%; text-align: center;">●</td> </tr> <tr> <td> </td> <td> </td> </tr> <tr> <th style="width: 100%;">REMARKS</th> <td style="width: 100%; text-align: center;">●</td> </tr> <tr> <td> </td> <td> </td> </tr> </table>	SOIL DESCRIPTION	●			REMARKS	●		
GRAIN SIZE	●																																													
D ₆₀																																														
D ₃₀																																														
D ₁₀																																														
COEFFICIENTS																																														
C _c																																														
C _u																																														
SIEVE (size)	PERCENT FINER	●																																												
SOIL DESCRIPTION	●																																													
REMARKS	●																																													

LABORATORY TESTS ARE NOT VALID IF SEPARATED FROM ORIGINAL REPORT. GRAIN SIZE: USCS 1 EN165065 WINYAH GENERATION STATION.GPJ 5/13/16

PROJECT: Winyah Generation Station

SITE: Georgetown, South Carolina




PROJECT NUMBER: EN165065

CLIENT: Santee Cooper
Moncks Corner, South Carolina

EXHIBIT: B-34

GRAIN SIZE DISTRIBUTION

ASTM D422 / ASTM C136



COBBLES	GRAVEL		SAND			SILT OR CLAY	
	coarse	fine	coarse	medium	fine		

BORING ID	DEPTH	% COBBLES	% GRAVEL	% SAND	% SILT	% FINES	% CLAY	USCS
● SPT-308	30 - 32					61.9		CH

<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th colspan="2" style="text-align: center;">GRAIN SIZE</th> </tr> <tr> <td style="width: 50%; text-align: center;">●</td> <td style="width: 50%;"></td> </tr> <tr> <td style="text-align: center;">D₆₀</td> <td></td> </tr> <tr> <td style="text-align: center;">D₃₀</td> <td></td> </tr> <tr> <td style="text-align: center;">D₁₀</td> <td></td> </tr> <tr> <th colspan="2" style="text-align: center;">COEFFICIENTS</th> </tr> <tr> <td style="text-align: center;">C_c</td> <td></td> </tr> <tr> <td style="text-align: center;">C_u</td> <td></td> </tr> </table>	GRAIN SIZE		●		D ₆₀		D ₃₀		D ₁₀		COEFFICIENTS		C _c		C _u		<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th style="width: 15%;">SIEVE (size)</th> <th style="width: 15%;">PERCENT FINER</th> </tr> <tr> <td style="text-align: center;">●</td> <td></td> </tr> </table>	SIEVE (size)	PERCENT FINER	●		<p>SOIL DESCRIPTION ● SANDY FAT CLAY (CH)</p> <p>REMARKS ●</p>
GRAIN SIZE																						
●																						
D ₆₀																						
D ₃₀																						
D ₁₀																						
COEFFICIENTS																						
C _c																						
C _u																						
SIEVE (size)	PERCENT FINER																					
●																						

LABORATORY TESTS ARE NOT VALID IF SEPARATED FROM ORIGINAL REPORT. GRAIN SIZE: USCS 1 EN165065 WINYAH GENERATION STATION.GPJ 5/13/16

PROJECT: Winyah Generation Station

SITE: Georgetown, South Carolina




PROJECT NUMBER: EN165065

CLIENT: Santee Cooper
Moncks Corner, South Carolina

EXHIBIT: B-35

GRAIN SIZE DISTRIBUTION

ASTM D422 / ASTM C136



COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	

BORING ID	DEPTH	% COBBLES	% GRAVEL	% SAND	% SILT	% FINES	% CLAY	USCS
● SPT-308	32 - 34	0.0	0.0	12.0	22.7		65.3	CH

<table border="1" style="width: 100%;"> <tr><th colspan="2">GRAIN SIZE</th></tr> <tr><td>D₆₀</td><td>0.003</td></tr> <tr><td>D₃₀</td><td></td></tr> <tr><td>D₁₀</td><td></td></tr> <tr><th colspan="2">COEFFICIENTS</th></tr> <tr><td>C_c</td><td></td></tr> <tr><td>C_u</td><td></td></tr> </table>	GRAIN SIZE		D ₆₀	0.003	D ₃₀		D ₁₀		COEFFICIENTS		C _c		C _u		<table border="1" style="width: 100%;"> <tr> <th>SIEVE (size)</th> <th colspan="2">PERCENT FINER</th> </tr> <tr> <td>●</td> <td></td> <td></td> </tr> </table>	SIEVE (size)	PERCENT FINER		●			<table border="1" style="width: 100%;"> <tr><th>SOIL DESCRIPTION</th></tr> <tr><td>● FAT CLAY (CH)</td></tr> <tr><th>REMARKS</th></tr> <tr><td>●</td></tr> </table>	SOIL DESCRIPTION	● FAT CLAY (CH)	REMARKS	●
GRAIN SIZE																										
D ₆₀	0.003																									
D ₃₀																										
D ₁₀																										
COEFFICIENTS																										
C _c																										
C _u																										
SIEVE (size)	PERCENT FINER																									
●																										
SOIL DESCRIPTION																										
● FAT CLAY (CH)																										
REMARKS																										
●																										

PROJECT: Winyah Generation Station

SITE: Georgetown, South Carolina



PROJECT NUMBER: EN165065

CLIENT: Santee Cooper
Moncks Corner, South Carolina

EXHIBIT: B-36

LABORATORY TESTS ARE NOT VALID IF SEPARATED FROM ORIGINAL REPORT. GRAIN SIZE: USCS 1 EN165065 WINYAH GENERATION STATION.GPJ 5/13/16

Triaxial Testing



Excel Geotechnical Testing, Inc.
"Excellence in Testing"

953 Forrest Street, Roswell, Georgia 30075
Tel: (770) 910 7537 Fax: (770) 910 7538

Project Name: Winyah Generating Station

Project No: 618


Site Sample ID: SPT-122, ST-01 (12.0-14.0')

Lab Sample No: 13J375

ASTM D 4767

**CONSOLIDATED-UNDRAINED (CU) TRIAXIAL TEST
WITH PORE PRESSURE MEASUREMENTS**

Figure 1



Test Specimen No.	Maximum Strength				
	Deviator Stress	Effective Axial Stress	Effective Radial Stress	Pore Pressure	Axial Strain
	$(\sigma'_1 - \sigma'_3)$ (psi)	(σ'_1) (psi)	(σ'_3) (psi)	(u) (psi)	(ϵ_u) (%)
1	61.2	84.2	23.0	43.5	15.2
2	36.8	49.5	12.7	62.3	15.1
3	49.6	69.4	19.8	60.2	15.0

Test Specimen No.	Strength at App. 15% Axial Strain				
	Deviator Stress	Effective Axial Stress	Effective Radial Stress	Pore Pressure	Axial Strain
	$(\sigma'_1 - \sigma'_3)$ (psi)	(σ'_1) (psi)	(σ'_3) (psi)	(u) (psi)	(ϵ_u) (%)
1	61.2	84.2	23.0	43.5	15.2
2	36.8	49.5	12.7	62.3	15.1
3	49.6	69.4	19.8	60.2	15.0

Notes:

σ'_c = Consolidation pressure, (psi) u_i = Initial pore pressure, (psi)

11-25-13
HJK



Excel Geotechnical Testing, Inc.
"Excellence in Testing"


953 Forrest Street, Roswell, Georgia 30075
 Tel: (770) 910 7537 Fax: (770) 910 7538

Project Name: Winyah Generating Station
Project No: 618
Site Sample ID: SPT-122, ST-01 (12.0-14.0')
Lab Sample No: 13J375

ASTM D 4767

**CONSOLIDATED-UNDRAINED (CU) TRIAXIAL TEST
 WITH PORE PRESSURE MEASUREMENTS**

Figure 2



Test Specimen No.	Initial Conditions							Axial Strain (% / min)	Specimen Quality (Bad to Good (1 to 10))
	Height (in.)	Diameter (in.)	Moisture Content (%)	Dry Unit Weight (pcf)	B Parameter (-)	Initial Pore Pressure (u) (psi)	Consolidation Pressure (σ'_c) (psi)		
1	6.00	2.93	76.8	54.2	1.00	60.0	6.5	0.100	5
2	6.05	2.80	64.1	60.7	0.98	60.0	15.0	0.099	4
3	6.18	2.83	53.1	67.4	0.98	60.0	20.0	0.097	5



Specimen No. 1
 Gray silt (fly ash)



Specimen No. 2
 Gray silt (fly ash)



Specimen No. 3
 Gray silt (fly ash)

Notes:

11-25-13
 NSR



Excel Geotechnical Testing, Inc.
 "Excellence in Testing"



953 Forrest Street, Roswell, Georgia 30075
 Tel: (770) 910 7537 Fax: (770) 910 7538

Project Name: Winyah Generating Station
Project No: 618
Site Sample ID: SPT-122, ST-03 (18.0-20.0')
Lab Sample No: 13J376

ASTM D 4767

**CONSOLIDATED-UNDRAINED (CU) TRIAXIAL TEST
 WITH PORE PRESSURE MEASUREMENTS**

Figure 1



Test Specimen No.	Maximum Strength				
	Deviator Stress ($\sigma'_1 - \sigma'_3$) (psi)	Effective Axial Stress (σ'_1) (psi)	Effective Radial Stress (σ'_3) (psi)	Pore Pressure (u) (psi)	Axial Strain (ϵ_a) (%)
1	33.6	46.7	13.1	52.9	15.0
2	42.3	58.6	16.3	60.7	14.9

Test Specimen No.	Strength at App. 15% Axial Strain				
	Deviator Stress ($\sigma'_1 - \sigma'_3$) (psi)	Effective Axial Stress (σ'_1) (psi)	Effective Radial Stress (σ'_3) (psi)	Pore Pressure (u) (psi)	Axial Strain (ϵ_a) (%)
1	33.6	46.7	13.1	52.9	15.0
2	42.3	58.6	16.3	60.7	14.9

Notes:

σ'_c = Consolidation pressure, (psi) u_i = Initial pore pressure, (psi)

12-17-13
NSR



Excel Geotechnical Testing, Inc.
"Excellence in Testing"


953 Forrest Street, Roswell, Georgia 30075
 Tel: (770) 910 7537 Fax: (770) 910 7538

Project Name: Winyah Generating Station
Project No: 618
Site Sample ID: SPT-122, ST-03 (18.0-20.0')
Lab Sample No: 13J376

ASTM D 4767

**CONSOLIDATED-UNDRAINED (CU) TRIAXIAL TEST
 WITH PORE PRESSURE MEASUREMENTS**

Figure 2



Test Specimen No.	Initial Conditions							Axial Strain (% / min)	Specimen Quality Bad to Good (1 to 10)
	Height (in.)	Diameter (in.)	Moisture Content (%)	Dry Unit Weight (pcf)	B Parameter (-)	Initial Pore Pressure (u_0) (psi)	Consolidation Pressure (σ'_c) (psi)		
1	6.44	2.86	49.9	65.0	0.98	60.0	6.0	0.093	5
2	5.77	2.80	62.7	60.1	0.94	60.0	17.0	0.104	5



Specimen No. 1
 Gray silt (fly ash)



Specimen No. 2
 Gray silt (fly ash)




Specimen No. 3

Notes:

12-17-13
 NSK


ICU TRIAXIAL COMPRESSION TEST



EFFECTIVE STRESS PARAMETERS

$\phi' = 23.1$ deg

$c' = 0.7$ psi



SPECIMEN NO.	1	2	3
INITIAL			
Moisture Content - %	115.4	145.3	
Dry Density - pcf	46.4	37.8	
Diameter - inches	2.86	2.86	
Height - inches	5.55	5.79	
AT TEST			
Final Moisture - %	62.1	77.7	
Dry Density - pcf	46.4	37.8	
Calculated Diameter - in.	2.86	2.87	
Height - inches	5.55	5.81	
Effect. Consol. Stress - psi	12.5	25.7	
Failure Stress - psi	12.98	15.83	
Total Pore Pressure - psi	57.9	63.2	
Strain Rate - inches/min.	0.00200	0.00200	
Failure Strain - %	3.2	3.8	
σ_1' Failure - psi	17.58	28.43	
σ_3' Failure - psi	4.60	12.60	

TEST DESCRIPTION




ISOTROPICALLY CONSOLIDATED, UNDRAINED TRIAXIAL COMPRESSION
 SAMPLE TYPE: Shelby Tube
 DESCRIPTION:
 SAMPLE: SPT 308 32-34
 ASSUMED SPECIFIC GRAVITY: 2.7
 LL: XX PL: XX PI: XX Percent -200: XX.X
 REMARKS: XXXXX

PROJECT INFORMATION

PROJECT: Winyah
 LOCATION:
 PROJECT NO: EN165065
 CLIENT: Santee Cooper
 DATE: 04/28/2016

**1450 Fifth St W
North Charleston, SC**





EFFECTIVE STRESS PARAMETERS	$R^2 = 1.00$	$\alpha = 21.4 \text{ deg}$	$a = 0.7 \text{ psi}$
PROJECT: Winyah	ISOTROPICALLY CONSOLIDATED, UNDRAINED TRIAXIAL COMPRESSION TEST		
PROJECT NO: EN165065	1450 Fifth St W		
DESCRIPTION:	North Charleston, SC		Terracon

Consolidation/Permeability Testing



Excel Geotechnical Testing, Inc
"Excellence in Testing"

953 Forrest Street, Roswell, Georgia 30075
 Tel: (770) 910 7537 Fax: (770) 910 7538

Project Name: Winyah Generating Station


Project No: 618

Client Sample ID: SPT-122, ST-01 (12-14')

Lab Sample No: 13J375

ASTM D 2435

ONE-DIMENSIONAL CONSOLIDATION TEST



Client Sample ID	Lab Sample No.	Specimen Quality 1-10 (Bad to Good)	Test Specimen Initial Conditions				Consolidation Pressure (psf)	Pressure Increment Duration (min)	Accumu. ⁽¹⁾ Vertical Strain (%)	Figure No.	Remarks
			Height (cm)	Diameter (cm)	Dry Unit Weight (pcf)	Moisture Content (%)					
SPT-122, ST-01 (12-14')	13J375	5	2.54	6.35	55.4	69.3	100	64	0.11	1	
							500	996	0.56	2	
							1000	300	0.95	3	
							2000	1343	1.55	4	
							4000	1331	2.44	5	
							8000	1376	3.79	6	
							16000	240	5.76	7	
							32000	1168	9.19	8	
							48000	1550	11.68	9	

Notes:

For each pressure increment, the vertical strain values were calculated based on the final deformation measurements.

*11-25-13
NSR*



Excel Geotechnical Testing, Inc.
"Excellence in Testing"

953 Forrest Street, Roswell, Georgia 30075
Tel: (770) 910 7537 Fax: (770) 910 7538

Project Name: Winyah Generating Station

Project No: 618



Client Sample ID: SPT-122, ST-01 (12-14')

Lab Sample No: 13J375

ASTM D 2435

ONE-DIMENSIONAL CONSOLIDATION TEST

Figure 1 - 100 psf



11-25-13
NSR



Excel Geotechnical Testing, Inc.
"Excellence in Testing"

953 Forrest Street, Roswell, Georgia 30075
Tel: (770) 910 7537 Fax: (770) 910 7538

Project Name: Winyah Generating Station

Project No: 618



Client Sample ID: SPT-122, ST-01 (12-14')

Lab Sample No: 13J375

ASTM D 2435

ONE-DIMENSIONAL CONSOLIDATION TEST

Figure 2 - 500 psf



11-25-13
ASB



Excel Geotechnical Testing, Inc.
"Excellence in Testing"

953 Forrest Street, Roswell, Georgia 30075
Tel: (770) 910 7537 Fax: (770) 910 7538

Project Name: Winyah Generating Station

Project No: 618



Client Sample ID: SPT-122, ST-01 (12-14')

Lab Sample No: 13J375

ASTM D 2435

ONE-DIMENSIONAL CONSOLIDATION TEST

Figure 3 - 1000 psf



11-25-13
NSR



Excel Geotechnical Testing, Inc.
"Excellence In Testing"

953 Forrest Street, Roswell, Georgia 30075
Tel: (770) 910 7537 Fax: (770) 910 7538

Project Name: Winyah Generating Station

Project No: 618



Client Sample ID: SPT-122, ST-01 (12-14')

Lab Sample No: 13J375

ASTM D 2435

ONE-DIMENSIONAL CONSOLIDATION TEST

Figure 4 - 2000 psf



11-25-13
NSR



Excel Geotechnical Testing, Inc.
"Excellence in Testing"

953 Forrest Street, Roswell, Georgia 30075
Tel: (770) 910 7537 Fax: (770) 910 7538

Project Name: Winyah Generating Station

Project No: 618



Client Sample ID: SPT-122, ST-01 (12-14')

Lab Sample No: 13J375

ASTM D 2435

ONE-DIMENSIONAL CONSOLIDATION TEST

Figure 5 - 4000 psf



11-25-13
JLR



Excel Geotechnical Testing, Inc.
"Excellence in Testing"

953 Forrest Street, Roswell, Georgia 30075
Tel: (770) 910 7537 Fax: (770) 910 7538

Project Name: Winyah Generating Station

Project No: 618



Client Sample ID: SPT-122, ST-01 (12-14')

Lab Sample No: 13J375

ASTM D 2435

ONE-DIMENSIONAL CONSOLIDATION TEST

Figure 6 - 8000 psf



11-25-13
NSR



Excel Geotechnical Testing, Inc.
"Excellence in Testing"

953 Forrest Street, Roswell, Georgia 30075
Tel: (770) 910 7537 Fax: (770) 910 7538

Project Name: Winyah Generating Station

Project No: 618



Client Sample ID: SPT-122, ST-01 (12-14')

Lab Sample No: 13J375

ASTM D 2435

ONE-DIMENSIONAL CONSOLIDATION TEST

Figure 7 - 16000 psf



11-25-13
NSR



Excel Geotechnical Testing, Inc.
"Excellence in Testing"

953 Forrest Street, Roswell, Georgia 30075
Tel: (770) 910 7537 Fax: (770) 910 7538

Project Name: Winyah Generating Station

Project No: 618



Client Sample ID: SPT-122, ST-01 (12-14')

Lab Sample No: 13J375

ASTM D 2435

ONE-DIMENSIONAL CONSOLIDATION TEST

Figure 8 - 32000 psf



11-25-13
NSR



Excel Geotechnical Testing, Inc
"Excellence in Testing"

953 Forrest Street, Roswell, Georgia 30075
Tel: (770) 910 7537 Fax: (770) 910 7538

Project Name: Winyah Generating Station

Project No: 618



Client Sample ID: SPT-122, ST-01 (12-14')

Lab Sample No: 13J375

ASTM D 2435

ONE-DIMENSIONAL CONSOLIDATION TEST



Figure 9 - 48000 psf



11-25-13
WJR

Winyah
SPT-308
EN165065


FROM 0.00 tsf t50 2.3 min.
TO 0.04 tsf t90 2.3 min.




**Winyah
SPT-308
EN165065**

FROM 0.04 tsf t50 6.0 min.
TO 0.08 tsf t90 56.3 min.

Load 2





Load 2




Winyah
SPT-308
EN165065

FROM 0.08 tsf t50 12.0 min.
TO 0.17 tsf t90 28.1 min.




FROM 0.17 tsf t50 8.0 min.
 TO 0.33 tsf t90 25.0 min.

Load 4




Load 4




Winyah
SPT-308
EN165065
1/0/00

FROM 0.33 tsf t50 8.0 min.
TO 0.67 tsf t90 25.0 min.

Load 5





load 5



Winyah
SPT-308
EN165065


FROM 0.67 tsf
TO 0.33 tsf




Winyah
SPT-308
EN165065

FROM 0.33 tsf
TO 0.17 tsf

Load 7




Load 7




Winyah
SPT-308
EN165065

FROM 0.17 tsf t50 2.00 min.
TO 0.33 tsf t90 6.25 min.

Load 8





Load 8




Winyah
SPT-308
EN165065

FROM 0.33 tsf 150 4.0 min.
TO 0.67 tsf 190 9.0 min.

Load 9



Reconstructed Consolidation Field Curve



$e_0 = 2.077$

$0.42e_0 = 0.872$

σ'_o (tsf) = 0.90

σ'_p (tsf) = 0.21

$C_r = 0.07$

$C_c = 3.98$

$C_{\epsilon_r} = 0.02$

$C_{\epsilon_c} = 1.29$

Winyah Generation Station

EN165065

SPT-308

308

32-34

Terracon


ATTACHMENT 5


Subsurface Stratigraphy and Material Properties

CALCULATION PACKAGE COVER SHEET


Client: Santee Cooper **Project:** Winyah Generating Station **Project No.** GSC5242


TITLE OF PACKAGE: **SUBSURFACE STRATIGRAPHY AND MATERIAL
PROPERTIES: ASH POND B**

Calculation Prepared by: Signature  10/10/2016
Name James McNash, P.E. Date

Assumptions & Procedures Checked by: Signature  10/10/2016
(peer reviewer) Name Ming Zhu, Ph.D., P.E. Date

Computations Checked by: Signature  10/10/2016
Name Clinton Carlson, Ph.D. Date

Computations Back-checked by: Signature  10/10/2016
Name James McNash, P.E. Date

Approved by: Signature  10/10/2016
(pm or designate) Name Fabian Benavente, P.E. Date

Approval notes: _____

Revisions (number and initial all revisions)

No.	Sheet	Date	By	Checked by	Approval
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____

Written by: J. McNash Date: 10/10/2016 Reviewed by: C. Carlson/M. Zhu Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No.: 01BT

SUBSURFACE STRATIGRAPHY AND MATERIAL PROPERTIES: ASH POND B

INTRODUCTION

This calculation package was prepared to present the subsurface stratigraphy and material properties supporting the geotechnical analyses for Ash Pond B located at Winyah Generating Station (WGS or “Site”), which is owned and operated by Santee Cooper. This calculation package is Attachment 5 to the *2016 Surface Impoundment Periodic Safety Factor Assessment Report: Ash Pond B* (Safety Factor Assessment Report) prepared by Geosyntec Consultants (Geosyntec). The remainder of this calculation package presents the: (i) site investigations; (ii) subsurface stratigraphy; (iii) interpretation of the phreatic surface and current water levels; (iv) standard penetration test (SPT) and cone penetration test (CPT) interpretation; (v) laboratory testing program and interpretation; (vi) in-situ testing interpretation; and (vii) recommended material properties for analysis.

SITE INVESTIGATIONS

This section summarizes the subsurface site investigations performed in the area of the Ash Pond B perimeter dikes at WGS. In the fall of 2013, Geosyntec conducted a focused subsurface investigation program to obtain geotechnical data supporting the evaluation of closure alternatives for the surface impoundment. Geosyntec returned to the Site in the spring of 2016 to collect additional subsurface information at five locations within the Ash Pond B perimeter dike or dike toe and several locations within the Ash Pond B interior. Historically, soil borings were performed in the vicinity of Ash Pond B prior to construction of the CCR surface impoundment; however, records (i.e., locations, boring logs, laboratory testing results) pertaining to these subsurface investigations were not available during the preparation of this Stability Report. Paul C. Rizzo Associates (PCRA) performed a geotechnical subsurface investigation program supporting the raising of the Ash Pond B perimeter dikes in 1993. Figure 1 presents the locations of soil test borings and CPT soundings performed during historical (when available) and Geosyntec’s subsurface investigations.

The geotechnical data obtained from these subsurface investigation programs, including soil test borings, CPT sounding data, and laboratory test results, are provided in Attachments 2, 3, and 4, respectively, of the Safety Factor Assessment Report. The following section summarizes each subsurface site investigation in the vicinity of Ash Pond B.

Paul C. Rizzo Associates (PCRA) Investigation

In 1993, PCRA conducted a focused geotechnical subsurface investigation of the Ash Pond B perimeter dikes to evaluate the feasibility of increasing the dike height by 7 feet (ft). PCRA’s investigation included six soil test borings which were advanced 25 to 30 ft below ground surface (bgs)

Written by: J. McNash Date: 10/10/2016 Reviewed by: C. Carlson/M. Zhu Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No.: 01BT

using a CME-55 drilling rig and the hollow stem auger (4.25-inch inner diameter) method. SPTs were conducted in 5-ft depth intervals using a rope-and-cathead system to apply the 140-lb hammer dropping a height of 30 inches. Soil boring logs prepared by PCRA (included in Attachment 2) indicate that the perimeter dikes were constructed of medium dense to dense sand with some trace clay and silt. Underlying the dike fill soils, poorly graded sand to clayey and silty sands with some shell fragments were generally encountered within the foundation soils. Depth to water measurements were collected from each soil boring location prior to termination. During this subsurface investigation, the free water elevation within Ash Pond B was maintained approximately at 29.2 ft NGVD29 (PCRA, 1993). Additionally, PCRA identified a potential offsite borrow source adjacent to WGS containing suitable soil to construct the additional height of the perimeter dike. Two samples of the potential borrow soils were collected and tested for index properties (i.e., grain size distribution tests and Atterberg limits) and compaction properties (i.e., standard Proctor tests).

Geosyntec Investigations

In October 2013, Geosyntec mobilized to WGS to collect geotechnical subsurface data by performing additional soil test borings and CPT soundings in support of evaluating preliminary and conceptual closure alternatives for each CCR surface impoundment at WGS. The subsurface investigation was focused in the vicinity of the South Ash Pond, Unit 2 Slurry Pond, Ash Pond A, and Ash Pond B. In the Ash Pond B area, Geosyntec advanced four soil test borings by the mud rotary wash drilling method in general accordance with recommendations made by Idriss and Boulanger (2008) (Table 1) and seven CPT soundings. Soil Consultants, Inc. (SCI) of Charleston, South Carolina was the drilling contractor during this subsurface investigation; while, Mid-Atlantic Drilling, Inc. (MAD) from Wilmington, North Carolina performed the CPT soundings. One soil boring (SPT-122) and three CPT soundings (CPT-152, CPT-153, and CPT-154) were advanced within the interior of Ash Pond B, but were terminated once native or foundation materials were encountered. The remaining soil test borings and CPT soundings during this investigation were performed on the perimeter and divider dikes and were terminated once refusal was encountered, which was defined as SPT N-value of 50 blows per foot over an advancement of 6 inches or the inability to further advance the cone.

For each soil boring, split spoon samples were collected and SPT blow counts (i.e., N-values) were measured typically in 5-ft depth intervals. Attempts were made to push Shelby tubes within dike fill and foundation soils; however, the recompacted dike fill soils were found to be dense and cohesionless and thus, undisturbed samples were unable to be collected. In one soil test boring (SPT-115), SCI switched from a paddle drilling bit to a tri-cone rotary wash drill bit once the Chicora Member stratum was encountered to penetrate the stratum and extend the borehole into the underlying stiff clay. In SPT-115, an attempt was made to push a Shelby tube to collect a sample of the underlying stiff clay for laboratory testing. However, the Shelby tube was sheared during extraction from the borehole (i.e., the screws attached to the drilling rods sheared). For select CPT soundings, the shear wave velocity (V_s)

Written by: J. McNash Date: 10/10/2016 Reviewed by: C. Carlson/M. Zhu Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No.: 01BT

was measured in 5-ft depth intervals or a porewater pressure dissipation test was performed to evaluate the phreatic surface at that location. Results of the V_s and porewater pressure dissipation tests are provided in Attachment 3.

In November 2013, Geosyntec returned to WGS to install piezometers as part of the development of the hydrogeological model at the Site. One piezometer (PPZW-10D) was installed adjacent to a Site monitoring well (WAP-10) by South Atlantic Environmental Drilling and Construction Co. Inc. (SAEDACCO). Prior to installing the piezometer, subsurface soils were collected within the borehole using a split spoon sampler and logged by a geologist. SPT blow counts measured during this piezometer installation were utilized within the Safety Factor Assessment Report.

Geosyntec mobilized to WGS in the spring of 2016 to perform a focused geotechnical subsurface investigation in the vicinity of the South Ash Pond, Ash Pond A, Ash Pond B, and the former Unit 2 Slurry Pond. The investigation program along the Ash Pond B perimeter dikes consisted of two soil test borings (SPT-309 and SPT-310) advanced using the mud-rotary drilling technique by MAD and three CPTs (CPT-225, CPT-226, and CPT-227) advanced by Terracon. Additionally, Terracon (by means of Carolina Drilling, Inc.) advanced two additional borings (SPT-307 and SPT-308) and several CPTs within the Ash Pond B interior in support of evaluating preliminary and conceptual closure alternatives. For SPT-309 and SPT-310, split spoon samples were collected and SPTs were performed continuously in the upper 20 ft bgs and in 5-ft depth intervals thereafter until refusal was encountered. Refusal was defined as SPT N-value of 50 blows per foot over an advancement of 6 inches or less. Select soil samples were sealed and transported to a geotechnical laboratory for testing.

SUBSURFACE STRATIGRAPHY AND RESIDUAL MATERIALS

Subsurface Stratigraphy

The subsurface stratigraphy at WGS was developed based on information collected during Geosyntec's geotechnical investigation and from site wide geotechnical data from other historical investigations. Boring logs from the Geosyntec investigation are provided within Attachment 2 to this Safety Factor Assessment Report. The subsurface stratigraphy is described as follows:

- **Dike Fill:** Dike fill soils for the Ash Pond B perimeter dikes were generally observed to be medium dense to very dense poorly graded silty sands with uncorrected SPT blow counts typically ranging between 9 and 51 blows per foot. CPT tip resistances in the top 10 ft of fill typically ranged between 30 and 200 tons per square foot (tsf), while CPT tip resistances below the top 10 ft of fill typically ranged between 200 and 450 tsf. Grain size distribution analyses indicated that the dike fill soils consist of approximately 70 percent to 90 percent sand-sized particles (diameters smaller than 0.187 in. [i.e., No. 4 sieve], but larger than 0.0029 in. [i.e., No.

Written by: J. McNash Date: 10/10/2016 Reviewed by: C. Carlson/M. Zhu Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No.: 01BT

200 sieve]) and approximately 8 percent to 27 percent silty and clay-sized particles (i.e., percent fines or “fines” with diameters smaller than the 0.0029 in. [i.e., No. 200 sieve]).

- **Foundation Soils:** Foundation soils were observed to be variable across the Ash Pond B footprint, consisting primarily of poorly graded silty sands with shells and a few isolated seams of clayey sand or high plasticity clay. Uncorrected SPT blow counts within sandy foundations typically ranged between 2 and 30 blows per foot, while CPT tip resistances typically ranged between 25 and 150 tsf.
- **Chicora Member:** A dense to very dense layer of partially cemented to heavily cemented shells was encountered beneath the foundation soils during the past subsurface investigations at WGS. Blow counts in this layer exceeded 50 blows over less than 6 inches of advancement with minimal sample recovery. The thickness of the Chicora Member varies across WGS, particularly the partially cemented layers of the stratum. Based on review of historical and existing data, this layer is the upper portion of the overall Williamsburg Formation and is also referred to as “Coquina” or “Shell Hash” by others. The term “Chicora Member” or “Chicora” has been used to refer to this soil unit throughout the Safety Factor Assessment Report based on the description provided by Doar (2012). Soil boring and CPT refusal was typically encountered at the top of this stratum, though one soil boring (SPT-115) within the Ash Pond B area penetrated this stratum.
- **Williamsburg Formation Clay:** The Williamsburg Formation Clay stratum was encountered beneath the Chicora Member. The Williamsburg Formation Clay is described as stiff to very hard, dark gray to black, medium to high plasticity clay or silt with sand. The Williamsburg Formation Clay has historically been referred to as “Black Mingo Clay” or the “Black Mingo Formation” at the Site. The term “Williamsburg Formation Clay” is the most recent geological term for this stratum and is used throughout the Safety Factor Assessment Report. The Williamsburg Formation Clay was found to be between 30-ft and 90-ft thick in the vicinity of WGS based on a review of the regional geology.

Coal Combustion Residuals

CCR in the form of fly ash, boiler slag, and bottom ash has been stored at the WGS since disposal operations began within Ash Pond B. Three soil test borings and seven CPT soundings were performed within the Ash Pond B interior during the subsurface site investigation programs at WGS. Only fly ash was observed within samples collected during the soil test borings. The fly ash is described as follows:

- **Fly Ash:** Fly ash was found to be soft, black, sandy silt with SPT blow counts between 0 (i.e., weight of hammer) and 2 blows per foot. The measured tip resistance of the fly ash ranged

Written by: J. McNash Date: 10/10/2016 Reviewed by: C. Carlson/M. Zhu Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No.: 01BT

between 5 tsf and 50 tsf, with most measured values below 15 tsf. It is noted that most of the higher tip resistance values were observed within the upper 5 ft bgs.

PHREATIC SURFACE INTERPRETATION AND CURRENT WATER LEVELS

Water levels from rotary wash borings located on the dike centerline were measured 24 hours after borehole termination and daily until borehole abandonment. CPT soundings were advanced with a porewater pressure transducer, which recorded porewater pressure measurements during advancement, located behind the cone. The measured porewater pressures were interpreted to locate the phreatic surface at the time of each sounding. Dissipation tests were conducted during the CPT soundings at several locations. Excess porewater pressures were allowed to dissipate to equilibrium or hydrostatic conditions over 5 to 30 minutes depending on the rate of porewater pressure dissipation. The measured rate of dissipation was then used to compute the phreatic surface. The measured phreatic surface level at each location is summarized in Table 2.

Dike Phreatic Surface

During the recent site investigations, six soil test borings and five CPT soundings were advanced through the perimeter dike centerline. The measurements and estimations of the phreatic surface from these locations indicate that the phreatic surface elevation through the perimeter dikes ranges from 23 to 30 ft National Geodetic Vertical Datum of 1929 (NGVD29).

Free Field (Dike Toe) Phreatic Surface

During the 2013 and 2016 site investigations, two CPT soundings were advanced and a piezometer (PPZW-10D) was installed along the downstream toe of the Ash Pond B perimeter dikes adjacent to the Intake and Discharge Canals. Access to the dike toe adjacent to the Cooling Pond was limited during these site investigations and thus, in-situ testing was not performed in this area. Additionally, one groundwater monitoring well (WAP-10) was previously installed adjacent to Ash Pond B. Depth to water measurements within the piezometer and monitoring well have generally been collected monthly. The most recent measurements from May 2015 have been included in this evaluation. Porewater pressure (u_o), piezometer, and monitoring well measurements indicate that the phreatic surface elevation along the toe of the Ash Pond B perimeter dikes ranges from 21 to 23 ft NGVD29. It is noted that an upward gradient from the Chicora stratum to the overlying foundation soils was observed between monitoring well WAP-10 and piezometer PPZ-10D.

Written by: J. McNash Date: 10/10/2016 Reviewed by: C. Carlson/M. Zhu Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No.: 01BT

Water Levels Since 2013 Investigation

As described within the Hydrologic and Hydraulic (H&H) analysis provided in Attachment 1 of the Safety Factor Assessment Report, the water level within Ash Pond B is typically maintained at an elevation of 34.9 ft NGVD29 by a 4-ft by 4-ft concrete riser structure which discharges free water westward into the Discharge Canal.

A temporary piezometer installed within the Ash Pond B interior (PPZ-BS-1) indicates that the phreatic surface elevation within the fly ash is influenced by the free water within the impoundment (34.9 ft NGVD29) over the period of recorded data. The water level of the Cooling Pond was selected as 19.1 ft NGVD29 based on the operating level of the Cooling Pond necessary to manage runoff from the 25-yr, 24-hr rainfall event. The maximum free water elevation during the inflow design flood (IDF) within Ash Pond B was computed as 37.1 ft NGVD29, which was used to represent the “Maximum Surcharge Pool” level within this Safety Factor Assessment Report.

In late 2015, WGS installed supplementary groundwater monitoring wells (WAP-20 and WAP-21) along the Ash Pond B perimeter dike crest. Water level elevations have been measured on a quarterly basis since installation and the most recent available measurements are provided in Table 2. On 21 June 2016, the phreatic surface elevation was measured to be between 24.0 ft and 26.7 ft NGVD29 along the Ash Pond B perimeter dike crest.

SPT AND CPT INTERPRETATION

Results of SPT and CPT sounding data were processed and interpreted by the methods described below.

Standard Penetration Test Interpretation

During an SPT, the number of “blows” or impacts from a standard, 140-lb hammer falling 30 inches needed to advance the split spoon sampler 6 inches is recorded over 3 intervals for a total of 18 inches. The blows for the last two 6-inch intervals are summed and referred to as an “N-value”. Due to variations in drill rigs, hammer efficiency, and sampling methods, the field or measured value must be corrected to a standard value for use in engineering correlations and computations. This standard value is based on a hammer system that is 60 percent efficient (i.e., applies 60 percent of the theoretical maximum potential energy). The corrected N-value (N_{60}) is computed as follows:

$$N_{60} = N_{\text{meas}} C_E C_B C_S C_R \quad (1)$$

where:

Written by: J. McNash Date: 10/10/2016 Reviewed by: C. Carlson/M. Zhu Date: 10/10/2016

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No.: **01BT**

N_{60} = N-value corrected to 60 percent efficiency (blows/ft);
 N_{meas} = measured N-value in the field (blows/ft);
 C_E = correction factor for the applied energy of the hammer;
 C_B = correction factor for the borehole diameter;
 C_S = correction factor for the sampling method; and
 C_R = correction factor for the rod length.

The correction factor for the applied energy (C_E) of the hammer is often variable between drilling rigs and hammer type. This correction factor is computed as follows:

$$C_E = \frac{ER}{60} \quad (2)$$

where:

ER = energy ratio of the SPT hammer.

SCI provided calibration records for the hammer system of the CME-550X drilling rig used during fall 2013 based on calibration tests performed offsite on 3 April 2013. An Energy Ratio (ER) of 88 percent was computed for this drill rig (the calibration records are provided in Table 3). The rig utilized by SAEDACCO was calibrated by GRL Engineers, Inc. (GRLE), on 30 July 2013 prior to mobilizing to the site and measured to have an ER of 87 percent (GRLE, 2013). The CME-55 drilling rig utilized by MAD during the spring 2016 investigation was calibrated on 19 August 2015 and measured to have an ER of 77.2 percent, as shown in Table 4. The CME-45C drilling rig utilized by Carolina Drilling, Inc. during the 2016 site investigation was computed to have an ER of 79.3 percent, as shown in Table 5.

Values for the other correction factors were selected based on industry standards (Idriss and Boulanger, 2008) and are provided in Table 6. N_{60} was computed based on a 4-inch borehole (101.6 mm) and a standard split spoon sampler for borings performed during the Geosyntec's investigations. Rod length for the C_R conversion factor was selected based on the depth of the measured SPT blow counts and a 5-ft stickup from the length of the drilling rod and anvil above the top of the borehole.

In many correlations and for liquefaction analysis, N_{60} is commonly normalized based on in-situ stress state at the time of the soil boring. The normalized and corrected blow count is referred to as $(N_1)_{60}$ and is computed as follows:

$$(N_1)_{60} = C_N N_{60} \quad (3)$$

where:

C_N = stress normalization parameter.

Written by: J. McNash Date: 10/10/2016 Reviewed by: C. Carlson/M. Zhu Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No.: 01BT

C_N is calculated as:

$$C_N = (P_a / \sigma'_{vo})^n \quad (4)$$

where:

P_a = atmospheric pressure (pounds per square foot, psf);
 σ'_{vo} = effective vertical stress (psf); and
 n = exponent based on soil type.

The exponent, n , is typically 1.0 for clays and ranges from 0.5 to 0.6 for sands. Soil specific correlations for the exponent have been developed for various geomaterials, but are not locally available. A value of 0.5 was selected for sands encountered at WGS. N-values can be either corrected to N_{60} or $(N_1)_{60}$ depending on the correlation or analysis being performed.

Cone Penetration Test Interpretation

CPT soundings performed onsite measured the cone tip resistance (q_c), the sleeve friction (f_s), and the pore pressure (u_2) in 0.05-m (\approx 2-inch) intervals. The measured cone tip resistance (q_c) must be corrected for the influence of pore pressure acting on the cone tip (Robertson and Cabal, 2012). The corrected cone tip resistance is computed as follows:

$$q_t = q_c + (1 - a_n)u_2 \quad (5)$$

where:

q_t = corrected cone tip resistance (tsf);
 q_c = measured cone tip resistance (tsf);
 a_n = net area ratio; and
 u_2 = measured pore pressure (tsf).

The cone used by MAD had a net area ratio of 0.80, which was applied by Geosyntec prior to processing each CPT sounding.

CPT sounding data are commonly interpreted into a Soil Behavior Type Index (I_c) (Robertson and Cabal, 2012), which is computed using the normalized cone tip resistance and normalized sleeve friction ratio. The normalized cone tip resistance (Q) is computed as follows:

$$Q = \left(\frac{q_t - \sigma_{vo}}{P_a} \right) \left(\frac{P_a}{\sigma'_{vo}} \right)^n \quad (6)$$

where:

Written by: J. McNash Date: 10/10/2016 Reviewed by: C. Carlson/M. Zhu Date: 10/10/2016

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No.: **01BT**

Q = normalized cone resistance;
 q_t = corrected cone tip resistance (tsf);
 σ_{vo} = total vertical stress (tsf);
 σ'_{vo} = effective vertical stress (tsf);
 P_a = atmospheric pressure (tsf); and
n = coefficient dependent on soil type and stress level.

A coefficient, n, of 1 was selected when interpreting each CPT sounding.

The normalized sleeve friction ratio (F) is calculated as follows:

$$F = \left(\frac{f_s}{q_t - \sigma_{vo}} \right) \times 100\% \quad (7)$$

where:

F = normalized sleeve friction ratio;
 f_s = sleeve friction (tsf);
 q_t = corrected tip resistance (tsf); and
 σ_{vo} = total vertical stress (tsf).

Finally, the I_c is calculated as follows:

$$I_c = ((3.47 - \log Q)^2 + (\log F + 1.22)^2)^{0.5} \quad (8)$$

The normalized cone tip resistance and normalized friction ratio can be plotted on the Normalized Soil Behavior Type (SBT_N) Chart presented in Figure 2 to estimate the I_c . Additionally, Figure 2 presents the range of I_c corresponding to a given soil type. I_c was plotted with depth or elevation for each CPT sounding performed at WGS by Geosyntec. An example of Geosyntec's interpretation is presented in Figure 3 for CPT-135.

LABORATORY TESTING PROGRAM AND INTERPRETATION

Geosyntec subcontracted Excel Geotechnical Testing, Inc. (EGT) of Roswell, Georgia to conduct geotechnical laboratory testing of select split spoon and thin-walled Shelby tube samples collected within the dike fill soils, foundation soils, and CCR. The geotechnical laboratory testing program included index (grain size distribution, Atterberg limits, and natural water content), unit weight, shear strength, and one dimensional (1-D) consolidation tests. Appendix 1 summarizes the index, unit weight, and shear strength testing results from Geosyntec's geotechnical subsurface investigations. The raw laboratory test results are provided as Attachment 4 of the Safety Factor Assessment Report. Results from this laboratory testing program are discussed further below.

Written by: J. McNash Date: 10/10/2016 Reviewed by: C. Carlson/M. Zhu Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No.: 01BT

Index Testing

Dike Fill and Foundation Soils

The index testing program on dike fill and foundation soils included twelve grain size distribution tests, two of which included hydrometer tests to evaluate the distribution of grain sizes of the soil which passes the No. 200 sieve (i.e., particle diameters less than 0.0029 in.). Grain size distribution analyses indicated that dike fill soils consisted of 73 percent to 93 percent sand-sized material (diameters smaller than 0.187 in. [i.e., No. 4 sieve], but larger than 0.0029 in. [i.e., No. 200 sieve]) and 7 percent to 27 percent silt and clay-sized material (i.e., percent fines or “fines” with diameters smaller than the 0.0029 in. [i.e., No. 200 sieve]) with most of the samples containing 10 percent to 15 percent fines.

Foundation materials were observed to be variable across Ash Pond B, but composed predominantly of poorly graded sand to silty sand with pockets of clayey sand or high plasticity clay and clayey shell hash. The poorly graded and silty or clayey sands were observed to be composed of 58 percent to 95 percent sand-sized particles with 5 percent to 30 percent fines. Some samples were described to resemble “shell hash” and contained many shells and fine gravel that constituted between 5 percent to 24 percent of the sample by weight. A plot of the grain size distribution analysis results for Ash Pond B is provided in Figure 4.

Fines content tests were performed on twenty-two samples to supplement grain size distribution analyses. Fines content data, including results from grain size distribution analyses, are provided in Figure 5. Results indicated that the dike fill material typically contained less than 15 percent fines, except in the upper 5 to 10 ft bgs where the dike fill soils were found to contain between 22 percent to 27 percent fines. Foundation soils typically were observed to contain between 5 percent and 30 percent fines.

Geosyntec conducted seven Atterberg limit tests on clayey sands from the foundation soil and dike fill soil. Generally, Atterberg limit testing was not performed on soils that were observed in the field to be apparently non-plastic. The sample of clayey sand foundation soil was calculated to have a plasticity index of 37; while, the clayey sand dike fill (upper 5 to 7 ft bgs) was calculated to be non-plastic. Deeper clay seams were calculated to have plasticity indices ranging between 12 and 67. The calculated natural moisture contents of the foundation soil typically ranged between 8 percent and 36 percent within the sandy soils, but were as high as 76 percent in isolated seams of soft clay. A plot of the natural moisture content with elevation is provided in Figure 6.

Fly Ash

Written by: J. McNash Date: 10/10/2016 Reviewed by: C. Carlson/M. Zhu Date: 10/10/2016

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No.: **01BT**

Index testing was performed on Shelby tube samples of CCR collected from within the Ash Pond B interior. Two samples were tested and calculated to be composed of 1 percent and 26 percent sand-sized particles and 99 percent and 74 percent fines, respectively. Both samples of fly ash were calculated to be non-plastic. One specific gravity test was performed and a specific gravity of 2.24 was calculated. A pH test (ASTM D 4792) and carbonate content test (ASTM D 4373) were performed on one sample of fly ash. The results indicated that the pH and the carbonate content were 5.8 percent and 0.0 percent, respectively.

Total Unit Weight

Dike Fill and Foundation Soils

Since the dike fill soils were observed to be dense, silty to poorly graded sands, Shelby tube samples were unable to be recovered and tested. However, the unit weight was estimated using V_s measurements discussed later within this calculation package.

Fly Ash

The dry unit weight and initial moisture content were measured as part of the shear strength and consolidation tests for two fly ash samples collected within the interior of Ash Pond B. The total unit weight was calculated using the measured dry unit weight and initial moisture content. The results indicated that the total unit weight of the fly ash ranges from 81 pounds per cubic foot (pcf) to 100 pcf within Ash Pond B. A plot of the total unit weight measurements is provided as Figure 7.

Written by: J. McNash Date: 10/10/2016 Reviewed by: C. Carlson/M. Zhu Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No.: 01BT

Undrained Shear Strength

Two consolidated undrained (CU) triaxial strength tests were performed on extruded thin-walled Shelby tube samples of the fly ash material. A description of the CU test and its interpretation is presented herein.

Methodology

For CU triaxial tests, a soil sample is usually trimmed into two to three specimens (depending on the Shelby tube recovery), and each specimen is tested under a different initial effective confining stress. The initial effective confining stress applied in each test should generally be applied at the effective overburden stress state or greater. The larger overburden stress states compensate for the effect of sample disturbance. The undrained shear strength (S_u) measured in each CU test corresponds to the initial effective confining stress applied to the specimens rather than the in-situ effective overburden stress to which the specimens were subjected. Therefore, the measured S_u from each CU test cannot directly be used in subsequent analyses. However, a relationship between the S_u in the field and the calculated S_u from the CU test results can be used to calculate the “in-situ” S_u as explained below:

The undrained shear strength ratio, defined as S_u/σ'_c , can be calculated from CU test results, where S_u is the undrained shear strength measured in the laboratory and is equal to one half of the peak deviator stress (the peak deviator stress is assumed to indicate the failure point of the specimen in this calculation package), and σ'_c is the initial effective confining stress applied in the CU test. If the sample is overconsolidated, the calculated S_u/σ'_c is then corrected for the overconsolidation effect by multiplying by a factor of $OCR^{0.8}$ (Kulhawy and Mayne, 1990). The S_u/σ'_c , or the corrected S_u/σ'_c if the soil is overconsolidated, can be applied directly to a slope stability analysis program. The slope stability analysis program calculates the effective stress for each slice and then assigns the appropriate S_u value based on the undrained shear strength ratio.

Fly Ash

Two sets of 2-point or 3-point CU tests (i.e., tests on two or three specimens from a Shelby tube) were conducted on the collected fly ash samples. The undrained shear strength ratio was calculated for each test specimen based on the calculated peak deviator stress for each point. The test results indicated that undrained shear strength ratios range from 1.24 to 4.71 for the fly ash. A plot of the S_u/σ'_c assuming an OCR of 1.0 is shown in Figure 8.

Drained Shear Strength

The effective stress friction angle (ϕ') and cohesion intercept (c') were also computed based on the CU triaxial test results. The stress states (i.e., shear stress vs. effective normal stress) of the tested samples are represented using Mohr's circles. The Mohr's circles for all tests are then fit with a line that is

Written by: J. McNash Date: 10/10/2016 Reviewed by: C. Carlson/M. Zhu Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No.: 01BT

approximately tangent to all of the Mohr's circles, which represents the failure envelope. The effective normal stress and shear stress (i.e., x- and y-coordinates) at the point of tangency are defined as the normal stress at failure (σ_{NF}') and shear stress at failure (τ_{NF}'), respectively. The slope of the "best-fit" line corresponds to ϕ' and the shear stress intercept (i.e., y-intercept) corresponds to c' . The ϕ' and c' estimated by the "best-fit" line are then used to represent the drained shear strengths of the fly ash.

Fly Ash

The Mohr's circles from the CU triaxial tests on the fly ash are plotted in Figure 9. The σ_{NF}' and τ_{NF}' obtained from these Mohr's circles are shown in Figure 10. Based on the CU test results, the ϕ' and c' for the fly ash material were estimated to be 34° and 0 psf, respectively.

Consolidation Test Interpretation

Fly Ash

A 1-D consolidation test was conducted on a Shelby tube sample fly ash collected from within the Ash Pond B interior. The preconsolidation pressure (σ_p') estimated from this test was 9,000 psf. The strain is plotted against the applied vertical load in Figure 11. The modified compression index (C_{ce}) and modified recompression index (C_{re}) were calculated as 0.12 and 0.006, respectively. Additionally, the coefficient of consolidation (C_v) and modified coefficient of secondary consolidation ($C_{\alpha\epsilon}$) were calculated from each load increment and plotted as a function of the stress ratio (σ_v'/σ_p'). Figures 12 and 13 display the C_v and $C_{\alpha\epsilon}$ results for the fly ash.

IN-SITU TESTING INTERPRETATION

Correlations were applied to in-situ testing data (q_t , f_s , etc.) to compute index and strength properties of the materials. The computed values from the correlations were then compared to the laboratory test results. Additionally, correlations were used for the in-situ measurements of the V_s and porewater pressure dissipation performed at several locations along the perimeter dike centerline and dike toe. The following section describes the methodology and correlations applied to interpret index and strength properties from the in-situ testing performed at the Site.

Shear Wave Velocity

Shear wave velocity measurements were taken in 5-ft depth intervals at several locations along the dike centerline and dike toe using a seismic CPT. Raw V_s data is provided in Attachment 3 to the Safety Factor Assessment Report. The field V_s testing data was supplemented with correlated values developed from CPT sounding sleeve friction data from adjacent soundings. Robertson and Cabal

Written by: J. McNash Date: 10/10/2016 Reviewed by: C. Carlson/M. Zhu Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No.: 01BT

(2012) provides a correlation between V_s and CPT sounding data for saturated sands, clays, and silts, as follows:

$$V_s = [\alpha_{vs} \times (\frac{q_t \times \sigma_{vo}}{P_a})]^{0.5} \quad (9)$$

where:

V_s	=	shear wave velocity (m/s);
q_t	=	corrected tip resistance (tsf);
σ_{vo}	=	total vertical stress (tsf);
P_a	=	atmospheric pressure (tsf); and
α_{vs}	=	$10^{(0.55 \times I_c + 1.68)}$.

Drained Friction Angle

SPT N-values were utilized to estimate the drained peak effective stress friction angle of sandy soils. The Hatanaka and Uchida (1996) correlation was applied to estimate the peak friction angle of sand layers that are relatively clean as follows:

$$\phi' = \sqrt{15.4(N_1)_{60}} + 20^\circ \quad (10)$$

ϕ'	=	effective stress friction angle (degrees); and
$(N_1)_{60}$	=	stress normalized and energy corrected N-value (blows/ft).

Undrained Shear Strength Ratio

The undrained shear strength ratio, as computed by the following correlation, was compared with laboratory test data. The undrained shear strength ratio was estimated from CPT soundings based on the correlation presented by Robertson and Cabal (2012) as follows:

$$\frac{S_u}{\sigma'_v} = \frac{(q_t - \sigma_{vo})}{\sigma'_{vo}} \left(\frac{1}{N_{kt}} \right) \quad (11)$$

where:

S_u/σ'_v	=	undrained shear strength (tsf);
q_t	=	corrected tip resistance (tsf);
σ_{vo}	=	total vertical stress (tsf);
σ'_{vo}	=	effective vertical stress (tsf); and
N_{kt}	=	coefficient based on shear mode.

Written by: J. McNash Date: 10/10/2016 Reviewed by: C. Carlson/M. Zhu Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No.: 01BT

N_{kt} varies regionally and by material type, with a typical range between 10 and 20; a value of 15 was selected in this calculation package (FHWA, 2002).

Effective Friction Angle by CPT Sounding Correlation

The effective friction angle was computed for each CPT sounding by the following correlation suggested by Robertson and Campanella (1983) for un-cemented, un-aged, moderately compressible quartz sands based on calibration chamber testing, as follows:

$$\tan \phi' = \frac{1}{2.68} \left[\log \frac{q_c}{\sigma'_{vo}} + 0.29 \right] \quad (12)$$

where:

- ϕ' = effective friction angle (°);
- q_c = tip resistance (tsf); and
- σ'_{vo} = effective vertical stress (tsf).

Total Unit Weight

The total unit weight (γ_t) of saturated subsurface materials can be approximated based on V_s measurements (Mayne, 2001) as follows:

$$\gamma_t = 8.32 \log(V_s) - 1.81 \log(z) \quad (13)$$

where:

- γ_t = total unit weight (kiloNewton per cubic meter (kN/m³));
- V_s = shear wave velocity (m/s); and
- z = depth (m).

The total unit weight of subsurface layers computed by Equation 13 is included in Figure 7.

RECOMMENDED MATERIAL PROPERTIES

The following paragraphs describe the recommended values of the material properties for analysis of the perimeter dikes surrounding Ash Pond B. The index and shear strength properties calculated from the laboratory tests and in-situ testing correlations were evaluated to establish the recommended values. Table 7 summarizes the selected parameters for analysis.

Total Unit Weight

Written by: J. McNash Date: 10/10/2016 Reviewed by: C. Carlson/M. Zhu Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No.: 01BT

Figure 7 presents total unit weight values measured as part of CU and 1-D consolidation testing of fly ash as well as total unit weight values interpreted from V_s measurements using Equation 13. Figure 7 indicates that the total unit weight for sandy foundation materials range from 103 to 130 pcf. Values of 125 pcf and 115 pcf are selected for dike fill and sandy foundation soils, respectively. A unit weight of 100 pcf is selected for the clay foundation soils, generally encountered below 5 ft NGVD29, based on properties of soft clays encountered within the vicinity of Ash Pond A (see *2016 Surface Impoundment Periodic Safety Factor Assessment Report: Ash Pond A* within the operating record for details). A unit weight of 100 pcf is selected for fly ash to maintain consistency with other areas of the Site (i.e., Ash Pond A).

Undrained Shear Strength

Based on undrained shear strength ratios estimated from CU testing, a typical S_u/σ'_c value of 1.0 is recommended for the fly ash materials, as shown in Figure 8. However, CPT data, provided in Figure 14, indicates zones of clayey soils are limited and the undrained shear strength ratio varies from area to area. For the safety factor assessment (Attachment 8), CPTs at each cross section evaluated were utilized to select the undrained shear strength for clayey foundation soils.

Drained Shear Strength

In general, estimated drained shear strength parameters exhibited significant variability across the Ash Pond B dike fill and foundation soils as shown in Figures 15 and 16. The effective friction angle was calculated to typically range between 38 degrees and 55 degrees within the dike fill soils and 28 degrees and 36 degrees within the sandy foundation soils. Drained shear strength parameters for these soils were selected on a cross section-by-cross section basis for the safety factor assessment calculation package provided in Attachment 8 of this Safety Factor Assessment Report. Isolated pockets or lenses of clay were observed within the foundation soils. An effective friction angle of 18 degrees with an effective cohesion intercept of 250 psf is selected for these clay layers, based on CU triaxial test results for clay soils collected in the vicinity of Ash Pond A (see *2016 Surface Impoundment Periodic Safety Factor Assessment Report: Ash Pond A* within the operating record for details).

Consolidation Parameters

The following consolidation parameters are recommended for the fly ash based on laboratory testing results. The fly ash is assumed to be normally consolidated ($OCR = 1.0$) since the material has recently been deposited within the impoundment. C_{ce} and C_{re} values of 0.12 and 0.006, respectively, are selected for the fly ash. A C_v value of 6.5 ft²/day is selected for the fly ash. C_{ae} values of 0.1 percent and 0.2 percent are selected for stress ratios less than 1.0 and greater than 1.0, respectively. Selected C_v and C_{ae} values for the fly ash are shown in Figures 12 and 13, respectively. Consolidation

Written by: J. McNash Date: 10/10/2016 Reviewed by: C. Carlson/M. Zhu Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No.: 01BT

parameters for clayey foundation soils shown in Table 7 are based on 1-D consolidation tests conducted on samples collected in the vicinity of Ash Pond A (see *2016 Surface Impoundment Periodic Safety Factor Assessment Report: Ash Pond A* within the operating record for details) since zones of clayey soils were not encountered within soil borings or sampled beneath the Ash Pond B perimeter dikes.

Representative Subsurface Profiles for Site Response Analysis

Shear wave velocity profiles, soil plasticity, and total unit weight are required as input for site response analyses presented in Attachment 6 of the Safety Factor Assessment Report. Therefore, two representative subsurface profiles were developed for sections of the perimeter dike structures based on the height of the perimeter dikes and the properties of the underlying soils. Representative profile 1 represents the 15-ft tall perimeter dike structures adjacent to the Intake and Discharge Canals. Representative profile 2 represents the 20 to 24-ft tall perimeter dikes adjacent to the Cooling Pond. Shear wave velocity profiles were developed from seismic CPT tests performed in 5-ft depth intervals during several CPT soundings and the correlated V_s (by Equation 9) from CPT sounding sleeve friction (f_s). The raw V_s data and interpretation of these tests are provided in Attachment 3 of the Safety Factor Assessment Report. The developed V_s profiles (by elevation) are summarized within Table 8 and provided in Figures 17 and 18 for representative profiles 1 and 2, respectively. Selection of the V_s of the Chicora and Williamsburg Formation Clay strata is discussed in Attachment 6 of the Safety Factor Assessment Report.

REFERENCES

- Doar, W.R. III, Geologic Map of the Georgetown South 7.5-minute Quadrangle, Georgetown County, South Carolina, 2012.
- Federal Highway Administration, "Geotechnical Engineering Circular No.5: Evaluation of soil and Rock Properties", FHWA-IF-02-034, April 2002.
- GRL Engineers, Inc. (GRLE), "Report on: Standard Penetration Test Energy Measurements: Diedrich D-50 Serial #177 and Diedrich Serial 244", prepared for SAEDACCO, Inc. Job No. 139048-1, July 30th, 2013.
- Hatanaka, M. and Uchida, A., "Empirical correlation between penetration resistance and effective friction angle of sandy soil", *Soils & Foundations* 36 (4): 1 – 9, 1996.
- Idriss, I. M., and Boulanger, R. W., "Soil Liquefaction During Earthquakes", Earthquake Engineering Research Institute, EERI Publication MNO-12. 2008.

Written by: J. McNash Date: 10/10/2016 Reviewed by: C. Carlson/M. Zhu Date: 10/10/2016

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No.: **01BT**

Kulhawy, F.H. and Mayne, P.W., “Manual on Estimating Soil Properties for Foundation Design”, EPRI EL-6800, Project 1493-6, August 1990.

Mayne, P.W., “Stress-strain-strength-flow parameters from enhanced in-situ tests”, *Proceedings, International Conference on In-Situ Measurement of Soil Properties & Case Histories*, Bali, Indonesia, May 21-24, 2001, pp. 27-48.

Paul C. Rizzo Associates, Inc., “Report: Geotechnical/Hydrogeologic Investigation: Winyah Generating Station”, July 1999.

Robertson, P.K., and Campanella, R.G., Interpretation of cone penetration tests – Part I (sand). *Canadian Geotechnical Journal*, 20(4): 718-733, 1983.

Robertson, P, K, and Cabal, K. L., “Guide to Cone Penetration Testing for Geotechnical Engineering”, 5th Edition, November 2012.

Soil & Material Engineers, Inc. “Subsurface Investigation, Ash and Slurry Pond Dikes: Winyah Generating Station”, June 1978.

Soil & Material Engineers, Inc. “Report of Geotechnical Exploration: Winyah Generating Station Units 1 & 2 Ammonium Sulfate FGD System”, December 2001.

Written by: **J. McNash** Date: **10/10/2016** Reviewed by: **C. Carlson/M. Zhu** Date: **10/10/2016**

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No.: **01BT**

TABLES

Written by: J. McNash Date: 10/10/2016 Reviewed by: C. Carlson/M. Zhu Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No.: 01BT

Table 1. Recommended SPT Procedure for Liquefaction Evaluations (Idriss and Boulanger, 2008)

Feature	Description
Borehole	Rotary borehole diameter of 4–5 in. with drilling mud for stability; the drilling mud should be kept thick enough, and the hole should always be full. Special care is required when pulling rods out of the hole, to avoid suction.
Drill bit	Upward deflection of drilling mud (e.g., tricone or baffled drag bit)
Sampler	O. D. = 2 in. I. D. = 1.38 in. (constant; i.e., no room for liners in barrel)
Drill rods	A or AW for depths < 50 ft N, BW, or NW for greater depths
Energy delivered to sampler	2,520 in.-lb. (i.e., 60% of theoretical maximum of 140 lbs. falling 30 in.)
Blow count rate	30–40 blows per minute
Penetration resistance count	Measured over a range of 6–18 in. of penetration into the ground

Written by: J. McNash Date: 10/10/2016 Reviewed by: C. Carlson/M. Zhu Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No.: 01BT

Table 2. Summary of Water Level Measurements

Boring ID	Method	Location	Ground Surface El.	Depth to Water (24-hr)	Depth of Dissipation Test	Measured Hydrostatic Pressure	Phreatic Surface Elevation
-	-		ft NGVD29	ft bgs	ft bgs	ft	ft NGVD29
CPT-135	u ₂ Signature	Dike Center	40.5	14.6	-	-	
CPT-136	u ₂ Signature	Dike Center	40.6	15.6	-	-	25.0
CPT-150	Diss. Test	Dike Center	40.9	-	35.5	21.4	26.8
CPT-151	u ₂ Signature	Dike Toe	23.7	2.5			21.2
CPT-152	Diss. Test	Pond Interior	38.7	-	15.4	6.5	29.9
CPT-153	Diss. Test	Pond Interior	40.5	-	14.9	5.6	31.2
CPT-154	u ₂ Signature	Pond Interior	40.1	-	-	-	-
CPT-225	u ₂ Signature	Dike Toe	24.0	1.0	-	-	24.0
CPT-226	u ₂ Signature	Dike Center	37.7	16.0	-	-	21.7
CPT-227	u ₂ Signature	Dike Center	38.0	12.0	-	-	26.0
SPT-114	Borehole Measurement	Dike Center	42.5	19.1	-	-	23.4
SPT-115	Borehole Measurement	Dike Center	40.9	15.0	-	-	25.9
SPT-121	Borehole Measurement	Dike Center	40.8	11.5	-	-	29.3
SPT-122	Borehole Measurement	Pond Interior	41.1	11.5	-	-	29.6
SPT-309	Borehole Measurement	Dike Center	40.5	14.1	-	-	26.4
SPT-310	Borehole Measurement	Dike Center	38.7	9.1	-	-	29.6
WAP-10 ^[4]	MW	Dike Toe	24.3	1.5	-	-	21.9
PPZW-10D ^[4]	Piezometer	Dike Toe	24.1	-1.2	-	-	25.3
WAP-20	MW	Dike Center	-	-	-	-	24.0
WAP-21	MW	Dike Center	-	-	-	-	26.6

Notes:

1. Depth to water levels in mud rotary boreholes may not be representative of existing conditions due to borehole collapse or the influence on drilling mud on measured depth to water levels.
2. Ground surface elevations of SPT-309 and SPT-310 were not surveyed, but estimated based on surface elevations of CPT-135 and CPT-151 respectively.
3. Piezometer water levels were measured on 22 May 2015. Monitoring well water levels were measured on 21 June 2016.
4. WAP-10 is screened from 4 and 24 ft bgs. PPZW-10D is located adjacent to WAP-10 and is screened between 35 and 45 ft bgs.

Written by: J. McNash Date: 10/10/2016 Reviewed by: C. Carlson/M. Zhu Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No.: 01BT

Table 3. CME-550X Energy Ratio Calibration (provided by Soil Consultants, Inc.) for Fall 2013 Investigation
SPT BAINMER EFFICIENCY



Drill Rig: SCI CME 550X
Hammer: Automatic
Rig Operator: Beebow
Engineer: Headerson

Test Date: 4/3/13
Project No.:
Location: SCI Yent
Drilling Method: Mid Rotary

Blow ID: TB-1
Rod Type: BV
Analyzer ID: 2168BV
Rod Area: 1.61 in²

Depth: 40 ft
L.E.: 43 ft
Blow Count: 1, 1, 3

Depth: 45 ft
L.E.: 48 ft
Blow Count: 12, 10, 17

Depth: 50 ft
L.E.: 53 ft
Blow Count: 5, 10, 14

Blow No.	Energy	Blow No.	Energy
1	0.383	26	
2	0.304	27	
3	0.311	28	
4	0.310	29	
5	0.308	30	
6		31	
7		32	
8		33	
9		34	
10		35	
11		36	
12		37	
13		38	
14		39	
15		40	
16		41	
17		42	
18		43	
19		44	
20		45	
21		46	
22		47	
23		48	
24		49	
25		50	

Average Energy: 0.301 ksp-ft
Max. Rated Energy: 0.350 ksp-ft
Efficiency: 87%
Std. Deviation: 0.012 ksp-ft

Blow No.	Energy	Blow No.	Energy
1	0.332	26	0.302
2	0.317	27	0.307
3	0.306	28	0.304
4	0.311	29	0.314
5	0.310	30	0.317
6	0.306	31	0.318
7	0.310	32	0.321
8	0.315	33	0.312
9	0.305	34	0.315
10	0.300	35	0.316
11	0.302	36	0.311
12	0.310	37	0.311
13	0.308	38	0.309
14	0.306	39	0.315
15	0.288	40	
16	0.301	41	
17	0.306	42	
18	0.307	43	
19	0.297	44	
20	0.302	45	
21	0.307	46	
22	0.306	47	
23	0.313	48	
24	0.313	49	
25	0.305	50	

Average Energy: 0.310 ksp-ft
Max. Rated Energy: 0.350 ksp-ft
Efficiency: 88%
Std. Deviation: 0.007 ksp-ft

Blow No.	Energy	Blow No.	Energy
1	0.332	26	0.307
2	0.338	27	0.308
3	0.333	28	0.309
4	0.337	29	0.305
5	0.316	30	
6	0.334	31	
7	0.306	32	
8	0.320	33	
9	0.308	34	
10	0.302	35	
11	0.303	36	
12	0.300	37	
13	0.303	38	
14	0.302	39	
15	0.301	40	
16	0.307	41	
17	0.298	42	
18	0.309	43	
19	0.297	44	
20	0.300	45	
21	0.297	46	
22	0.304	47	
23	0.299	48	
24	0.304	49	
25	0.279	50	

Average Energy: 0.309 ksp-ft
Max. Rated Energy: 0.350 ksp-ft
Efficiency: 88%
Std. Deviation: 0.014 ksp-ft

Average efficiency from all tests: **88%**

Written by: J. McNash Date: 10/10/2016 Reviewed by: C. Carlson/M. Zhu Date: 10/10/2016

Client: Santec Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No.: 01BT

Table 4. CME-45C Energy Ratio Calibration (provided by Mid Atlantic Drilling, Inc.) for Spring 2016 Investigation

Test	LE	LP	Blows			N-Value	BPM	AET (k-ft)	ETR	Soil Classification
			Increment 1 (0-6")	Increment 2 (6-12")	Increment 3 (12-18")					
Test 1	35.5	30.0	7	16	15	31	47.4	0.261	74.6	SC
Test 2	37.5	32.0	10	13	13	26	49.8	0.275	78.6	SP
Test 3	39.5	34.0	4	6	17	23	49.1	0.275	78.4	SP

Fig 5 CME 45C Track Rig (Serial #273964)

LE Length Below Gages BPM Blows Per Minute AET Average Energy Transfer
 LP Length of Penetration ETR Energy Transfer Ratio

- Note:
1. Average values of the three tests result in an ER = 77.2%.

Written by: J. McNash Date: 10/10/2016 Reviewed by: C. Carlson/M. Zhu Date: 10/10/2016
 Client: Santec Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No.: 01BT

**Table 5. CME-45C Energy Ratio Calibration for 2016 Investigation
 (Provided by Bridger Drilling Enterprises, Inc. (Carolina Drilling))**



ECS Carolinas, LLP
 6714 Netherlands Drive
 Wilmington, North Carolina 28405

Drill Company: Bridger Drilling Enterprises, Inc.
 Drill Rig: CME45C Trailer Rig (Serial #282974)
 Operator: Gerald Estler
 Test Date: 5/32/2015

Drill Method: Mud Rotary
 Rod Serial #: 289 AWJ - 1
 Project No. 22-22841

SPT ENERGY TESTING

30 feet			
Depth	Blow Count:	4-5-8	N = 13
Blow No.	EFV (k-ft)	ETR (%)	
1	0.263	75.3	
2	0.262	74.9	
3	0.263	75.1	
4	0.270	77.2	
5	0.265	75.6	
6	0.268	76.5	
7	0.266	76.0	
8	0.265	75.8	
9	0.264	75.5	
10	0.267	76.3	
11	0.264	75.3	
12	0.264	75.3	
13	0.268	76.5	
14	0.261	74.6	
15	0.271	77.5	
16	0.262	74.8	
17	0.267	76.2	

35 feet			
Depth	Blow Count:	5-5-7	N = 17
Blow No.	EFV (k-ft)	ETR (%)	
1	0.271	77.6	
2	0.278	79.4	
3	0.277	79.2	
4	0.278	79.3	
5	0.283	80.7	
6	0.280	80.0	
7	0.279	79.6	
8	0.281	80.1	
9	0.281	80.3	
10	0.280	79.9	
11	0.283	80.8	
12	0.280	79.9	
13	0.280	80.0	
14	0.285	81.4	
15	0.282	80.5	
16	0.284	81.0	
17	0.281	80.4	

40 feet			
Depth	Blow Count:	5-9-10	N = 17
Blow No.	EFV (k-ft)	ETR (%)	
1	0.289	82.6	
2	0.292	83.4	
3	0.284	81.1	
4	0.287	81.9	
5	0.284	81.0	
6	0.284	81.2	
7	0.285	81.5	
8	0.284	81.2	
9	0.282	80.6	
10	0.284	81.2	
11	0.288	82.3	
12	0.288	82.3	
13	0.288	82.2	
14	0.287	82.1	
15	0.286	81.6	
16	0.288	82.4	
17	0.286	81.8	
18	0.292	83.5	
19	0.288	82.4	
20	0.286	81.7	
21	0.288	82.2	
22	0.288	82.2	
23	0.288	82.4	
24	0.291	83.2	

Average Standard Deviation Maximum	0.265 0.003 0.271	75.6 0.6 77.5	0.28 0.003 0.285	80 0.9 81.4	Average Standard Deviation Maximum	0.287 0.003 0.292	82 0.8 83.5
------------------------------------	-------------------------	---------------------	------------------------	-------------------	------------------------------------	-------------------------	-------------------

Average Hammer Efficiency: 79.3 %

EFV is method for determining energy ETR is energy transfer ratio
 The maximum rated energy of 0.350 k-ft is based on an assumed hammer weight of 0.14 kips and assumed drop height of 2.5 feet

Written by: J. McNash Date: 10/10/2016 Reviewed by: C. Carlson/M. Zhu Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No.: 01BT

Table 6. Standard N-value Correction Factors for Drilling Methods

Factor	Description										
Energy ratio	<p>Energy measurements are required to determine the delivered energy ratios or to calibrate the specific equipment being used. The correction factor is then computed as</p> $C_E = \frac{ER_m}{60}$ <p>where ER_m is the measured energy ratio as a percentage of the theoretical maximum.</p> <p>Empirical estimates of C_E (for rod lengths of 10 m or more) involve considerable uncertainty, as reflected by the following ranges:</p> <table> <tr> <td>Doughnut hammer</td> <td>$C_E = 0.5-1.0$</td> </tr> <tr> <td>Safety hammer</td> <td>$C_E = 0.7-1.2$</td> </tr> <tr> <td>Automatic triphammer</td> <td>$C_E = 0.8-1.3$</td> </tr> </table> <p>(Seed et al. 1984, Skempton 1986, NCEER 1997)</p>	Doughnut hammer	$C_E = 0.5-1.0$	Safety hammer	$C_E = 0.7-1.2$	Automatic triphammer	$C_E = 0.8-1.3$				
Doughnut hammer	$C_E = 0.5-1.0$										
Safety hammer	$C_E = 0.7-1.2$										
Automatic triphammer	$C_E = 0.8-1.3$										
Borehole diameter	<table> <tr> <td>Borehole diameter of 65–115 mm</td> <td>$C_B = 1.0$</td> </tr> <tr> <td>Borehole diameter of 150 mm</td> <td>$C_B = 1.05$</td> </tr> <tr> <td>Borehole diameter of 200 mm</td> <td>$C_B = 1.15$</td> </tr> </table> <p>(Skempton 1986)</p>	Borehole diameter of 65–115 mm	$C_B = 1.0$	Borehole diameter of 150 mm	$C_B = 1.05$	Borehole diameter of 200 mm	$C_B = 1.15$				
Borehole diameter of 65–115 mm	$C_B = 1.0$										
Borehole diameter of 150 mm	$C_B = 1.05$										
Borehole diameter of 200 mm	$C_B = 1.15$										
Rod length	<p>Where the ER_m is based on rod lengths of 10 m or more, the ER delivered with shorter rod lengths may be smaller. Recommended values from Youd et al. (2001) are as follows:</p> <table> <tr> <td>Rod length < 3 m</td> <td>$C_R = 0.75$</td> </tr> <tr> <td>Rod length 3–4 m</td> <td>$C_R = 0.80$</td> </tr> <tr> <td>Rod length 4–6 m</td> <td>$C_R = 0.85$</td> </tr> <tr> <td>Rod length 6–10 m</td> <td>$C_R = 0.95$</td> </tr> <tr> <td>Rod length 10–30 m</td> <td>$C_R = 1.00$</td> </tr> </table>	Rod length < 3 m	$C_R = 0.75$	Rod length 3–4 m	$C_R = 0.80$	Rod length 4–6 m	$C_R = 0.85$	Rod length 6–10 m	$C_R = 0.95$	Rod length 10–30 m	$C_R = 1.00$
Rod length < 3 m	$C_R = 0.75$										
Rod length 3–4 m	$C_R = 0.80$										
Rod length 4–6 m	$C_R = 0.85$										
Rod length 6–10 m	$C_R = 0.95$										
Rod length 10–30 m	$C_R = 1.00$										
Sampler	<p>Standard split spoon without room for liners (the inside diameter is a constant 1³/₈ in.), $C_S = 1.0$.</p> <p>Split-spoon sampler with room for liners but with the liners absent (this increases the inside diameter to 1¹/₂ in. behind the driving shoe):</p> $C_S = 1.1 \quad \text{for} \quad (N_1)_{60} \leq 10$ $C_S = 1 + \frac{(N_1)_{60}}{100} \quad \text{for} \quad 10 \leq (N_1)_{60} \leq 30$ $C_S = 1.3 \quad \text{for} \quad (N_1)_{60} \geq 30$ <p>(from Seed et al. 1984, equation by Seed et al. 2001)</p>										

Written by: J. McNash Date: 10/10/2016 Reviewed by: C. Carlson/M. Zhu Date: 10/10/2016

Client: Santec Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No.: 01BT

Table 7. Selected Material Parameters for Analysis

Material	Total Unit Weight (pcf)	Drained Parameters			Undrained Parameters		Consolidation Parameters ^[1]				
		ϕ' (°)	c' (psf)	S_u/σ'_v	$S_{u, min}$ (psf)	C_{cc}	C_{re}	C_{ac} (%)	C_v (ft ² /day)	OCR	
Dike Fill Material	125	Varies	0	-	-	-	-	-	-	-	
Foundation Soils (Clayey) ^[2]	100	18	250	Varies	-	0.32	0.06	2.0	0.01	1.0	
Foundation Soils (Sandy)	115	Varies	0	-	-	-	-	-	-	-	
Chicora	130	50	0	-	-	-	-	-	-	-	
Williamsburg Formation Clay ^[3]	105	50	0	-	-	-	-	-	-	-	
Fly Ash	100	34	0	1.0 ^[2]	-	0.12	0.006	0.2	6.5	1.0	

Notes:

1. C_v and C_{ac} values are provided assuming soils are normally consolidated in-situ and additional loading would yield a stress ratio greater than 1.0 (i.e., $\sigma'_v / \sigma'_p > 1.0$).
2. Parameters for clayey foundation soils were selected based on laboratory testing of samples collected within Ash Pond A (see 2016 Surface Impoundment Periodic Safety Factor Assessment Report: Ash Pond A within the operating record for details).
3. Strength parameters for the Williamsburg Formation Clay are based on direct shear testing performed from cored samples provided by S&ME (2001). The Williamsburg Formation Clay is typically 50 ft bgs, and critical slip surfaces during slope stability analyses are not anticipated to pass through this zone based on the perimeter dike heights. Measured blow counts (N-values) within this material ranged from 30 to 100 blows per foot and were typically in excess of 50 blows per foot.

Written by: **J. McNash** Date: **10/10/2016** Reviewed by: **C. Carlson/M. Zhu** Date: **10/10/2016**

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No.: **01BT**

Table 8. Summary of Representative Shear Wave Velocity Profiles

Profile 1 (Dike Centerline)		Profile 2 (Dike Centerline)	
Elev. (ft)	V _s (ft/s)	Elev. (ft)	V _s (ft/s)
-60 to -5	1500+	-60 to -5	1500+
-5 to 25	700	-5 to 20	600
25 to 35	1000	20 to 35	1000
35 to 42	550	35 to 42	550

Notes:

1. Elevations are provided in ft NGVD29.
2. Shear wave velocities at elevations below -10 ft NGVD29 are discussed in Attachment 6.
3. Representative profile 1 corresponds to the perimeter dikes adjacent to the Discharge Canal while representative profile 2 corresponds to the perimeter dikes adjacent to the Cooling Pond.

Written by: **J. McNash** Date: **10/10/2016** Reviewed by: **C. Carlson/M. Zhu** Date: **10/10/2016**

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No.: **01BT**

FIGURES




- LEGEND**
- GAS
 - GAS
 - 30
 - EXISTING MAJOR GRADE CONTOUR
 - EXISTING RAILROAD
 - EXISTING WATER
 - EXISTING STAFF GAUGE
 - GEOSYNTEC CONE PENETRATION TEST
 - GEOSYNTEC SOIL BORING
 - HISTORICAL BORING
 - GROUNDWATER MONITORING WELL
 - PIEZOMETER

- W-SW-APB
- CPT-144
- SPT-111
- B-1
- W165-9
- PPZ-S, PPZ-W80

NOTES:

1. TOPOGRAPHIC SURVEY PROVIDED BY THOMAS & HUTTON DATED 06/26/11 AND REVISED ON 01/14/12.
2. ELEVATIONS FROM THIS SURVEY ARE REFERENCED TO NSVD 1929 DATUM AS DERIVED FROM NGS MONUMENT PIDRD11957.
3. THE POSITION OF UNDERGROUND UTILITIES SHOWN ON THIS DRAWING IS BASED UPON THE LOCATION OF SURFACE APERTURES AND/OR SURFACE MARKINGS AND SHOULD BE CONSIDERED APPROXIMATE.



BORING LOCATION MAP - ASH POND B


Creosyntec
consultants

PROJECT NO. GSC5242 OCTOBER 2018

FIGURE
1

Written by: J. McNash Date: 10/10/2016 Reviewed by: C. Carlson/M. Zhu Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No.: 01BT



Zone	Soil Behavior Type	I_c
1	Sensitive, fine grained	N/A
2	Organic soils – clay	> 3.6
3	Clays – silty clay to clay	2.95 – 3.6
4	Silt mixtures – clayey silt to silty clay	2.60 – 2.95
5	Sand mixtures – silty sand to sandy silt	2.05 – 2.6
6	Sands – clean sand to silty sand	1.31 – 2.05
7	Gravelly sand to dense sand	< 1.31
8	Very stiff sand to clayey sand*	N/A
9	Very stiff, fine grained*	N/A

* Heavily overconsolidated or cemented

Figure 2. SBT_N Chart with typical I_c Ranges used in CPT Interpretation (Robertson and Cabal, 2012)

Written by: J. McNash Date: 10/10/2016 Reviewed by: C. Carlson/M. Zhu Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No.: 01BT




Figure 3. Example I_c Classification Profile for CPT-135

Notes:

1. I_c – Soil Behavior Index by Robertson and Cabal (2012).
2. Thick black lines represent transitions between soil types shown in Figure 2.

Written by: J. McNash Date: 10/10/2016 Reviewed by: C. Carlson/M. Zhu Date: 10/10/2016

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No.: **01BT**




Figure 4. Grain Size Distribution Test Results

Note:

1. Samples of Williamsburg Formation Clay were observed below Elevation -20.0 ft NGVD29.

Written by: J. McNash Date: 10/10/2016 Reviewed by: C. Carlson/M. Zhu Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No.: 01BT




Figure 6. Natural Moisture Content Test Results

Note:

1. Samples of Williamsburg Formation Clay were observed below Elevation -20.0 ft NGVD29.

Written by: J. McNash Date: 10/10/2016 Reviewed by: C. Carlson/M. Zhu Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No.: 01BT




Figure 7. Total Unit Weight from CU and 1-D Consolidation Tests

Notes:

1. The total unit weight measurements from triaxial tests are plotted for tests performed on samples of fly ash from SPT-122. Shear wave velocity measurements (V_s) were used to supplement laboratory data using the correlation provided by Equation 13 for CPT-135, CPT-137, CPT-147, and CPT-150.
2. It is noted that CPT-137 and CPT-147 are located in the Ash Pond A area immediately north of the divider dike, but were considered representative due to their proximity to the Ash Pond B perimeter dikes. Details of these two CPT soundings can be found in *2016 Surface Impoundment Periodic Safety Factor Assessment Report: Ash Pond A*, which is provided within the operating record.
3. Unit weight of sandy foundation soils was found to range between 103 pcf and 121 pcf. A unit weight value of 115 pcf was selected.
4. Unit weight of fly ash was selected to be 100 pcf in order to be consistent with the unit weight selected for fly ash located within Ash Pond A.

Written by: J. McNash Date: 10/10/2016 Reviewed by: C. Carlson/M. Zhu Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No.: 01BT




Figure 8. Undrained Shear Strength Ratio from CU Triaxial Tests on Fly Ash

Note:

1. In SPT-122, Samples of fly ash were collected from 12 to 14 ft bgs and 18 to 20 ft bgs.

Written by: J. McNash Date: 10/10/2016 Reviewed by: C. Carlson/M. Zhu Date: 10/10/2016

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No.: **01BT**




Figure 9. Mohr's Circles for Fly Ash

Note:

1. In SPT-122, Samples of fly ash were collected from 12 to 14 ft bgs and 18 to 20 ft bgs.

Written by: J. McNash Date: 10/10/2016 Reviewed by: C. Carlson/M. Zhu Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No.: 01BT




Figure 10. Failure Envelope from CU Triaxial Testing for Fly Ash

Note:

1. In SPT-122, Samples of fly ash were collected from 12 to 14 ft bgs and 18 to 20 ft bgs.

Written by: J. McNash Date: 10/10/2016 Reviewed by: C. Carlson/M. Zhu Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No.: 01BT




Figure 11. Load-Strain Curve for Fly Ash in Ash Pond B

Note:

1. SPT-122 ST-01 was collected from 12 to 14 ft bgs.

Written by: J. McNash Date: 10/10/2016 Reviewed by: C. Carlson/M. Zhu Date: 10/10/2016

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No.: **01BT**




Figure 12. Evaluation of the Coefficient of Consolidation (C_v) for Fly Ash

Note:

1. SPT-122 ST-01 was collected from 12 to 14 ft bgs.

Written by: J. McNash Date: 10/10/2016 Reviewed by: C. Carlson/M. Zhu Date: 10/10/2016

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No.: **01BT**




Figure 13. Evaluation of the Coefficient of Secondary Compression ($C_{\alpha\epsilon}$) for Fly Ash

Note:

1. SPT-122 ST-01 was collected from 12 to 14 ft bgs.

Written by: J. McNash Date: 10/10/2016 Reviewed by: C. Carlson/M. Zhu Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No.: 01BT




Figure 14. Undrained Shear Strength Ratio from CPT Sounding Correlation

Note:

1. Undrained shear strength is computed by Robertson and Cabal (2012) for “clay-like” ($I_c < 2.60$) soils. Soils classifying as “sand-like” were plotted with a zero value.

Written by: J. McNash Date: 10/10/2016 Reviewed by: C. Carlson/M. Zhu Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No.: 01BT




Figure 15. Effective Stress Friction Angle from SPT Correlation

Note:

1. Effective stress friction angle is computed by Hatanaka and Uchida (1996) for sands ($I_c < 2.60$).

Written by: J. McNash Date: 10/10/2016 Reviewed by: C. Carlson/M. Zhu Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No.: 01BT




Figure 16. Effective Stress Friction Angle from CPT Correlation

Note:

1. Effective stress friction angle is computed by Robertson and Campanella (1983) for sands ($I_c < 2.60$).

Written by: J. McNash Date: 10/10/2016 Reviewed by: C. Carlson/M. Zhu Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No.: 01BT




Figure 17. Representative Shear Wave Velocity Profile 1 (for dikes adjacent to Intake and Discharge Canals)

Notes:

1. sCPT refers to a seismic CPT where V_s measurements are collected in 5 ft depth intervals.
2. Representative profile is provided for the subsurface in the upper 100 ft bgs.
3. The upper 5 ft of dike fill soils were modeled with a $V_s = 550$ ft/s.
4. Note that the development of shear wave velocity profiles and site response analyses were performed prior to the 2016 site investigation and are not included within this figure.

Written by: J. McNash Date: 10/10/2016 Reviewed by: C. Carlson/M. Zhu Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No.: 01BT




Figure 18. Representative Shear Wave Velocity Profile 2 (for dikes adjacent to the Cooling Pond)

Notes:

1. sCPT refers to a seismic CPT where V_s measurements are collected in 5 ft depth intervals.
2. Representative profile is provided for the subsurface in the upper 100 ft bgs.
3. The upper 5 ft of dike fill soils were modeled with a $V_s = 550$ ft/s.
4. Note that the development of shear wave velocity profiles and site response analyses were performed prior to the 2016 site investigation and are not included within this figure.

Written by: **J. McNash** Date: **10/10/2016** Reviewed by: **C. Carlson/M. Zhu** Date: **10/10/2016**

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No.: **01BT**

Appendix 1

Summary of Laboratory Testing Results

Written by: J. McNash Date: 10/10/2016 Reviewed by: C. Carlson/M. Zhu Date: 10/10/2016

Client: Santec Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No.: 01BT

Table 1-1. Summary of Index Testing

Boring ID	Sample ID	Depth	Elev.	Natural Moisture Content	Liquid Limit	Plastic Limit	Plasticity Index	Gravel	Sand	Silt	Clay	Fines Content	Specific Gravity	pH
Units	-	ft bgs	ft	%	%	%	%	%	%	%	%	%	-	-
SPT-114	SS-1	5.75	35.73	15.8	NP	NP	NP	0.3	72.8	7.4	19.5	26.9	-	-
SPT-114	SS-5	25.75	15.73	23.2	-	-	-	-	-	-	-	9.2	-	-
SPT-114	SS-7	35.75	5.73	25.7	-	-	-	-	-	-	-	7.0	-	-
SPT-114	ST-1	37.50	3.98	18.9	-	-	-	-	-	-	-	#N/A	-	-
SPT-114	SS-8	40.75	0.73	26.6	-	-	-	0.4	85.5	-	-	14.1	-	-
SPT-114	SS-10	50.75	-9.27	20.5	-	-	-	5.5	80.6	-	-	13.9	-	-
SPT-114	SS-11	55.75	-14.27	26.7	-	-	-	-	-	-	-	14.7	-	-
SPT-115	SS-02	10.75	30.15	7.6	-	-	-	-	-	-	-	8.2	-	-
SPT-115	SS-7	35.75	5.15	27.6	-	-	-	0.0	89.8	-	-	10.2	-	-
SPT-115	SS-9	46.25	-5.35	26.1	61	24	37	11.5	71.5	-	-	17.0	-	-
SPT-115	SS-12	60.75	-19.85	16.0	-	-	-	23.8	58.3	-	-	17.9	-	-
SPT-115	SS-13	65.75	-24.85	15.0	-	-	-	-	-	-	-	18.3	-	-
SPT-121	SS-2	10.75	30.07	14.8	-	-	-	-	-	-	-	10.7	-	-
SPT-121	SS-6	30.75	10.07	27.8	-	-	-	0.0	92.6	-	-	7.4	-	-
SPT-121	SS-7	35.75	5.07	36.0	-	-	-	-	-	-	-	14.3	-	-
SPT-121	SS-8	40.75	0.07	17.3	-	-	-	11.0	73.7	-	-	15.3	-	-
SPT-121	SS-9	45.75	-4.93	31.1	-	-	-	-	-	-	-	14.5	-	-
SPT-122 ⁽¹⁾	ST-1	13.00	28.11	69.3	NP	NP	NP	0.0	26.3	54.6	26.3	73.7	2.243	5.8
SPT-122	ST-3	19.00	22.11	-	NP	NP	NP	0.0	1.0	79.4	19.6	99.0	-	-
SPT-307	30-32	31.00	7.07	29	-	-	-	-	-	-	-	2.8	-	-
SPT-307	38-40	39.00	-0.93	23	NP	NP	NP	-	-	-	-	3.7	-	-
SPT-307	40-42	41.00	-2.93	26	-	-	-	-	-	-	-	6.4	-	-
SPT-308	20-22	21.00	14.29	25	NP	NP	NP	-	-	-	-	2.1	-	-
SPT-308	30-32	31.00	4.29	76	63	21	42	-	-	-	-	61.9	-	-
SPT-308	32-34	33.00	2.29	76	98	31	67	0.0	12.0	22.7	65.3	88.0	-	-
SPT-308	36-38	37.00	-1.71	30	28	16	12	-	-	-	-	11.8	-	-
SPT-309	S-5	9.00	31.47	17.6	-	-	-	0.0	78.5	-	-	21.5	-	-

Written by: J. McNash Date: 10/10/2016 Reviewed by: C. Carlson/M. Zhu Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No.: 01BT

Boring ID	Sample ID	Depth	Elev.	Natural Moisture Content	Liquid Limit	Plastic Limit	Plasticity Index	Gravel	Sand	Silt	Clay	Fines Content	Specific Gravity	pH
Units		ft bgs	ft	%	%	%	%	%	%	%	%	%	-	-
SPT-309	S-9	17.00	23.47	22.0	-	-	-	-	-	-	-	9.6	-	-
SPT-309	S-12	29.25	11.22	31.6	-	-	-	-	-	-	-	7.3	-	-
SPT-309	S-13	34.25	6.22	30.7	-	-	-	0.1	88.0	-	-	11.9	-	-
SPT-309	S-15	44.25	-3.78	27.5	-	-	-	-	-	-	-	11.1	-	-
SPT-309	S-17	54.25	-13.78	29.8	-	-	-	-	-	-	-	29.5	-	-
SPT-310	S-6	11.00	27.73	23.5	-	-	-	-	-	-	-	22.8	-	-
SPT-310	S-9	17.00	21.73	21.7	-	-	-	-	-	-	-	10.5	-	-
SPT-310	S-12	29.25	9.48	33.7	-	-	-	0.0	94.7	-	-	5.3	-	-
SPT-310	S-13	34.25	4.48	34.4	-	-	-	-	-	-	-	12.7	-	-
SPT-310	S-14	39.25	-0.52	27.2	-	-	-	-	-	-	-	6.3	-	-

Notes:

1. Carbonate content was measured in accordance with ASTM D4373. The carbonate content was measured as 0% in the samples tested.
2. Elevations are in ft NGVD29.
3. Surface elevations of borings SPT-309 and SPT-310 were not surveyed but approximated using adjacent soundings as 40.47 ft NGVD29 (CPT-135) and 38.8 ft NGVD29 (CPT-151), respectively.

Written by: J. McNash Date: 10/10/2016 Reviewed by: C. Carlson/M. Zhu Date: 10/10/2016

Client: Santec Cooper Project: Winyah Generating Station Project/Proposal No.: GSC5242 Task No.: 01BT

Table 1-2. Summary of Triaxial Testing Results (from Geosyntec's investigation)

Boring ID	Depth	Elevation	Moisture Content	Dry Unit Weight	Wet Unit Weight	σ_{consol}'	$\sigma_{1,f}'$	$\sigma_{3,f}'$	S_u	S_u / σ_c'
Units	ft bgs	ft	%	pcf	pcf	psi	psi	psi	psi	-
SPT-122	13.0	28.1	76.8	54.2	95.8	6.5	84.2	23.0	30.6	4.71
SPT-122	13.0	28.1	64.1	60.7	99.6	15.0	49.5	12.7	18.4	1.23
SPT-122	13.0	28.1	53.1	53.1	81.3	20.0	69.4	19.8	24.8	1.24
SPT-122	19.0	22.1	49.9	65.0	97.4	6.0	46.7	13.1	16.8	2.80
SPT-122	19.0	22.1	62.7	60.1	97.8	17.0	58.6	16.3	21.2	1.24

Notes:

1. Unit weight information selected from triaxial test laboratory results.
2. Elevations are provided in ft NGVD29.

ATTACHMENT 6

Seismic Hazard Evaluation and Site Response Analysis

CALCULATION PACKAGE COVER SHEET


Client: Santee Cooper **Project:** Winyah Generating Station **Project No.** GSC5242

TITLE OF PACKAGE: SEISMIC HAZARD EVALUATION AND SITE RESPONSE ANALYSIS: ASH POND B


Calculation Prepared by:

	Signature 	10/12/2016
	Name Clinton Carlson, Ph.D.	Date


Assumptions & Procedures Checked by:
(peer reviewer)

	Signature 	10/12/2016
	Name Glenn J. Rix, P.E., Ph.D.	Date


Computations Checked by:

	Signature 	10/12/2016
	Name Wassim Tabet, Ph.D.	Date

Computations Back-checked by:

	Signature 	10/12/2016
	Name Clinton Carlson, Ph.D.	Date

Approved by:
(pm or designate)

	Signature 	10/12/2016
	Name Fabian Benavente, P.E.	Date

Approval notes: _____

Revisions (number and initial all revisions)

No.	Sheet	Date	By	Checked by	Approval

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT

SEISMIC HAZARD EVALUATION AND SITE RESPONSE ANALYSIS: ASH POND B

PURPOSE

The purpose of this calculation package is to present the results of the seismic hazard evaluation and site response analyses performed for Ash Pond B at the Winyah Generating Station (WGS or “Site”). This calculation package is provided as Attachment 6 to the *2016 Surface Impoundment Periodic Safety Factor Assessment Report* (Safety Factor Assessment Report). Seismic hazard analysis for the Site includes the selection of an appropriate hazard level and associated hazard parameters. Based on the selected hazard level and associated hazard parameters, site response analyses were performed to evaluate the local site effects on the selected time history records propagated from the hypothetical firm ground outcrop to the ground surface of the Site. The objective of this site response analysis is to calculate accelerations and shear stresses within the representative soil profiles of the Ash Pond B perimeter dikes. Cyclic shear stresses will be examined to evaluate liquefaction potential for dike fill and foundation soils and to calculate the seismic coefficient for seismic slope stability analyses presented in Attachments 7 and 8 of the Safety Factor Assessment Report, respectively.

SEISMIC HAZARD EVALUATION

Seismic hazard analysis for the Site includes the selection of: (i) appropriate hazard level; and (ii) associated hazard parameters. The appropriate hazard level is often expressed in probabilistic terms as a specific hazard level that has a certain probability of exceedance in a given time period. Selecting the hazard parameters includes developing an understanding of the seismic sources, ground motion attenuation, and site response. The goals of this section are to: (i) develop the target response spectrum, including the peak ground acceleration (PGA), at a hypothetical firm ground outcrop at WGS corresponding to the appropriate seismic hazard level; (ii) select the earthquake magnitude that contributes predominantly to the seismic hazard at WGS; and (iii) select a set of ground motion time histories that envelope the target spectrum, and are generally consistent with the source and path characteristics of ground motions at WGS.

Seismic Hazard Level

On 17 April 2015, the United States Environmental Protection Agency (USEPA) published the CCR Rule (40 Code of Federal Regulations [CFR] Parts 257 and 261). §257.63(a) of the CCR Rule states that:

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No: **01BT**

“New CCR landfills, existing and new CCR surface impoundments, and all lateral expansions of CCR units must not be located in seismic impact zones, unless the owner or operator demonstrates by the dates specified in paragraph (c) of this section that all structural components including liners, leachate collection and removal systems, and surface water control systems, are designed to resist the maximum horizontal acceleration in lithified earth material for the site.”

§257.53 of the CCR Rule defines the maximum horizontal acceleration in lithified earth material as:

“... the maximum expected horizontal acceleration at the ground surface as depicted on a seismic hazard map, with a 98 percent or greater probability that the acceleration will not be exceeded in 50 years, or the maximum expected horizontal acceleration based on a site-specific seismic risk assessment.”

As the purpose of the Safety Factor Assessment Report is to demonstrate compliance of the existing CCR surface impoundments at WGS with the structural integrity criteria provided in §257.73, the seismic factor of safety must also exceed 1.0 considering *“the peak ground acceleration for a seismic event with a 2% probability of exceedance in 50 years, equivalent to a return period of approximately 2,500 years, based on the U.S. Geological Survey (USGS) seismic hazard maps”*.

Therefore, the analysis performed herein is based on design parameters consistent with a 98 percent probability that the PGA will not be exceeded in 50 years. This hazard level results in seismic design parameters consistent with a 2 percent probability that the PGA will be exceeded in 50 years. This selected hazard level has a return period of 2,475 years, which is commonly referred to as a 2,500-year event.

Peak Ground Acceleration (PGA)

PGA values corresponding to different hazard levels and different site conditions, including firm ground outcrops, are published as seismic hazard maps. While USGS national seismic hazard maps are the most commonly used resources for the selection of PGA, regional seismic hazard maps developed by local experts consider regional geologic setting and seismicity and are often the preferred alternatives.

USGS national seismic hazard maps for a 2 percent probability of exceedance in 50 year ground motion (i.e., 2,475-year return period event) provide the PGA and spectral accelerations for a hypothetical firm ground outcrop at the Site. The software available at the USGS website (USGS, 2008) uses pre-calculated hazard values at nearby grid locations and interpolates the hazard value for a given site location. As presented in Appendix 1, the USGS interpolated PGA is 0.469g for the Site.

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT

The South Carolina Department of Transportation (SCDOT) Geotechnical Design Manual (SCDOT, 2010) presents seismic hazard maps with PGAs for “geologically realistic” site conditions, as well as for the hypothetical “hard-rock” basement outcrop conditions for locations throughout SC. The SCDOT seismic hazard maps were developed by Chapman and Talwani (2006) to incorporate their local experience and research over several decades for the Charleston Seismic Zone. The “geologically realistic” site condition is a hypothetical site condition that was included via a depth-dependent transfer (i.e., site amplification) function for Coastal Plain and non-Coastal Plain regions of SC. The Coastal Plain “geologically realistic” site condition was modeled with two layers: (i) the shallowest layer consisting of Coastal Plain sedimentary soils ($\gamma = 125$ pcf, shear wave velocity, $V_s = 2,300$ ft/s); and (ii) weathered rock ($\gamma = 155$ pcf, $V_s = 8,200$ ft/s) over a half-space of unweathered Mesozoic and Paleozoic sedimentary and Metamorphic/Igneous rock ($\gamma = 165$ pcf, $V_s = 11,200$ ft/s). Conversely, the USGS national seismic hazard maps were developed using a generic site amplification function that does not account for the soil conditions in the Coastal Plain of SC as well as the SCDOT maps.

The SCDOT (2010) seismic hazard maps for a probability of exceedance of 2 percent in 50 years for the “geologically realistic” and “hard rock” conditions are presented in Appendix 1. The PGA seismic hazard map for the “geologically realistic” condition is also presented in Figure 1. The Site PGA is about 0.16g and 0.21g for “geologically realistic” and “hard rock” conditions, respectively. A site response analysis can be performed either by: (i) using the hard rock acceleration as the hypothetical outcrop acceleration and modeling the soil/rock column extending to the rock layer with a $V_s = 11,200$ ft/s; or (ii) using the “geologically realistic” acceleration as the hypothetical outcrop acceleration and modeling the soil column extending to the firm ground layer with $V_s = 2,300$ ft/s. The latter approach will be used for this project because it is less practical to extend the site response model to reach a hard rock outcrop with $V_s = 11,000$ ft/s at reasonable depths in the SC Coastal Plain region.

SCDOT hazard maps for “geologically realistic” conditions were used to select the PGA for the hypothetical firm ground outcrop at WGS when evaluating the seismic response of existing CCR surface impoundments. While the approach used for developing the SCDOT maps and USGS maps is the same (i.e., a probabilistic seismic hazard analysis), the following key features are noted by Chapman and Talwani (2006) with regards to their study: (i) inclusion of alternative source configurations for earthquakes in the magnitude range from 5.0 to 7.0; (ii) use of alternative source models for larger, characteristic-type earthquakes with magnitudes 7.0 to 7.5 in the coastal areas of SC; (iii) use of a maximum magnitude for characteristic earthquakes in the coastal areas; and (iv) more accurate representation of actual geologic conditions in SC. A PGA value of 0.16g is selected at the Site using the hazard maps for “geologically realistic” hypothetical firm ground outcrop conditions.

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT

Earthquake Magnitude

In a probabilistic seismic hazard analysis, the PGA cannot be associated with a single earthquake event due to the hazard contribution from multiple possible events. An earthquake moment magnitude (M_w) value is required to conduct liquefaction potential analyses and to select earthquake time histories. A process called deaggregation can be performed for sites that have multiple hazard sources using the USGS (2002) deaggregation tool.

Figure 2 presents the deaggregation for the PGA near Georgetown, South Carolina. A 7.3 moment magnitude earthquake event at a source-to-site distance of approximately 70 km appears to be the main event contributing to the hazard at the site. Thus, a 7.3 moment magnitude was selected for liquefaction potential analyses and time history selection for WGS.

Target Acceleration Response Spectra

The target spectrum for a “geologically realistic” site was selected using the SCDOT seismic hazard maps for different spectral periods (or frequencies) as presented in Appendix 2. This spectrum is presented in Figure 3. The “geologically realistic” target acceleration response spectrum has a PGA (represented by a spectral period of 0.01 seconds) of 0.16g and a peak spectral acceleration of 0.48g at a spectral period of 0.2 seconds. As stated previously, the “geologically realistic” condition target acceleration response spectrum was selected for WGS.

Time Histories

Time histories of ground motions are used as input for site response analysis and are selected such that their response spectra match or envelope the target spectrum. While use of recorded ground motion time histories from earthquakes with similar source characteristics is preferred, synthetic motions may be used if recordings are not available for a particular seismic zone. Earthquake events with a moment magnitude, M_w , 7.0 or greater have not occurred in the stable continental tectonic environment of the Central and Eastern United States since the Charleston earthquake in 1886, so ground motion time history records matching the seismic source characteristics for the WGS are generally not available. Two synthetic acceleration time histories were selected from the six synthetic acceleration time histories developed for the Site using the USGS Interactive Deaggregation tool (USGS, 2002). These time histories are referred to herein as Winyah1 and Winyah2, and provide a reasonable match to the short-period portion of the “geologically realistic” target acceleration response spectrum. Three time histories, BOS-T1, DEL090, and YER360, developed by McGuire et al. (2001) as part of a study for the Nuclear Regulatory Commission to provide time histories representative of expected earthquake events in the Central and Eastern United States were selected to provide a reasonable match with the long-period portion of the

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No: **01BT**

“geologically realistic” target acceleration response spectrum. One time history, RSN8529-HNE, from the Next Generation Attenuation – East (NGA East) database (Goulet et al., 2014), which provides a database of time histories recorded for earthquake events in the Central and Eastern United States, was selected to also provide a reasonable match with the “geologically realistic” target acceleration response spectrum for longer periods. As shown in Figure 4, this suite of six time histories provides a reasonable envelope of the “geologically realistic” target spectrum for the Site over a broad range of periods. Time histories were scaled in the site response evaluation computer program to match the target PGA of 0.16g. These scaled acceleration time histories are presented in Appendix 3. Additional details of the time histories are presented in Table 1.

SITE RESPONSE ANALYSIS

Site response analyses were performed to evaluate the effect of local site conditions on the expected ground motions at the Site. The objective of the site response analysis is to calculate accelerations and shear stresses within the Site soil profiles. Shear stresses are examined to evaluate the liquefaction potential analysis (Attachment 7 of the Safety Factor Assessment Report) and seismic stability analysis (Attachment 8 of the Safety Factor Assessment Report).

Methodology for Site Response Analysis

Site response analyses presented herein were conducted using DEEPSOIL[®] (Hashash et al., 2015), a one-dimensional, nonlinear site response analysis program. The program assumes that all the soil layers are perfectly horizontal (i.e., “layer cake”) and that ground response is mainly caused by vertically-propagating, horizontally polarized shear waves. This assumption is valid for many geotechnical cases including the analyses of the Site. Under these assumptions, the subsurface stratigraphy is modeled as a one-dimensional column of soil layers for the analyses.

DEEPSOIL[®] employs a viscoelastic material model, described by its shear modulus (G), mass density (ρ) or unit weight (γ), and material damping ratio (D). Preliminary equivalent-linear site response analyses yielded calculated maximum shear strains greater than 5 percent in some layers, which is greater than the shear strains for which equivalent-linear analyses are considered applicable (i.e., 1 to 2 percent). Therefore, nonlinear site response analyses were performed.

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT

Input Parameters for Site Response Analysis

Input Motions

As discussed in the Time Histories subsection, six acceleration time histories were selected and scaled to match the target PGA of 0.16g. These ground motions were applied as outcrop motions in DEEPSOIL[®] at the top of the half space with $V_s = 2,300$ ft/s.

Representative Soil Profile

A detailed description of the subsurface stratigraphy is presented in Attachment 5 of the Safety Factor Assessment Report titled “*Subsurface Stratigraphy and Material Properties: Ash Pond B*” (Data Package). Information that is specific to the site response analysis is presented herein. To develop representative soil profiles, the Ash Pond B perimeter dike was divided into two sections depending on the depth of the dike fill and the V_s profile of the subsurface as shown in Figure 5. The top of the dike is roughly at the same elevation by the intake/discharge canals and the cooling pond. However, the dike fill extends to greater depths near the cooling pond. Two representative profiles to 100 ft below ground surface (bgs) were developed for the perimeter dike: (i) one by the intake/discharge canals (Profile 1); and (ii) one by the cooling pond (Profile 2). For both profiles, the water table was assumed to be at a depth of 15 ft bgs. The two representative profiles are shown in Figure 6.

Profiles 1 and 2 were extended to a depth of 500 ft bgs using information on deep V_s profiles derived from URS (2001) and S&ME (2001). At that depth, the deep V_s profiles indicate the presence of firm Coastal Plain sediments with V_s of approximately 2,300 ft/s, which is consistent with the definition of “geologically realistic” soil conditions described previously. The site response analysis presented in this package thus considers the full depth of the soil columns (i.e., 500 ft bgs), but results are presented for the soil columns to a depth of approximately 100 ft bgs to emphasize the near-surface response.

Dynamic Soil Properties

Shear Modulus Reduction and Damping Curves

The modified Kondner-Zelasko model implemented in DEEPSOIL[®] is described in Matasovic (1993). The shear modulus reduction and damping curves are required as input parameters to the constitutive soil model, and were developed for regional soil characteristics based on guidance presented in the SCDOT Geotechnical Design Manual (2010) and previous geotechnical reports of the Site. Adopting relationships proposed by Stokoe et al. (1995 and 1999), Andrus et al. (2003)

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No: **01BT**

developed regression equations for shear modulus reduction and damping curves suitable for South Carolina soils. The regression equations are presented in the SCDOT Geotechnical Design Manual (2010). These region-specific curves are a function of the plasticity index (PI) of the soil, effective mean stress, and geologic age and location of soil deposits. Geologic interpretation of the foundation soil at WGS by Paul C. Rizzo Associates (PCRA) (PCRA, 1999) and the SC Department of Natural Resources (DNR) (2012) indicates the native foundation soils above the Chicora and Williamsburg Formation strata are Pleistocene deposits. The dike fill soils were considered to be a Holocene deposit, since the perimeter dikes were constructed of compacted earthen fill in 1979-1980. The SCDOT (2010) shear modulus reduction and damping curves were calculated for the dike fill and foundation soils located above the Chicora and Williamsburg Formation strata. Soft rock curves (Silva et al., 1997) were selected for the Chicora and Williamsburg Formation strata to be consistent with the V_s -based classification indicating soft rock conditions. Pacific Engineering (S&ME, 2001) also used these soft rock shear modulus reduction and damping curves to perform the site response analysis of an ammonia tank building onsite. Figure 7 presents shear modulus reduction and damping curves used for these analyses. An example of the development of the dynamic curves and the references are provided in Appendix 4.

Representative Shear Wave Velocity Profile

Geosyntec developed representative V_s profiles of the dike fill and foundation soils using both direct measurements from Seismic Cone Penetration Tests (SCPTs) and estimates using Cone Penetration Tests (CPTs) and associated correlations. Upon evaluation of several correlations, the Mayne (2006) correlation was found to agree most closely with results of site-specific V_s measurements. This correlation is as follows:

$$V_s = 118.8 \log (f_s) + 18.5$$

where,

V_s = shear wave velocity (m/sec); and

f_s = sleeve friction from CPT (kPa).

Appendix 5 presents SCPT measurements, estimated values, and selected V_s profiles. Figure 8 shows the shallow (depths less than 100 ft bgs) V_s profiles used for the site response analyses presented herein. As described previously, these profiles were extended to greater depths to layers with V_s of approximately 2,300 ft/s to be consistent with the definition of “geologically realistic” soil conditions.

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT

Unit Weight

Unit weights of the dike fill and foundation soils were selected predominantly based on laboratory measured values as presented in the Data Package. The selected unit weight of the dike fill was 125 pcf. The selected unit weight of the foundation soils was 115 pcf. Unit weights of the Chicora and Williamsburg Formation soils were assumed to be 130 pcf and 105 pcf, respectively, based on Standard Penetration Test (SPT) N-values and material descriptions presented in the PCRA (1999) report. Williamsburg Formation soils at depths greater than approximately 110 feet were assumed to have unit weights of 125 pcf.

Site Response Analysis Results

Figures 9a and 9b show calculated maximum shear strains and shear stresses for Profiles 1 and 2, respectively. The maximum shear strains produced by two of the motions (BOS-T1 and YER360) are relatively large in the foundation soils, supporting the use of nonlinear site response analyses. Calculated accelerations within the soil profiles are presented in Appendix 6. The envelopes of maximum shear strain and shear stress for the six motions for each profile are presented in Figure 10. The calculated envelopes of maximum shear stress (τ_{max}) values for different depths are presented in Table 2. These values were used to calculate cyclic stress ratios for the evaluation of liquefaction potential (Attachment 7 in the Safety Factor Assessment Report) and to calculate the seismic coefficient for seismic stability analyses (Attachment 8 in the Safety Factor Assessment Report).

CONCLUSIONS

- The design PGA was selected to be 0.16g. This firm ground PGA corresponds to an event with a probability of exceedance of 2 percent in 50 years and is representative of a motion expected for the “geologically realistic” site condition presented in the SCDOT Geotechnical Design Manual (2010).
- The design earthquake was assumed to have an M_w of 7.3 based on the deaggregation of the probabilistic seismic hazard analysis. This M_w was used for soil liquefaction analysis and time history selection.
- A target response spectrum for “geologically realistic” site conditions was developed using the SCDOT seismic hazard maps and is presented in Figure 4.
- Six time history recordings were selected. Two synthetic time histories were obtained using the USGS Interactive Deaggregation tool (USGS, 2002), three of the time histories were

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No: **01BT**

selected from the McGuire et al. (2001) database, and one of the time histories was selected from the NGA East database (Goulet et al., 2014). The time histories were scaled to match the design PGA of 0.16g for site response analyses.

- Nonlinear site response analyses were conducted using DEEPSOIL[®] (Hashash et al., 2015). The soil profiles were developed based on results of subsurface exploration and historical site data. The analyses used region-specific shear modulus reduction and damping curves. The shear wave velocity profiles were estimated from measured SCPT values and correlations between V_s and measured CPT sleeve frictions. The inputs used for each profile in DEEPSOIL[®] are shown in Appendix 7.
- The site response analysis results are presented in Figures 9a and 9b and Figure 10. The calculated maximum shear stresses are presented in Table 2 and are used for evaluation of soil liquefaction potential and calculation of the seismic coefficient for seismic stability analyses.

REFERENCES

- Andrus, R.D., Zhang, J., Ellis, B.S., and Juang, C.H. (2003), "Guide for Estimating the Dynamic Properties of South Carolina Soils for Ground Response Analysis", South Carolina Department of Transportation, SC-DOT Research Project No. 623, FHWA-SC-03-07.
- Chapman, M.C. and Talwani, P. (2006), "Seismic Hazard Mapping for Bridge and Highway Design in South Carolina", South Carolina Department of Transportation, FHWA-SC-06-09.
- Goulet, C.A., Kishida, T., Ancheta, T.D., Cramer, C.H., Darragh, R.B., Silva, W.J., Hashash, Y.M.A., Harmon, J., Stewart, J.P., Wooddell, K.E., and Youngs, R.R. (2014), "PEER NGA-East Database", Pacific Earthquake Engineering Research Center, PEER 2014/17.
- Hashash, Y.M.A., Musgrove, M.I., Harmon, J.A., Groholski, D.R., Phillips, C.A., and Park, D. (2015), "DEEPSOIL 6.1, User Manual", Board of Trustees of University of Illinois at Urbana-Champaign, Urbana, Illinois.
- Matasovic, N. (1993), "Seismic Response of Composite Horizontally-Layered Soil Deposits", Ph.D. Dissertation, University of California, Los Angeles, California.
- Mayne, P.W. (2006), "The 2nd James K. Mitchell Lecture: Undisturbed Sand Strength from Seismic Cone Tests", Geomechanics and Geoengineering, Vol. 1, No. 4, 2006, pp.239–247.

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No: **01BT**

McGuire, R.K., Silva, W.J., and Constantino, C.J. (2001), “Technical Basis for Revision of Regulatory Guidance on Design Ground Motions: Hazard- and Risk-consistent Ground Motion Spectra Guidelines”, United States Nuclear Regulatory Commission, NUREG/CR-6728.

Paul C. Rizzo Associates (1999), “Geotechnical/Hydrogeologic Investigation Winyah Generating Station”, Georgetown, South Carolina, submitted to Santee Cooper.

S&ME, Inc. (2001), “Report of Geotechnical Exploration Winyah Generating Station Units 1&2 Ammonium Sulfate FGD System”, Georgetown, South Carolina, submitted to Marsulex Environmental Technologies.

Silva, W.J., N. Abrahamson, G. Toro, and C Costantino (1997), “Description and validation of the stochastic ground motion model”, Submitted to Brookhaven National Laboratory, Associated Universities, Inc. Upton, New York.

South Carolina Dept. of Transportation (SCDOT) (2010), Geotechnical Design Manual, available: http://www.scdot.org/doing/structural_Geotechnical.aspx

South Carolina Department of Natural Resources: Geologic Survey, (2012). “Geologic Map of the Georgetown South Quadrangle, Georgetown County, South Carolina”, 2012.

Stokoe, K. H., II, Hwang, S. K., Darendeli, M. B., and Lee, N. J. (1995), “Correlation Study of Nonlinear Dynamic Soils Properties”, final report to Westinghouse Savannah River Company, The University of Texas at Austin, Austin, TX.

Stokoe, K. H., II, Darendeli, M. B., Andrus, R. D., and Brown, L. T. (1999), “Dynamic Soil Properties: Laboratory, Field and Correlation Studies”, Proceedings, 2nd International Conference on Earthquake Geotechnical Engineering, Vol. 3, Lisbon, Portugal, 811-845.

URS Corporation, Durham Technologies, Inc., Image Cat, Inc., Pacific Engineering and Analysis, S&ME, Inc. (2001), “Comprehensive Seismic Risk and Vulnerability Study for the State of South Carolina”, prepared for South Carolina Emergency Preparedness Division, 51-D0111027.00, Final Report, 10 September 2001.

USGS (2002), “2002 Interactive Deaggregation”, 2002. <https://geohazards.usgs.gov/deaggint/2002/index.php>

USGS (2008), “US Seismic Hazard 2008”, 2008. <http://earthquake.usgs.gov/hazards/apps/map>

Written by: **C. Carlson** Date: **10/12/2016** Reviewed by: **G. Rix** Date: **10/12/2016**

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No: **01BT**

Tables

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No: **01BT**

Table 1. Summary of Hazard Parameters of the Time Histories Selected for Site Response Analysis

Name	Site Class	M _w	R (km)	PGA (g)	T _p (s)
BOS-T1	-	7.40	26.1	0.14	0.36
DEL090	C	6.70	59.3	0.27	0.22
RSN8529-HNE	C	5.74	124.1	0.09	0.26
Winyah1	A	7.04	30.2	0.56	0.08
Winyah2	A	7.04	30.2	0.56	0.10
YER360	C	7.30	24.9	0.22	0.22

Note:

1. All accelerations are scaled within DEEPSOIL[®] to match the target PGA of 0.16g.

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No: **01BT**

Table 2. Calculated Maximum Shear Stress Envelopes

Profile 1		Profile 2	
Depth (ft)	τ_{max} (psf)	Depth (ft)	τ_{max} (psf)
1.5	23	1.5	20
5.0	62	5.0	60
9.0	94	9.0	90
13.0	119	13.0	113
16.0	140	17.0	138
19.5	164	20.5	163
24.5	189	24.5	188
29.5	203	29.5	205
34.5	213	34.5	215
39.5	221	39.5	222
44.5	231	44.5	233
49.5	295	49.5	290
57.0	381	57.0	378
67.0	462	67.0	463
77.0	551	77.0	564
87.0	659	87.0	673
97.0	779	97.0	795
107.0	937	107.0	944

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No: **01BT**

Figures

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT




Figure 1. PGA (%) with 2 Percent Probability of Exceedance in 50 Years for Geologically Realistic Conditions (Chapman and Talwani, 2006)

Note:

1. PGA for WGS was selected as 0.16g.

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT

PGA




Figure 2. Deaggregation of 2 Percent Probability of Exceedance in 50 Years for PGA near Georgetown, South Carolina (Chapman and Talwani, 2006)

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT




Figure 3. “Geologically Realistic” Target Response Spectrum for WGS

Notes:

1. Target response spectrum shown for “geologically realistic” conditions was developed from SCDOT (2010) seismic hazard maps (see Appendix 2).
2. The target spectrum for “geologically realistic” conditions is selected for seismic evaluations.

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No: **01BT**




Figure 4. Response Spectra of Scaled Time Histories Selected for Seismic Evaluations

Note:

1. Time histories were scaled to match the target PGA = 0.16g (represented by a period of 0.01 seconds).

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT




Figure 5. Locations of Representative Soil Profiles

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT

Dike Soil Profile Models




Figure 6. DEEPSOIL[®] Soil Profile Models for the Two Representative Profiles

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT




Figure 7. Shear Modulus Reduction (G/G_{max}) and Damping Curves for Soils Used in Site Response Analyses

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT





Figure 8. Selected Shear Wave Velocity (V_s) Profiles for Site Response Analyses

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT

Profile 1

Maximum Shear Strain (%)



Profile 1

Maximum Shear Stress (psf)




Figure 9a. Site Response Analysis Results for Profile 1

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT




Figure 9b. Site Response Analysis Results for Profile 2

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT




Figure 10. Maximum Shear Strain and Shear Stress Envelopes for Each Profile

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No: **01BT**

Appendix 1

Peak Ground Accelerations from Different Seismic Hazard Maps

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT




Figure 1-1. PGA (%) with 2 Percent Probability of Exceedance in 50 Years (USGS, 2008)

Note:

1. Site PGA based on USGS seismic hazard map (2008) is 0.469g.

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No: 01BT




Figure 1-2. PGA (%) with 2 Percent Probability of Exceedance in 50 Years for Geologically Realistic Conditions (Upper Figure) and Hard Rock Conditions (Lower Figure) (Chapman and Talwani, 2006)

Note:

1. Site PGA based on Chapman and Talwani (2006) is approximately 0.16g for “geologically realistic” conditions and 0.21g for hard rock conditions.

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No: **01BT**

Appendix 2

SCDOT Seismic Hazard Maps Used for Development of Target Design Spectra

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT




Figure 2-1. PGA (%) with 2 Percent Probability of Exceedance in 50 Years for Geologically Realistic Conditions (Upper Figure) and Hard Rock Conditions (Lower Figure) (Chapman and Talwani, 2006)

Note:

1. Refer to the figures in Appendix 1 for the site location.

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT




Figure 2-2. Spectral Acceleration (%) for 13 Hz (0.075 s Period) with 2 Percent Probability of Exceedance in 50 Years for Geologically Realistic Conditions (Upper Figure) and Hard Rock Conditions (Lower Figure) (Chapman and Talwani, 2006)

Note:

1. Refer to the figures in Appendix 1 for the site location.

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT




Figure 2-3. Spectral Acceleration (%) for 6.7 Hz (0.15 s Period) with 2 Percent Probability of Exceedance in 50 Years for Geologically Realistic Conditions (Upper Figure) and Hard Rock Conditions (Lower Figure) (Chapman and Talwani, 2006)


Note:

1. Refer to the figures in Appendix 1 for the site location.

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT

5 Hz Spectral Acceleration (%g) with 2% Probability of Exceedance in 50 Years. Site condition takes into account sediment thickness and near surface weathering.



5 Hz Spectral Acceleration (%g) with 2% Probability of Exceedance in 50 Years. Hard Rock Site Condition.




Figure 2-4. Spectral Acceleration (%) for 5 Hz (0.2 s Period) with 2 Percent Probability of Exceedance in 50 Years for Geologically Realistic Conditions (upper figure) and Hard Rock Conditions (Lower Figure) (Chapman and Talwani, 2006)


Note:

1. Refer to the figures in Appendix 1 for the site location.

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT

3.33 Hz Spectral Acceleration (%g) with 2% Probability of Exceedance in 50 Years. Site condition takes into account sediment thickness and near surface weathering.



3.33 Hz Spectral Acceleration (%g) with 2% Probability of Exceedance in 50 Years. Hard Rock Site Condition.




Figure 2-5. Spectral Acceleration (%) for 3.33 Hz (0.3 s Period) with 2 Percent Probability of Exceedance in 50 Years for Geologically Realistic Conditions (Upper Figure) and Hard Rock Conditions (Lower Figure) (Chapman and Talwani, 2006)

Note:

1. Refer to the figures in Appendix 1 for the site location.

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT




Figure 2-6. Spectral Acceleration (%) for 2 Hz (0.5 s Period) with 2 Percent Probability of Exceedance in 50 Years for Geologically Realistic Conditions (Upper Figure) and Hard Rock Conditions (Lower Figure) (Chapman and Talwani, 2006)

Note:

1. Refer to the figures in Appendix 1 for the site location.

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT




Figure 2-7. Spectral Acceleration (%) for 1 Hz (1 s Period) with 2 Percent Probability of Exceedance in 50 Years for Geologically Realistic Conditions (Upper Figure) and Hard Rock Conditions (Lower Figure) (Chapman and Talwani, 2006)

Note:

1. Refer to the figures in Appendix 1 for the site location.

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT




Figure 2-8. Spectral Acceleration (%) for 0.5 Hz (2 s Period) with 2 Percent Probability of Exceedance in 50 Years for Geologically Realistic Conditions (Upper Figure) and Hard Rock Conditions (Lower Figure) (Chapman and Talwani, 2006)

Note:

1. Refer to the figures in Appendix 1 for the site location.

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No: **01BT**

Appendix 3

Selected Time Histories

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No: **01BT**




Figure 3-1. Acceleration Time Histories of Selected Earthquake Motions Scaled to PGA of 0.16g

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No: **01BT**

Appendix 4

Shear Modulus Reduction and Damping Curve Selection

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No: **01BT**

As indicated in the package, Geosyntec developed region-specific shear modulus reduction and damping curves based on the procedures presented in SCDOT GDM (2010). Figures 4-1 and 4-5 show the procedures. An example calculation following these procedures is presented as follows.

Shear Modulus Reduction Curve for the foundation soil in Profile 2

(see Figure 4-1 for description on each step; see Figure 4-2 for the profile)

Step 1 – age of the soil layer: Pleistocene deposit.

Step 2 – soil type: sandy soils with PI=0; groundwater table @ 15 ft bgs.

Step 3 – calculate σ_m' @ mid-depth of the layer (34.5 ft bgs)

$$\sigma_v' = \gamma H - \gamma_w H_w = 125 \times 22 + 115 \times 12.5 - 62.4 \times 19.5 = 2970.7 \text{ psf}$$

$$\sigma_m' = \sigma_v' (1 + 2K_o') / 3 = 2970.7 \times (1 + 2 \times 0.47) / 3 = 1921.1 \text{ psf}$$

$$(K_o' = 1 - \sin \phi' = 1 - \sin(32) = 0.47, \text{ see Figure 5-3 for the equation})$$

Step 4 – σ_m' for the upper and lower native soils are within $\pm 50\%$ σ_m' value calculated above. The modulus reduction curve developed here can be used for the entire foundation soils in Profile 2.

Step 5 – select the parameters α , γ_{r1} , k from Figure 4-4.

$$\gamma_{r1} = 0.018\%, \alpha = 1.00, k = 0.454$$

Step 6 – compute the reference strain using SCDOT GDM Equation 12-20 (see Figure 4-3 for the equation).

$$\gamma_r = \gamma_{r1} (\sigma_m' / P_a)^k = 0.018 \times (1921.1 / 2089)^{0.454} = 0.0173\%$$

Step 7 – compute shear modulus reduction curve using SCDOT GDM Equation 12-19 (see Figure 4-3 for the equation)

$$\frac{G}{G_{max}} = \frac{1}{1 + (\frac{\gamma}{\gamma_r})^\alpha}$$

$$\text{If } \gamma = 0.001\%, G/G_{max} = 1 / [1 + (0.001 / 0.0173)] = 0.945$$

$$\text{If } \gamma = 0.01\%, G/G_{max} = 1 / [1 + (0.01 / 0.0173)] = 0.634$$

$$\text{If } \gamma = 0.1\%, G/G_{max} = 1 / [1 + (0.1 / 0.0173)] = 0.147$$

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No: **01BT**

Damping Curve for the upper native soil in Profile 2

(see Figure 4-5 for description on each step; see Figure 4-2 for the profile)

Steps 1 through 4 are the same as those for modulus reduction curve development.

Step 5 – select small-strain material damping @ $\sigma_m' = 1$ atm, D_{min1} from Figure 4-6.

$$D_{min1} = 0.59\%$$

Step 6 – compute the small strain material damping, D_{min} , using SCDOT GDM Equation 12-28 (see Figure 4-7 for the equation).

$$D_{min} = D_{min1} (\sigma_m'/P_a)^{-0.5k} = 0.59 \times (1921.1/2089)^{-0.5 \times 0.454} = 0.601\%$$

Step 7-9 – instead of taking Steps 7 through 9, use SCDOT GDM Equation 12-29 to compute damping ratio curve (D).

$$D = 12.2 (G/G_{max})^2 - 34.2 (G/G_{max}) + 22.0 + D_{min}$$

$$\text{If } \gamma = 0.001\%, D = 12.2 \times (0.945)^2 - 34.2 \times (0.945) + 22.0 + 0.601 = 1.18\%$$

$$\text{If } \gamma = 0.01\%, D = 12.2 \times (0.634)^2 - 34.2 \times (0.634) + 22.0 + 0.601 = 5.82\%$$

$$\text{If } \gamma = 0.1\%, D = 12.2 \times (0.147)^2 - 34.2 \times (0.147) + 22.0 + 0.601 = 17.84\%$$

Shear Modulus Reduction and Damping Curves for Chicora / Williamsburg Formation

Figure 4-8 presents shear modulus reduction and damping curves used for Pacific Engineering's site response analyses of the Ammonia tank building located at the WGS.

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT

Table 12-16, Procedure for Computing G/G_{max}

Step	Procedure Description
1	Perform a geotechnical subsurface exploration and identify subsurface soil geologic units, approximate age, and formation.
2	Develop soil profiles based on geologic units, soil types, average Pf , and soil density. Subdivide major geologic units to reflect significant changes in Pf and soil density. Identify design ground water table based on seasonal fluctuations and artesian pressures.
3	Calculate the average σ'_m and determine the corresponding $\pm 50\%$ range of σ'_m for each major geologic unit using Equation 12-21
4	Calculate σ'_m for each layer within each major geologic unit. If the values for σ'_m of each layer are within a geologic unit's $\pm 50\%$ range of σ'_m (Step 3) then assign the average σ'_m for the major geologic unit (Step 3) to all layers within it. If the σ'_m of each layer within a geologic unit is not within the $\pm 50\%$ range of σ'_m for the major geologic unit, then the geologic unit needs to be "subdivided" and more than one average σ'_m needs to be used, provided the σ'_m remain within the $\pm 50\%$ range of σ'_m for the "subdivided" geologic unit.
5	Select the appropriate values for each layer of reference strain, γ_{r1} , at 1 tsf (1 atm), curvature coefficient, α , and k exponent from Table 12-15. These values may be selected by rounding to the nearest Pf value in the table or by interpolating between listed Pf values in the table.
6	Compute the reference strain, γ_r , based on Equation 12-20 for each geologic unit (or "subdivided" geologic unit) that has a corresponding average σ'_m .
7	Compute the design shear modulus reduction curves (G/G_{max}) for each layer by substituting reference strain, γ_r , and curvature coefficient, α , for each layer using Equation 12-19. Tabulate values of normalized shear modulus, G/G_{max} with corresponding shear strain, γ for use in a site-specific response analysis.

Figure 4-1. Procedure for Development of Region-specific Modulus Reduction Curve (SCDOT, 2010)

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT




Figure 4-2. Profile 2 for the Example Calculations

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT

$$\frac{G}{G_{\max}} = \frac{1}{1 + \left(\frac{\gamma}{\gamma_r}\right)^a} \quad \text{Equation 12-19}$$

$$\gamma_r = \gamma_{r1} (\sigma'_m / P_a)^k \quad \text{Equation 12-20}$$

$$\sigma'_m = \sigma'_v \left[\frac{1 + 2K'_o}{3} \right] \quad \text{Equation 12-21}$$

Where,

σ'_v = vertical effective pressure (kPa)

K'_o = coefficient of effective earth pressure at rest. The K'_o is defined as the ratio of horizontal effective pressure, σ'_h , to vertical effective pressure, σ'_v . The coefficient of effective earth pressure at-rest, K'_o , can be approximated by the coefficient of at-rest pressure, K_o , equations shown in Table 12-14.

Table 12-14, Estimated Coefficient of At-Rest Pressure, K_o

Soil Type	Equation ⁽¹⁾	Equation No.
Normally Consolidated Granular Soils (Jaky, 1944)	$K_o \approx 1 - \sin \phi'$	Equation 12-22
Normally Consolidated Clay Soils (Brooker and Ireland, 1965)	$K_o \approx 0.95 - \sin \phi'$	Equation 12-23
Normally Consolidated Clay Soils ($0 < PI \leq 40$) (Brooker and Ireland, 1965)	$K_o \approx 0.40 + 0.007(PI)$	Equation 12-24
Normally Consolidated Clay Soils ($40 < PI < 80$) (Brooker and Ireland, 1965)	$K_o \approx 0.6 + 0.001(PI)$	Equation 12-25
Overconsolidated Clays (Alpan, 1967; Schmertmann, 1975)	$K_o \approx K_{o(N.C.)} \sqrt{OCR}$	Equation 12-26
Overconsolidated Soils (Mayne and Kulhawy, 1982)	$K_o \approx K_{o(N.C.)} OCR^{\sin \phi'}$	Equation 12-27

⁽¹⁾ ϕ' =Drained Friction Angle; PI =Plasticity Index; $N.C.$ =Normally Consolidated; OCR = Overconsolidated Ratio

Figure 4-3. Equations Needed for Shear Modulus Reduction Curve Development (SCDOT, 2010)

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT

Table 12-15, Recommended Values γ_{r1} , α , and k for SC Soils
(Andrus et al., 2003)

Geologic Age and Location of Deposits ⁽¹⁾	Variable	Soil Plasticity Index, PI (%)					
		0	15	30	60	100	150
Holocene	γ_{r1} (%)	0.073	0.114	0.156	0.211	0.350	0.488
	α	0.95	0.96	0.97	0.98	1.01	1.04 ⁽²⁾
	k	0.385	0.202	0.108	0.045	0.005	0.001 ⁽²⁾
Pleistocene (Wando)	γ_{r1} (%)	0.018	0.032	0.047	0.067	0.117	0.166
	α	1.00	1.02	1.04	1.06	1.13	1.19
	k	0.454	0.402	0.355	0.301	0.199	0.132
Tertiary Ashley Formation (Cooper Mari)	γ_{r1} (%)	---	---	0.030 ⁽²⁾	0.049	0.096 ⁽²⁾	---
	α	---	---	1.10 ⁽²⁾	1.15	1.28	---
	k	---	---	0.497 ⁽²⁾	0.455	0.362 ⁽²⁾	---
Tertiary (Stiff Upland Soils)	γ_{r1} (%)	---	---	0.023	0.041 ⁽²⁾	---	---
	α	---	---	1.00	1.00 ⁽²⁾	---	---
	k	---	---	0.102	0.045 ⁽²⁾	---	---
Tertiary (All soils at SRS except Stiff Upland Soils)	γ_{r1} (%)	0.038	0.058	0.079	0.108	0.174 ⁽²⁾	---
	α	1.00	1.00	1.00	1.00	1.00 ⁽²⁾	---
	k	0.277	0.240	0.208	0.172	0.106 ⁽²⁾	---
Tertiary (Tobacco Road, Snapp)	γ_{r1} (%)	0.029	0.056	0.082	0.117	0.205 ⁽¹⁾	---
	α	1.00	1.00	1.00	1.00	1.00 ⁽¹⁾	---
	k	0.220	0.185	0.156	0.124	0.070 ⁽¹⁾	---
Tertiary (Soft Upland Soils, Dry Branch, Santee, Warley Hill, Congaree)	γ_{r1} (%)	0.047	0.059	0.071	0.088	0.125 ⁽¹⁾	---
	α	1.00	1.00	1.00	1.00	1.00 ⁽¹⁾	---
	k	0.313	0.299	0.285	0.268	0.229 ⁽¹⁾	---
Residual Soil and Saprolite	γ_{r1} (%)	0.040	0.066	0.093 ⁽¹⁾	0.129 ⁽¹⁾	---	---
	α	0.72	0.80	0.89	1.01 ⁽¹⁾	---	---
	k	0.202	0.141	0.099	0.061 ⁽²⁾	---	---

⁽¹⁾ SRS = Savannah River Site
⁽²⁾ Tentative Values - Andrus et al. (2003)

Figure 4-4. Recommended Parameters for South Carolina Soils (Table 12-15 of SCDOT, 2010)

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT

Table 12-18, Procedure for Computing Damping Ratio

Step	Procedure Description
1	Perform a geotechnical subsurface exploration and identify subsurface soil geologic units, approximate age, and formation.
2	Develop soil profiles based on geologic units, soil types, average Pf , and soil density. Subdivide major geologic units to reflect significant changes in Pf and soil density. Identify design ground water table based on seasonal fluctuations and artesian pressures.
3	Calculate the average σ'_m and determine the corresponding $\pm 50\%$ range of σ'_m for each major geologic unit using Equation 12-21.
4	Calculate σ'_m for each layer within each major geologic unit. If the values for σ'_m of each layer are within a geologic unit's $\pm 50\%$ range of σ'_m (Step 3) then assign the average σ'_m for the major geologic unit (Step 3) to all layers within it. If the σ'_m of each layer within a geologic unit is not within the $\pm 50\%$ range of σ'_m for the major geologic unit, then the geologic unit needs to be "subdivided" and more than one average σ'_m needs to be used, provided the σ'_m remain within the $\pm 50\%$ range of σ'_m for the "subdivided" geologic unit.
5	Select appropriate small-strain material Damping @ $\sigma'_m = 1 \text{ atm}$, D_{small} , from Table 12-17 for each layer within a geologic unit.
6	Compute the small-strain material Damping, D_{small} , for each layer within a geologic unit using Equation 12-28.
7	Select the appropriate values for each layer of reference strain, γ_r , @ $\sigma'_m = 1 \text{ atm}$, curvature coefficient, α , and k exponent from Table 12-15. These values may be selected by rounding to the nearest Pf value in the table or by interpolating between listed Pf values in the table.
8	Compute the reference strain, γ_r , based on Equation 12-20 for each geologic unit that has a corresponding average σ'_m .
9	Compute the design equivalent viscous damping ratio curves (D) for each layer by substituting reference strain, γ_r , and curvature coefficient, α , and small-strain material Damping, D_{small} , for each layer using Equation 12-30. Tabulate values of Soil Damping Ratio, D , with corresponding shear strain, γ , for use in a site-specific site response analysis.

Figure 4-5. Procedure for Development of Region-Specific Damping Curve (SCDOT, 2010)

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No: **01BT**

**Table 12-17, Recommended Value D_{min1} (%) for SC Soils
(Andrus et al., 2003)**

Geologic Age and Location of Deposits	Soil Plasticity Index, PI (%)					
	0	15	30	50	100	150
Holocene	1.09	1.29	1.50	1.78	2.48	3.18 ⁽¹⁾
Pleistocene (Wando)	0.59	0.66	0.73	0.83	1.08	1.32
Tertiary Ashley Formation (Cooper Marl)	---	---	1.14 ⁽¹⁾	1.52 ⁽¹⁾	2.49 ⁽¹⁾	---
Tertiary (Stiff Upland Soils)	---	---	0.98	1.42 ⁽¹⁾	---	---
Tertiary (All soils at SRS except Stiff Upland Soils)	0.68	0.94	1.19	1.53	2.37 ⁽¹⁾	---
Tertiary (Tobacco Road, Snapp)	0.68	0.94	1.19	1.53	2.37 ⁽¹⁾	---
Tertiary (Soft Upland Soils, Dry Branch, Santee, Warley Hill, Congaree)	0.68	0.94	1.19	1.53	2.37 ⁽¹⁾	---
Residual Soil and Saprolite	0.56 ⁽¹⁾	0.85 ⁽¹⁾	1.14 ⁽¹⁾	1.52 ⁽¹⁾	---	---

⁽¹⁾ Tentative Values – Andrus et al. (2003)

Figure 4-6. Recommended D_{min1} for South Carolina Soils (Table 12-17 of SCDOT, 2010)

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT

$$D_{min} = D_{min1} (\sigma'_m / P_a)^{-0.5k} \quad \text{Equation 12-28}$$

Where D_{min1} is the small-strain damping at a σ'_m of 1 tsf (1 atm). The mean confining pressure, σ'_m , is computed using Equation 12-21. The k exponent is provided for South Carolina soils based on Andrus et al. (2003) in Table 12-15. A relationship for D_{min1} based on soil plasticity index, PI , and fitting parameters "a" and "b" for specific geologic units has been developed by Darendeli (2001) as indicated in Figure 12-27. Values for D_{min1} , small-strain damping @ $\sigma'_m = 1$ atm are provided for South Carolina soils based on Andrus et al. (2003) in Table 12-17. The mean confining pressure, σ'_m , at depth (Z) is computed as shown in Equation 12-21 in units of kPa.

Equation 12-29 represents a best-fit equation (UTA Correlation) of the observed relationship of $(D - D_{min})$ vs. (G/G_{max}) indicated in Figure 12-28.

$$D - D_{min} = 12.2(G/G_{max})^2 - 34.2(G/G_{max}) + 22.0 \quad \text{Equation 12-29}$$

If we substitute Equation 12-19 into Equation 12-29 and Solve for damping ratio, D , the Equivalent Viscous Damping Ratio curves can be generated using Equation 12-30.

$$D = D_{min} + 12.2 \left(\frac{1}{1 + \left(\frac{\gamma}{\gamma_r} \right)^\alpha} \right)^2 - 34.2 \left(\frac{1}{1 + \left(\frac{\gamma}{\gamma_r} \right)^\alpha} \right) + 22.0 \quad \text{Equation 12-30}$$

Where values of reference strain, γ_r , are computed using Equation 12-20.

Figure 4-7. Equations Needed for Damping Curve Development (SCDOT, 2010)

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT




Figure 5b. Generic G/Gmax and hysteretic damping curves for soft rock (Silva et al., 1997).

Figure 4-8. Shear Modulus Reduction and Damping Curves for Chicora/Williamsburg Formation (S&ME, 2001)

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No: **01BT**

Appendix 5

Shear Wave Velocity Profile Selection

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT




Figure 5-1a. Selected V_s Profile for the Intake/Discharge Canals Dike Model (Profile 1)

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No: **01BT**




Figure 5-1b. Selected V_s Profile for the Cooling Pond Dike Model (Profile 2)

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT




Figure 3-9. Base case shear-wave velocity profile for the Myrtle Beach site response category along with available profiles.

Figure 5-2. Reference V_s Profile for Chicora/Williamsburg Formation (URS, 2001)

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No: **01BT**

Appendix 6

Calculated Acceleration Profiles

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No: **01BT**

Profile 1




Figure 6-1. Calculated Maximum Acceleration for Profile 1

Note:

1. The input motions were applied as an outcrop motion with a PGA of 0.16g.

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No: **01BT**

Profile 2




Figure 6-2. Calculated Maximum Acceleration for Profile 2

Note:

1. The input motions were applied as an outcrop motion with a PGA of 0.16g.

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No: **01BT**

Appendix 7

DEEPSOIL[®] Input

Step 1 - Analysis Definition

INSTRUCTIONS
To begin, either complete the fields in the "Define Analysis" section and select "Next".

Define Analysis

Frequency Domain Analysis

Time Domain Analysis

Linear

Nonlinear

Also Generate Equivalent Linear Results

Dynamic Properties Formulation:

Discrete Points

Nonlinear Parameters

Nonlinear Backbone Formulation

Hysteretic Re/Unloading Formulation

Pressure-Dependent Modified Kodner Zelasko (MKZ)

Non-Masing Re/Unloading

Masing Re/Unloading

Pore Pressure Generation

Do Not Generate

Generate

Initial Shear Stiffness Definition

Include PWP Dissipation

Shear-Wave Velocity (Vs)

Shear Modulus (Gmax)

Bottom of Profile:

Permeable


Impermeable

Soil Model


Units English Metric DS-NL2 ?

Current Workspace Directory:
C:\Users\ccarlson\Documents\DEEPSOIL\

Buttons:



Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016
 Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT




Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: Santee Cooper Project: Winyah Generating Station Project/Proposal No.: GSC5242 Task No: 01BT

Step 2a - Soil Profile Definition

Layer #	Layer Name	Thickness (ft)	Unit Weight (pcf)	Shear Velocity (ft/s)	Damping Ratio (%)	Ref. Strain (%)	Ref. Stress (MPa)	Beta	a	b	d	F1	P2	P3
28	Williamsburg Formation	10	125	2000	3.16107320786548	0.0556	0.18	1.515	0.99	0	0	0.758	0.28	0.85
29	Williamsburg Formation	10	125	2000	3.16107320786548	0.0556	0.18	1.515	0.99	0	0	0.758	0.28	0.85
30	Williamsburg Formation	10	125	2000	3.16107320786548	0.0556	0.18	1.515	0.99	0	0	0.758	0.28	0.85
31	Williamsburg Formation	10	125	2000	3.16107320786548	0.0556	0.18	1.515	0.99	0	0	0.758	0.28	0.85
32	Williamsburg Formation	10	125	2000	3.16107320786548	0.0556	0.18	1.515	0.99	0	0	0.758	0.28	0.85
33	Williamsburg Formation	10	125	2200	3.15951070328587	0.0812000000000001	0.18	1.515	0.975	0	0	0.81	0.308	0.65
34	Williamsburg Formation	10	125	2200	3.15951070328587	0.0812000000000001	0.18	1.515	0.975	0	0	0.81	0.308	0.65
35	Williamsburg Formation	10	125	2200	3.15951070328587	0.0812000000000001	0.18	1.515	0.975	0	0	0.81	0.308	0.65
36	Williamsburg Formation	10	125	2200	3.15951070328587	0.0812000000000001	0.18	1.515	0.975	0	0	0.81	0.308	0.65
37	Williamsburg Formation	10	125	2200	3.15951070328587	0.0812000000000001	0.18	1.515	0.975	0	0	0.81	0.308	0.65
38	Williamsburg Formation	10	125	2200	3.15951070328587	0.0812000000000001	0.18	1.515	0.975	0	0	0.81	0.308	0.65
39	Williamsburg Formation	10	125	2200	3.15951070328587	0.0812000000000001	0.18	1.515	0.975	0	0	0.81	0.308	0.65
40	Williamsburg Formation	10	125	2200	3.15951070328587	0.0812000000000001	0.18	1.515	0.975	0	0	0.81	0.308	0.65
41	Williamsburg Formation	10	125	2200	3.15951070328587	0.0812000000000001	0.18	1.515	0.975	0	0	0.81	0.308	0.65
42	Williamsburg Formation	10	125	2200	3.15951070328587	0.0812000000000001	0.18	1.515	0.975	0	0	0.81	0.308	0.65
43	Williamsburg Formation	10	125	2200	3.15951070328587	0.0812000000000001	0.18	1.515	0.975	0	0	0.81	0.308	0.65
44	Williamsburg Formation	10	125	2200	3.15951070328587	0.0812000000000001	0.18	1.515	0.975	0	0	0.81	0.308	0.65
45	Williamsburg Formation	10	125	2200	3.15951070328587	0.0812000000000001	0.18	1.515	0.975	0	0	0.81	0.308	0.65
46	Williamsburg Formation	10	125	2200	3.15951070328587	0.0812000000000001	0.18	1.515	0.975	0	0	0.81	0.308	0.65
47	Williamsburg Formation	10	125	2200	3.15951070328587	0.0812000000000001	0.18	1.515	0.975	0	0	0.81	0.308	0.65
48	Williamsburg Formation	10	125	2200	3.15951070328587	0.0812000000000001	0.18	1.515	0.975	0	0	0.81	0.308	0.65
49	Williamsburg Formation	10	125	2200	3.15951070328587	0.0812000000000001	0.18	1.515	0.975	0	0	0.81	0.308	0.65
50	Williamsburg Formation	10	125	2200	3.15951070328587	0.0812000000000001	0.18	1.515	0.975	0	0	0.81	0.308	0.65
51	Williamsburg Formation	10	125	2200	3.15951070328587	0.0812000000000001	0.18	1.515	0.975	0	0	0.81	0.308	0.65
52	Williamsburg Formation	10	125	2200	3.15951070328587	0.0812000000000001	0.18	1.515	0.975	0	0	0.81	0.308	0.65
53	Williamsburg Formation	10	125	2200	3.15951070328587	0.0812000000000001	0.18	1.515	0.975	0	0	0.81	0.308	0.65
54	Williamsburg Formation	10	125	2200	3.15951070328587	0.0812000000000001	0.18	1.515	0.975	0	0	0.81	0.308	0.65
55	Williamsburg Formation	10	125	2200	3.15951070328587	0.0812000000000001	0.18	1.515	0.975	0	0	0.81	0.308	0.65
56	Williamsburg Formation	10	125	2200	3.15951070328587	0.0812000000000001	0.18	1.515	0.975	0	0	0.81	0.308	0.65
57	Williamsburg Formation	10	125	2200	3.15951070328587	0.0812000000000001	0.18	1.515	0.975	0	0	0.81	0.308	0.65



Soil Profile Display
 Total Profile Depth (ft): 507.00
 Natural Freq. of Profile: 0.83 Hz
 Natural Period of Profile: 1.21 sec


Water Table Location
 Top of Layer: 5
 No Water Table

Soil Profile Legend
 Below Water Table
 Layer Properties
 Material Properties

Conversion Tools
 Units: English to Metric
 Shear: Velocity to Modulus

Back Next

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016
 Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT



Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT

Step 2c - Halfspace and Bedrock Definition

Forward Analysis

Elastic Half-Space Rigid Half-Space

Bedrock Properties

Firm Rock **Bedrock Name**

Shear Velocity (ft/s)

Unit Weight (pcf)

Damping Ratio (%)

Information Regarding Rock Properties

The selection of bedrock type is related to the type of input motion.

If an outcrop motion is being used (most common situation), the Elastic Half-Space option should be selected.

If a within motion is being used (e.g. from a vertical array), the Rigid Half-Space option should be selected.

Use Saved Bedrock

Default bed:

Halfspace Porewater Pressure Dissipation


Use Cv of bottom layer Specify Halfspace Cv: ft²/s

Deconvolution

Motion recorded at top of layer:

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT



Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT

Step 5 - Analysis Control

Frequency Domain

Number of Iterations:

Effective Shear Strain Definition
SSR = $\frac{M-1}{10}$

Effective Shear Strain Ratio (SSR):

Complex Shear Modulus Formulation

Frequency Independent (recommended)
 $G^* = G(1+j2\xi)$

Frequency Dependent (use with caution)
 $G^* = G(1-2\xi^2 + j2\xi\sqrt{1-\xi^2})$

Simplified
 $G^* = G(1-\xi^2 + j2\xi)$

Time Domain

Step Control

Flexible Fixed

Maximum Strain Increment:

of Sub-increments:


Time-history Interpolation Method

Linear interpolation

Zero-padded frequency-domain interpolation

Back
Analyze

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016
 Client: Santee Cooper Project: Winyah Generating Station Project/Proposal No.: GSC5242 Task No: 01BT



Soil Profile Display
 Total Profile Depth (ft): 502.00
 Natural Freq. of Profile: 0.84 Hz
 Natural Period of Profile: 1.19 sec

Soil Profile
 Material Properties
 Add Layer(s)
 Remove Layer

Water Table Location
 Top of Layer: 5
 No Water Table

Below Water Table
 Layer Properties
 Material Properties

Conversion Tools
 Units: English to Metric
 Shear: Velocity to Modulus

Back Next

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016
 Client: Santee Cooper Project: Winyah Generating Station Project/Proposal No.: GSC5242 Task No: 01BT

Step 2a - Soil Profile Definition

Layer #	Layer Name	Thickness (ft)	Unit Weight (pcf)	Shear Velocity (ft/s)	Damping Ratio (%)	Ref. Strain (%)	Ref. Stress (MPa)	Beta	s	b	d	P1	P2	P3
28	Williamsburg Formation	10	125	2000	3.16107320796548	0.0556	0.18	1.515	0.99	0	0	0.768	0.28	0.85
29	Williamsburg Formation	10	125	2000	3.16107320796548	0.0556	0.18	1.515	0.99	0	0	0.768	0.28	0.85
30	Williamsburg Formation	10	125	2000	3.16107320796548	0.0556	0.18	1.515	0.99	0	0	0.768	0.28	0.85
31	Williamsburg Formation	10	125	2000	3.16107320796548	0.0556	0.18	1.515	0.99	0	0	0.768	0.28	0.85
32	Williamsburg Formation	10	125	2000	3.16107320796548	0.0556	0.18	1.515	0.99	0	0	0.768	0.28	0.85
33	Williamsburg Formation	10	125	2200	3.15051070328587	0.0812000000000001	0.18	1.515	0.975	0	0	0.81	0.308	0.65
34	Williamsburg Formation	10	125	2200	3.15051070328587	0.0812000000000001	0.18	1.515	0.975	0	0	0.81	0.308	0.65
35	Williamsburg Formation	10	125	2200	3.15051070328587	0.0812000000000001	0.18	1.515	0.975	0	0	0.81	0.308	0.65
36	Williamsburg Formation	10	125	2200	3.15051070328587	0.0812000000000001	0.18	1.515	0.975	0	0	0.81	0.308	0.65
37	Williamsburg Formation	10	125	2200	3.15051070328587	0.0812000000000001	0.18	1.515	0.975	0	0	0.81	0.308	0.65
38	Williamsburg Formation	10	125	2200	3.15051070328587	0.0812000000000001	0.18	1.515	0.975	0	0	0.81	0.308	0.65
39	Williamsburg Formation	10	125	2200	3.15051070328587	0.0812000000000001	0.18	1.515	0.975	0	0	0.81	0.308	0.65
40	Williamsburg Formation	10	125	2200	3.15051070328587	0.0812000000000001	0.18	1.515	0.975	0	0	0.81	0.308	0.65
41	Williamsburg Formation	10	125	2200	3.15051070328587	0.0812000000000001	0.18	1.515	0.975	0	0	0.81	0.308	0.65
42	Williamsburg Formation	10	125	2200	3.15051070328587	0.0812000000000001	0.18	1.515	0.975	0	0	0.81	0.308	0.65
43	Williamsburg Formation	10	125	2200	3.15051070328587	0.0812000000000001	0.18	1.515	0.975	0	0	0.81	0.308	0.65
44	Williamsburg Formation	10	125	2200	3.15051070328587	0.0812000000000001	0.18	1.515	0.975	0	0	0.81	0.308	0.65
45	Williamsburg Formation	10	125	2200	3.15051070328587	0.0812000000000001	0.18	1.515	0.975	0	0	0.81	0.308	0.65
46	Williamsburg Formation	10	125	2200	3.15051070328587	0.0812000000000001	0.18	1.515	0.975	0	0	0.81	0.308	0.65
47	Williamsburg Formation	10	125	2200	3.15051070328587	0.0812000000000001	0.18	1.515	0.975	0	0	0.81	0.308	0.65
48	Williamsburg Formation	10	125	2200	3.15051070328587	0.0812000000000001	0.18	1.515	0.975	0	0	0.81	0.308	0.65
49	Williamsburg Formation	10	125	2200	3.15051070328587	0.0812000000000001	0.18	1.515	0.975	0	0	0.81	0.308	0.65
50	Williamsburg Formation	10	125	2200	3.15051070328587	0.0812000000000001	0.18	1.515	0.975	0	0	0.81	0.308	0.65
51	Williamsburg Formation	10	125	2200	3.15051070328587	0.0812000000000001	0.18	1.515	0.975	0	0	0.81	0.308	0.65
52	Williamsburg Formation	10	125	2200	3.15051070328587	0.0812000000000001	0.18	1.515	0.975	0	0	0.81	0.308	0.65
53	Williamsburg Formation	10	125	2200	3.15051070328587	0.0812000000000001	0.18	1.515	0.975	0	0	0.81	0.308	0.65
54	Williamsburg Formation	10	125	2200	3.15051070328587	0.0812000000000001	0.18	1.515	0.975	0	0	0.81	0.308	0.65
55	Williamsburg Formation	10	125	2200	3.15051070328587	0.0812000000000001	0.18	1.515	0.975	0	0	0.81	0.308	0.65
56	Williamsburg Formation	10	125	2200	3.15051070328587	0.0812000000000001	0.18	1.515	0.975	0	0	0.81	0.308	0.65
57	Williamsburg Formation	10	125	2200	3.15051070328587	0.0812000000000001	0.18	1.515	0.975	0	0	0.81	0.308	0.65

Water Table Location

Top of Layer: 5

No Water Table

Soil Profile

Total Profile Depth (ft): 502.00

Natural Freq. of Profile: 0.84 Hz

Natural Period of Profile: 1.19 sec

Back

Water Table Location

Top of Layer: 5

No Water Table

Soil Profile

Total Profile Depth (ft): 502.00

Natural Freq. of Profile: 0.84 Hz

Natural Period of Profile: 1.19 sec

Back


Conversion Tools

Units: English to Metric

Shear: Velocity to Modulus


Next

Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016
 Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT



Written by: C. Carlson Date: 10/12/2016 Reviewed by: G. Rix Date: 10/12/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT



ATTACHMENT 7

Liquefaction Potential Analysis

Written by: J. McNash Date: 10/10/2016 Reviewed by: M. Zhu/G. Rix/J. Colley Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No.: 01BT

LIQUEFACTION POTENTIAL ANALYSIS: ASH POND B

INTRODUCTION

This liquefaction potential analysis calculation package (Liquefaction Package) was prepared to present the evaluation for soil liquefaction potential of the perimeter dike soils forming Ash Pond B at Winyah Generating Station (WGS or Site). This calculation package is Attachment 7 to the *2016 Surface Impoundment Periodic Safety Factor Assessment Report: Ash Pond B* (Safety Factor Assessment Report) prepared by Geosyntec Consultants (Geosyntec) to demonstrate compliance with the United States Environmental Protection Agency's (USEPA) Coal Combustion Residuals (CCR) Rule with respect to the periodic safety factor assessment criteria presented in 40 Code of Federal Regulations (CFR) 257.73(e). Ground motions and resulting cyclic shear stresses for the design seismic event are presented in Attachment 6 titled "Seismic Hazard Evaluation and Site Response Analysis: Ash Pond B" (Site Response Package) to the Safety Factor Assessment Report. The potential of soils to liquefy was evaluated for soil borings and cone penetration test (CPT) soundings advanced through the Ash Pond B perimeter dike based on geotechnical information collected during Geosyntec's 2013 and 2016 geotechnical subsurface investigations and an historical investigation (PCRA, 1993) for which boring logs are available. Soil borings and soundings located at the perimeter dike toe will be analyzed during an evaluation of "Unstable Areas" at a later time. Details of these investigations are discussed in Attachment 5 titled "Subsurface Stratigraphy and Material Properties: Ash Pond B" (Data Package) to the Safety Factor Assessment Report. The remainder of this Liquefaction Package presents: (i) methodology; (ii) analysis cases; (iii) input parameters; (iv) results; (v) conclusions; and (vi) references.

METHODOLOGY

Current state-of-practice procedures for evaluating the liquefaction potential of a soil were developed based on case histories of occurrences and non-occurrences of liquefaction due to past earthquakes. Occurrences (or non-occurrences) of liquefaction were determined by presence (or absence) of surface manifestations of liquefaction such as sand boils, ground cracking, slope movements, and/or flow failures. Surface manifestations were generally present if large excess pore pressures are generated during seismic loading and "liquefaction" is triggered. Therefore, if soils at a particular site are deemed not to be susceptible to liquefaction based on the state-of-practice or regulatory guidance, additional analyses such as post-liquefaction slope stability or lateral spreading are not necessary for the anticipated seismic ground motions.

It was assumed that soils classified as Organic Peat, Silt, and Clay, or a combination of these materials, are typically not liquefiable. Additionally, soils that exhibit "clay-like" behavior according to data collected during CPT soundings were also screened as not potentially liquefiable. "Clay-like"

Written by: J. McNash Date: 10/10/2016 Reviewed by: M. Zhu/G. Rix/J. Colley Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No.: 01BT

behavior was defined as a soil with a Soil Behavior Index (I_c) greater than 2.60. The interpretation of CPT soundings and the computation of I_c are discussed in the Data Package and reiterated below. If a zone of soil that was considered to be non-liquefiable by the above criteria, the soil zone was assigned a factor of safety (FS) against liquefaction triggering of 2.00. The criteria recommended by Bray and Sancio (2006) were typically applied at WGS to evaluate the susceptibility of fine-grained soils to cyclic softening. However, fine-grained soils were not typically encountered except within a few CPT soundings and representative samples were not typically collected in the vicinity of the Ash Pond B perimeter dikes. Thus, the criteria recommended by Bray and Sancio (2006) were not applicable or applied on samples collected from the Ash Pond B area.

The liquefaction analysis described below was performed based on the simplified procedure recommended by Seed and Idriss (1971) and later updated by Idriss and Boulanger (2008). Analyses were performed on both the CPT soundings and SPT borings. The methodology to compute the potential of soils to liquefy and the factor of safety against liquefaction are described below.

Cyclic Stress Ratio

The Cyclic Stress Ratio (CSR) is a measure of the shear stresses developed during an earthquake and is normalized with effective overburden stress. The CSR for a soil interval is calculated as follows:

$$CSR_{M,\sigma'_{vo}} = 0.65 \frac{\tau_{max}}{\sigma'_{vo}} \quad (1)$$

where:

$CSR_{M,\sigma'_{vo}}$ = Cyclic Stress Ratio due to an earthquake with magnitude, M;
 τ_{max} = maximum shear stress developed during an earthquake (psf); and
 σ'_{vo} = effective vertical stress (psf).

The cyclic shear stress represents the loading or demand on a soil unit during an earthquake.

Corrected Normalized CPT Sounding Interpretation

To evaluate the resistance or capacity of the soil against liquefaction, soil data must be interpreted from each boring or sounding. A discussion of the interpretation of the CPT data is provided in the Data Package, and the equations used in the interpretation are reiterated below.

The normalized cone tip resistance, Q, and friction ratio, F, were calculated by:

$$Q = \left(\frac{q_c - \sigma_{vo}}{P_a} \right) \left(\frac{P_a}{\sigma'_{vo}} \right)^n \quad (2)$$

Written by: J. McNash Date: 10/10/2016 Reviewed by: M. Zhu/G. Rix/J. Colley Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No.: 01BT

and,

$$F = \left(\frac{f_s}{q_c - \sigma_{vo}} \right) \times 100\% \quad (3)$$

where:

- q_c = measured tip resistance (tsf);
- σ_{vo} = total vertical stress (tsf);
- σ'_{vo} = effective vertical stress (tsf);
- P_a = atmospheric pressure ($P_a = 1.058$ tsf);
- n = varies from 0.5 in sands to 1.0 in clays; and
- f_s = measured sleeve friction (tsf).

It is noted that the tip resistance (q_c) measured in the field must be adjusted for pore pressure effects on the cone tip if the data collection software does not automatically account for the area ratio of the cone. This correction is discussed within the Data Package.

The soil behavior type index, I_c , as derived by Robertson and Wride (1998) is calculated by:

$$I_c = \left[(3.47 - \log(Q))^2 + (\log(F) + 1.22)^2 \right]^{0.5} \quad (4)$$

The I_c is used to compute the soil behavior type (SBT), which may be used to infer the type of soil that is present at the data collection interval.

To compute the resistance of a soil interval against liquefaction, the overburden-corrected tip resistance, q_{c1} , must be computed for a soil unit. q_{c1} can be computed as follows:

$$q_{c1} = C_N q_c \quad (5)$$

where:

- C_N = overburden correction factor = $(P_a / \sigma'_{vo})^{1.338 - 0.249(q_{c1N})^{0.264}}$;
- q_{c1N} = normalized tip resistance q_{c1} / P_a (dimensionless).

The computation of C_N was limited to a maximum value of 1.7 and is applicable for values of q_{c1N} between 21 and 254. As evident above, the computation of q_{c1} and q_{c1N} is an iterative procedure, which was performed using an algorithm developed within the MathCAD[®] computation software.

Written by: J. McNash Date: 10/10/2016 Reviewed by: M. Zhu/G. Rix/J. Colley Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No.: 01BT

Corrected Normalized SPT Blow Count

Interpretation of soil test borings and SPT blow counts is discussed within the Data Package, but is briefly reiterated below. The corrected normalized SPT blow count, $(N_1)_{60}$, which is applied in computing resistance of a soil against liquefaction, was calculated by the following equation presented by Idriss and Boulanger (2008).

$$(N_1)_{60} = N_{\text{meas}} C_E C_B C_S C_R C_N \quad (6)$$

where:

- N_{meas} = measured SPT blow count (blows/ft);
- C_E = correction factor for energy ratio;
- C_B = correction factor for borehole diameter;
- C_R = correction factor for rod length;
- C_S = correction factor for sampler; and
- C_N = correction factor for overburden pressure.

The correction factor for the applied energy (C_E) is dependent on the type and calibration of the hammer system attached to the drill rig. The correction factor (C_E) converts the measured N-value to a standard value, which assumes a 60 percent efficiency of the hammer system. This correction factor was computed as follows:

$$C_E = \frac{ER}{60} \quad (7)$$

where:

- ER = energy ratio of the SPT hammer system.

Energy ratios selected for these analyses are discussed later within this Liquefaction Package. The correction factors above (excluding C_N) are given in Table 1. C_N was calculated for $(N_1)_{60}$ values less than 46 blows per foot, as follows:

$$C_N = \left(\frac{P_a}{\sigma'_{vo}} \right)^{(0.784 - 0.0768\sqrt{(N_1)_{60}})} \quad (8)$$

where:

- P_a = atmospheric pressure (2,117 psf); and
- σ'_{vo} = effective vertical stress (psf).

Written by: J. McNash Date: 10/10/2016 Reviewed by: M. Zhu/G. Rix/J. Colley Date: 10/10/2016

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No.: **01BT**

The computation of C_N was limited to a maximum value of 1.7. As evident above, the computation of $(N_1)_{60}$ is an iterative procedure, which was performed using an algorithm developed within the MathCAD[®] computation software.

Cyclic Resistance Ratio (CRR)

The CRR is the measure of a soil's resistance to liquefaction. If the $CSR > CRR$, liquefaction is likely to occur during the analyzed seismic event. The CRR was computed from CPT sounding data based on the corrected tip resistance of clean sand for an earthquake of magnitude = 7.5 and an overburden pressure of one atmosphere, as follows:

$$CRR_{M=7.5, \sigma'_{vo}=1 \text{ atm}} = \exp\left(\frac{q_{c1Ncs}}{540} + \left(\frac{q_{c1Ncs}}{67}\right)^2 - \left(\frac{q_{c1Ncs}}{80}\right)^3 + \left(\frac{q_{c1Ncs}}{114}\right)^4 - 3\right) \quad (9)$$

Equation 9 is considered valid for the equivalent clean sand corrected tip resistance (q_{c1Ncs}) with values less than 211. For clean sands, q_{c1Ncs} , is equivalent to q_{c1N} , but for soils with some percentage of fines, $q_{c1Ncs} = q_{c1N} + \Delta q_{c1N}$, where the correction factor, Δq_{c1N} , is given by:

$$\Delta q_{c1N} = \left(5.4 + \frac{q_{c1N}}{16}\right) \times \exp\left(1.63 + \frac{9.7}{FC+0.01} - \left(\frac{15.7}{FC+0.01}\right)^2\right) \quad (10)$$

where:

FC = percent of fines (by mass) within a soil.

The CRR was computed similarly for an earthquake of magnitude, $M = 7.5$, and an overburden pressure of one atmosphere, using corrected SPT N-values, as follows:

$$CRR_{M=7.5, \sigma'_{vo}=1 \text{ atm}} = \exp\left(\frac{(N_1)_{60cs}}{14.1} + \left(\frac{(N_1)_{60cs}}{126}\right)^2 - \left(\frac{(N_1)_{60cs}}{23.6}\right)^3 + \left(\frac{(N_1)_{60cs}}{25.4}\right)^4 - 2.8\right) \quad (11)$$

For clean sands, the equivalent clean sand value of the SPT penetration resistance $(N_1)_{60cs}$, is equivalent to $(N_1)_{60}$, but for soils with some percentage of fines, $(N_1)_{60cs} = (N_1)_{60} + \Delta(N_1)_{60}$, where the correction factor, $\Delta(N_1)_{60}$, is given by:

$$\Delta(N_1)_{60} = \exp\left(1.63 + \frac{9.7}{FC+0.01} - \left(\frac{15.7}{FC+0.01}\right)^2\right) \quad (12)$$

The selected fines content (FC) values used in these computations are discussed later within this calculation package. It is noted that $\Delta(N_1)_{60}$ is limited to a maximum value of 5.5.

Written by: J. McNash Date: 10/10/2016 Reviewed by: M. Zhu/G. Rix/J. Colley Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No.: 01BT

Overburden Correction Factor

The overburden correction factor, K_{σ} , was introduced by Seed (1983) to adjust the CRR to a reference value of effective overburden stress because the CRR of sands is dependent on the effective overburden stress (Idriss and Boulanger, 2008). The recommended relationship for K_{σ} is given by:

$$K_{\sigma} = 1 - C_{\sigma} \ln \left(\frac{\sigma'_{vo}}{P_a} \right) \leq 1.1 \quad (13)$$

where:

$$C_{\sigma} = 1 / (37.3 - 8.27(q_{c1N})^{0.264}) \leq 0.3 \text{ for CPT soundings.} \quad (14)$$

and,

$$C_{\sigma} = 1 / (18.9 - 2.55((N_1)_{60})^{0.5}) \leq 0.3 \text{ for SPT borings.} \quad (15)$$

Furthermore, Equations 14 and 15 are applicable for q_{c1N} and $(N_1)_{60}$ values less than 211 and 37 blows per foot, respectively. The overburden correction factor is used in liquefaction potential computations to adjust the CRR to a common effective overburden stress as shown by the following equation:

$$CRR_{\sigma'_{vo}} = K_{\sigma} \times CRR_{\sigma'_{vo}=1 \text{ atm}} \quad (16)$$

Magnitude Scaling Factor (MSF)

The magnitude scaling factor (MSF) is applied to adjust the CRR to a common earthquake magnitude, M (conventionally selected as $M = 7.5$). For cohesionless soils, the MSF is calculated using the equation proposed by Idriss (1999):

$$MSF = 6.9 \times \exp \left(\frac{-M}{4} \right) - 0.058, \text{ and } MSF \leq 1.8 \quad (17)$$

The MSF was calculated as 1.05 for a magnitude 7.3 earthquake, which was selected based on the deaggregation of the probabilistic seismic hazard as described in the Site Response Package (Attachment 6).

The CRR for a magnitude M earthquake is calculated as follows:

$$CRR_M = MSF \times CRR_{M=7.5} \quad (18)$$

Age Correction Factor (K_{DR})

Correlations associated with liquefaction potential analysis were developed based on case histories of

Written by: J. McNash Date: 10/10/2016 Reviewed by: M. Zhu/G. Rix/J. Colley Date: 10/10/2016

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No.: **01BT**

the presence or absence of liquefaction in relatively young soil deposits (i.e., Holocene age). As described in the South Carolina Department of Transportation (SCDOT) Geotechnical Design Manual (2010), the CRR may be adjusted to account for diagenesis and other age-related effects in older soils that have not previously experienced liquefaction. Equation 13-47 within Chapter 13 of the SCDOT Geotechnical Design Manual (GDM) computes the Age Correction Factor (K_{DR}) based on its age (t in years) as:

$$K_{DR} = 0.17 \log_{10}(t) + 0.83 \quad (19a)$$

Meanwhile, Andrus et al. (2008) presents a similar equation for the K_{DR} as:

$$K_{DR} = 0.19 \log_{10}(t) + 0.68 \quad (19b)$$

It is noted that “ t ” is considered based on the “geotechnical age” instead of the “geologic age”. Geologic age is the time since initial soil deposition; whereas geotechnical age is the time since the last significant liquefaction event resulting in re-sedimentation of the soil fabric.

Next, the CRR for sand strata was further adjusted by the age correction factor to account for this aging effect, and is computed as follows.

$$CRR_{M,K} = K_{DR} \times CRR_M \quad (20)$$

Factor of Safety

Finally, the factor of safety against liquefaction (FS_{liq}) triggering for both SPT and CPT analyses was computed by:

$$FS_{liq} = \frac{CRR_{M,\sigma'_{vo},K_{dr}}}{CSR_{M,\sigma'_{vo}}} \quad (21)$$

where:

$CRR_{M,\sigma'_{vo},K_{dr}}$ = cyclic resistance ratio adjusted for earthquake magnitude, overburden, and aging;

and

$CSR_{M,\sigma'_{vo}}$ = cyclic stress ratio for the same earthquake and overburden stress.

ANALYSIS CASES

As noted previously, liquefaction potential computations were conducted on soil data collected for soil borings and CPT soundings overseen by Geosyntec in 2013 and for soil collected by Paul C. Rizzo

Written by: J. McNash Date: 10/10/2016 Reviewed by: M. Zhu/G. Rix/J. Colley Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No.: 01BT

Associates (PCRA) (1993). Computations were limited to soil borings and soundings located through the dike centerline and beneath the dike centerline.

Two representative soil profiles of shear wave velocity (V_s) were developed and presented in the Data Package from the dike crest to the Chicora stratum. These profiles were developed from direct measurements of V_s and by means of a correlation with CPT sounding data. As discussed in the Data Package, these representative V_s profiles were supplemented with historical data to extend the V_s profile into the underlying Chicora and Williamsburg Formation Clay strata during the site response analyses for Ash Pond B.

For each representative soil profile, a site response analysis, described within the Site Response Package (Attachment 6), was performed using six ground motions selected for the Site. A profile of the cyclic shear stress (τ_{max}) was computed for each ground motion and the maximum value at each depth was calculated to create a single profile of τ_{max} for each representative profile. These τ_{max} profiles were applied to compute the CSR at every depth for each soil boring or sounding. The maximum shear stress at each computed depth for each representative profile was tabulated and provided in Table 2. The τ_{max} for measurements in between depth intervals listed within Table 2 were linearly interpolated to calculate τ_{max} at every depth.

INPUT PARAMETERS

The following section describes the selection of the input parameters applied for the liquefaction potential analysis.

Total Unit Weight

The total unit weight (γ_T) of a soil interval was applied in liquefaction potential computations to calculate the total and effective stress states for the soil column for each boring and sounding analyzed. For the purpose of this analysis, CPT intervals were assigned a unit weight based on the ranges presented for soils in the region provided within the SCDOT GDM (SCDOT, 2010) and the site-specific laboratory data (Attachment 5). The assigned unit weight is dependent initial soil behavior index (I_c) as follows:

- Clays and clayey sand mixtures ($I_c > 2.95$): 100 pcf
- Silt to silty sand mixtures ($2.60 < I_c \leq 2.95$): 100 pcf
- Silty sands to sand mixtures ($2.05 < I_c \leq 2.60$): 110 pcf
- Sands ($1.31 < I_c \leq 2.05$): 120 pcf
- Gravelly sands to sands ($I_c \leq 1.31$): 125 pcf

Written by: J. McNash Date: 10/10/2016 Reviewed by: M. Zhu/G. Rix/J. Colley Date: 10/10/2016

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No.: **01BT**

SPT intervals were assigned total unit weight values based on visual and laboratory observations on the soil type as follows:

- Clays and Silts: 100 pcf
- Loose Sands ($N \leq 10$ blows/foot): 105 pcf
- Medium Dense Sands ($10 \text{ blows/foot} < N \leq 30 \text{ blows/foot}$): 115 pcf
- Dense Sands ($N \geq 30$ blows/foot): 120 pcf
- Chicora: 130 pcf
- Williamsburg Formation Clay: 105 pcf

Age Correction Factor

The susceptibility of soil deposits to liquefaction was summarized by type of deposit and geologic age by Youd and Perkins (1978), and is provided in Table 3. Youd and Perkins (1978) observed that younger soils (Holocene age) generally are the most susceptible to liquefaction. In the South Carolina (SC) region, the influence of soil age was investigated locally by Arango et al. (2009) and Andrus et al. (2008) based on cyclic strength testing of high-quality samples of sand and in-situ testing on paleoliquefaction sites, respectively. Each researcher compared observations and results in each study with the case-history-based chart for liquefaction triggering developed by Idriss and Boulanger (2008). Andrus (2008) developed a correlation (Equation 19b) relating soil age to a correction factor to CRR. Additionally, Leon et al. (2005) investigated a site nearby to WGS (Sampit, SC) and identified soil ages for sands encountered between 546 to 450,000 years old. Age Correction Factors (K_{DR}) were computed for the range of soil ages observed in the region presented by Leon et al. (2005), and are provided in Table 4 based on Equations 19a and 19b. A K_{DR} was selected from Table 4 and applied to soils in the vicinity of the Ash Pond B perimeter dikes that were evaluated to be of geologic and geotechnical ages older than Holocene age (i.e., foundation soils).

As shown in Figure 1, soils immediately surrounding Ash Pond B perimeter dikes were determined by the SC Department of Natural Resources (2012) to be of Pleistocene age. It was assumed that these soils are located beneath the recompacted dike fill soils, which are considered to be of Holocene age due to the relatively “recent” construction. Based on the range of soil ages presented in Table 4, an age correction factor of 1.30 was selected for Pleistocene-aged, foundation soils at WGS. Dike base elevations were approximated based on the surface elevation of borings or soundings located at the dike toe or the prevailing ground surface elevation of the Cooling Pond. Boring information and the top of foundation soil elevation (or dike base elevation) are summarized within Table 5 of this Liquefaction Package. An age correction factor of 1.00 was applied for dike fill soils, as these structures are approximately 30 to 40 years old. As noted previously, “geologic” age differs from “geotechnical” age. Geologic age refers to the overall age of the soil since deposition. Geotechnical

Written by: J. McNash Date: 10/10/2016 Reviewed by: M. Zhu/G. Rix/J. Colley Date: 10/10/2016

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No.: **01BT**

age refers to the age of the soil since the last instance of liquefaction. The geotechnical age was considered in the selection of K_{DR} .

Fines Content

As shown in Equations 9 through 12, the Cyclic Resistance Ratio (CRR) is influenced by the fines content (% particles by mass passing a No. 200 sieve) of the soil interval. An increase in fines content of the soil results in higher resistance to liquefaction. As shown in the Attachment 5, fines content data of dike fill and foundation soils is somewhat variable across the Ash Pond B footprint. Physical samples are not collected during CPT soundings and historical borings with laboratory index testing are not currently available. As it is considered impractical to collect index testing (and fines content data) on every soil sample or soil interval, the index test data was applied to each CPT sounding based on the data collected from the nearest available soil boring with laboratory index testing, as provided in Attachment 5. Index testing, when available, for soil borings were utilized for each individual SPT N-value. The source of the select fines content for each investigation point is summarized within Table 5.

Phreatic Surface

The phreatic surface through the perimeter dikes to the downstream toe of the dike at the time of this Liquefaction Package was developed for each individual boring or CPT sounding based on depth to water measurements, porewater pressure (u_0) signatures, and dissipation tests. Phreatic surface assumptions through the Ash Pond B perimeter dikes at the time of the boring (TOB) and at the time of analysis (TOA) for this calculation package are also summarized in Table 5.

Energy Calibration for SPT N-Values

As described in the Data Package, the subcontractor during Geosyntec's 2013 investigation, Soil Consultants, Inc. (SCI), reported that the automatic hammer on the utilized drilling rig had an energy ratio of 89 percent, which was independently evaluated within six months of the investigation. Borings performed by Mid Atlantic Drilling, Inc. along the perimeter dikes (SPT-309 and SPT-310) in 2016 utilized a drilling rig with an energy ratio of 77.2% (Attachment 5).

Historical Borings

Liquefaction potential of dike fill soils was evaluated using data provided within a PCRA design report including boring logs, which evaluated the raising of the Ash Pond B dikes (PCRA, 1993). As stated previously, correlations developed to predict the potential of soils to liquefy are based on empirical observations using a standard procedure or method during drilling activities. PCRA (1993) boring logs

Written by: J. McNash Date: 10/10/2016 Reviewed by: M. Zhu/G. Rix/J. Colley Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No.: 01BT

indicate that the 4-inch inner diameter, hollow stem auger borings were advanced by a CME-55 drilling rig equipped with rope and cathead hammer. It was assumed that the rope and cathead hammer system contained an energy ratio of 70 percent, and was applied for Borings B-1 through B-6.

RESULTS

The methodology discussed previously was applied within a MathCAD[®] algorithm similar to the spreadsheets presented in Idriss and Boulanger (2008). Computations were performed on soil borings and soundings (including the historical borings) located at the dike centerline. The factor of safety against liquefaction (FS_{liq}) was computed at every depth interval where data was collected for soil test borings (in 2-ft or 5-ft intervals) and CPT soundings (in 0.16-ft intervals). The computed FS against liquefaction triggering for the soil borings and CPT soundings and the approximate base of the perimeter dike structure, which was developed from historical drawings, are shown in Figures 2 through 6. Figure 2 shows SPT-121, CPT-310, and B-6, which are located in the northwest corner of the Ash Pond B immediately south of the divider dike. Subsequent figures depict calculation results for soil borings and CPT soundings positioned progressively in a counter-clockwise direction around the surface impoundment. Example calculations are provided within Appendix 1.

The liquefaction potential calculation results can be generally summarized as follows:

- The computed FS_{liq} typically exceeded 2.0 within dike fill and foundation soils immediately below the Ash Pond B perimeter dikes.
- When present in CPT-150 and CPT-310, the computed FS_{liq} in the west Ash Pond B perimeter dikes ranged between 1.5 and 1.8 (when not greater than 2.0) between elevations 0.0 ft and 10.0 ft NGVD29.
- When present in CPT-135 and CPT-136, the computed FS_{liq} for thin seams of looser soil within the foundation soils of the east Ash Pond B perimeter dikes adjacent to the Cooling Pond ranged between 1.4 and 1.5 (when not greater than 2.0) between elevations 0.0 ft and 20.0 ft NGVD29. These isolated seams were typically less than 1-ft thick.
- The FS_{liq} computed from SPTs within soil borings and from CPT soundings were found to be generally consistent between investigation points adjacently located (i.e., lower FS_{liq} computed at SPT-310 and CPT-150 at similar elevations).

CONCLUSIONS

Based the liquefaction potential computations presented within this calculation package, liquefiable

Written by: J. McNash Date: 10/10/2016 Reviewed by: M. Zhu/G. Rix/J. Colley Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No.: 01BT

soils were not observed in the dike fill soils (i.e., native soils recompacted to form impounding perimeter dikes) or foundation soils beneath the perimeter dikes of the Ash Pond B. Soil borings and CPT soundings advanced at the downstream toe of the Ash Pond B perimeter dikes were not evaluated within this calculation package and will be included during an evaluation of “Unstable Areas” for the Ash Pond B. Since liquefiable zones were not identified for borings and CPT soundings advanced through the perimeter dikes within the dike fill or foundation soils beneath the perimeter dikes, additional post-liquefaction stability and displacement analyses are not warranted for the Ash Pond B perimeter dikes at this time.

REFERENCES

- Andrus, R. Gassman, S. L., Talwani, P., Hasek, M., Camp, W. Hayati, H., and Boller, R. (2008), “Characterization of Liquefaction Resistance of Aged Soils: Summary of Selected First Year Findings”, *Proceedings of 2008 NSF Engineering Research and Innovation Conference, Knoxville, Tennessee*, NSF Grant # CMS-0556006.
- Arango, I., Lewis, M. R., and McHood, M. D. (2009), “Site Characterization Philosophy and Liquefaction Evaluation of Aged Sands”, *Bechtel Technology Journal*, Vol. 2, No. 1.
- Bray, J.D. and Sancio, R.B. (2006) “Assessment of the Liquefaction Susceptibility of Fine-Grained Soils”. *Journal of Geotechnical and Geoenvironmental Engineering*, 132 (9), 1165-1177.
- Idriss, I. M. (1999), “An update to the Seed-Idriss simplified procedure for Evaluating Liquefaction Potential, in *Proceedings, TRB Workshop on New Approaches to Liquefaction*” Publication No. FHWA-RD-99-165, Federal Highway Administration.
- Idriss, I. M. and Boulanger, R. W. (2008), “Soil Liquefaction During Earthquakes”, *Earthquake Engineering Research Institute*, EERI Publication MNO-12.
- Leon, E., Gassman, S. L., and Talwani, P. (2005), “Effect of Soil Aging on Assessing Magnitudes and Accelerations of Prehistoric Earthquakes”, *Earthquake Spectra*, Vol. 21, No. 3 pg. 737-759.
- Paul C. Rizzo Associates, Inc. (1993), “Report: Ash Pond B Dike Elevation: Winyah Generating Station”, December 1993.
- Robertson, P.K. and Wride, C.E. (1998), “Evaluating cyclic liquefaction potential using the cone penetration test, *Canadian Geotechnical Journal*, Volume 35, No. 3, pp. 442-59.
- Seed, H.B. (1983), “Earthquake Resistant Design of Earth Dams”, in *Proceedings, Symposium of Seismic Design of Embankments and Caverns, Pennsylvania*, ASCE, NY, pp. 41-64.

Written by: **J. McNash** Date: **10/10/2016** Reviewed by: **M. Zhu/G. Rix/J. Colley** Date: **10/10/2016**

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No.: **01BT**

Seed, H.B, and Idriss, I.M. (1971), “Simplified Procedure for Evaluation Soil Liquefaction Potential”, *Journal of the Soil Mechanics and Foundations Division*, ASCE, Vol. 107, NO. SM9.

South Carolina Department of Transportation (2010), “SCDOT Geotechnical Design Manual: Chapter 13: Geotechnical Seismic Hazards”.

South Carolina Department of Natural Resources: Geologic Survey (2012), “Geologic Map of the Georgetown South Quadrangle, Georgetown County, South Carolina”.

Youd, T. L. and Perkins, M. (1978), “Mapping liquefaction-induced ground failure potential”, *J. Geotechnical Eng. Div.*, ASCE 104(GT4), 433-46.

Written by: **J. McNash** Date: **10/10/2016** Reviewed by: **M. Zhu/G. Rix/J. Colley** Date: **10/10/2016**

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No.: **01BT**

TABLES

Written by: J. McNash Date: 10/10/2016 Reviewed by: M. Zhu/G. Rix/J. Colley Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No.: 01BT

Table 1. Correction Factors for Interpretation of SPT for Liquefaction Potential Analysis
(Idriss and Boulanger, 2008)

Factor	Description										
Energy ratio	<p>Energy measurements are required to determine the delivered energy ratios or to calibrate the specific equipment being used. The correction factor is then computed as</p> $C_E = \frac{ER_m}{60}$ <p>where ER_m is the measured energy ratio as a percentage of the theoretical maximum.</p> <p>Empirical estimates of C_E (for rod lengths of 10 m or more) involve considerable uncertainty, as reflected by the following ranges:</p> <table> <tr> <td>Doughnut hammer</td> <td>$C_E = 0.5-1.0$</td> </tr> <tr> <td>Safety hammer</td> <td>$C_E = 0.7-1.2$</td> </tr> <tr> <td>Automatic triphammer</td> <td>$C_E = 0.8-1.3$</td> </tr> </table> <p>(Seed et al. 1984, Skempton 1986, NCEER 1997)</p>	Doughnut hammer	$C_E = 0.5-1.0$	Safety hammer	$C_E = 0.7-1.2$	Automatic triphammer	$C_E = 0.8-1.3$				
Doughnut hammer	$C_E = 0.5-1.0$										
Safety hammer	$C_E = 0.7-1.2$										
Automatic triphammer	$C_E = 0.8-1.3$										
Borehole diameter	<table> <tr> <td>Borehole diameter of 65–115 mm</td> <td>$C_B = 1.0$</td> </tr> <tr> <td>Borehole diameter of 150 mm</td> <td>$C_B = 1.05$</td> </tr> <tr> <td>Borehole diameter of 200 mm</td> <td>$C_B = 1.15$</td> </tr> </table> <p>(Skempton 1986)</p>	Borehole diameter of 65–115 mm	$C_B = 1.0$	Borehole diameter of 150 mm	$C_B = 1.05$	Borehole diameter of 200 mm	$C_B = 1.15$				
Borehole diameter of 65–115 mm	$C_B = 1.0$										
Borehole diameter of 150 mm	$C_B = 1.05$										
Borehole diameter of 200 mm	$C_B = 1.15$										
Rod length	<p>Where the ER_m is based on rod lengths of 10 m or more, the ER delivered with shorter rod lengths may be smaller. Recommended values from Youd et al. (2001) are as follows:</p> <table> <tr> <td>Rod length < 3 m</td> <td>$C_R = 0.75$</td> </tr> <tr> <td>Rod length 3–4 m</td> <td>$C_R = 0.80$</td> </tr> <tr> <td>Rod length 4–6 m</td> <td>$C_R = 0.85$</td> </tr> <tr> <td>Rod length 6–10 m</td> <td>$C_R = 0.95$</td> </tr> <tr> <td>Rod length 10–30 m</td> <td>$C_R = 1.00$</td> </tr> </table>	Rod length < 3 m	$C_R = 0.75$	Rod length 3–4 m	$C_R = 0.80$	Rod length 4–6 m	$C_R = 0.85$	Rod length 6–10 m	$C_R = 0.95$	Rod length 10–30 m	$C_R = 1.00$
Rod length < 3 m	$C_R = 0.75$										
Rod length 3–4 m	$C_R = 0.80$										
Rod length 4–6 m	$C_R = 0.85$										
Rod length 6–10 m	$C_R = 0.95$										
Rod length 10–30 m	$C_R = 1.00$										
Sampler	<p>Standard split spoon without room for liners (the inside diameter is a constant $1\frac{3}{8}$ in.), $C_S = 1.0$.</p> <p>Split-spoon sampler with room for liners but with the liners absent (this increases the inside diameter to $1\frac{1}{2}$ in. behind the driving shoe):</p> $C_S = 1.1 \quad \text{for } (N_1)_{60} \leq 10$ $C_S = 1 + \frac{(N_1)_{60}}{100} \quad \text{for } 10 \leq (N_1)_{60} \leq 30$ $C_S = 1.3 \quad \text{for } (N_1)_{60} \geq 30$ <p>(from Seed et al. 1984, equation by Seed et al. 2001)</p>										

Written by: J. McNash Date: 10/10/2016 Reviewed by: M. Zhu/G. Rix/J. Colley Date: 10/10/2016

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No.: **01BT**

Table 2. Summary of Representative Profiles for the Dike Centerline

Profile 1		Profile 2	
Depth (ft)	τ_{max} (psf)	Depth (ft)	τ_{max} (psf)
1.5	23.0	1.5	20.0
5	62.4	5	60.0
9	93.8	9	90.0
13	119.4	13	112.9
16	140.3	17	138.5
19.5	164.0	20.5	162.5
24.5	188.6	24.5	187.6
29.5	202.8	29.5	205.0
34.5	212.8	34.5	214.9
39.5	221.0	39.5	222.4
44.5	231.1	44.5	232.6
49.5	295.2	49.5	289.7
57	380.8	57	378.5
67	462.0	67	463.2
77	551.4	77	564.4
87	659.4	87	672.9
97	779.4	97	794.9
107	936.7	107	944.1

Notes:

1. Profile 1 refers to the perimeter dikes adjacent to the Discharge Canal; while Profile 2 refers to the perimeter dikes adjacent to the Cooling Pond. Development of each profile is discussed within the Site Response Package provided as Attachment 6.
2. For calculation points located in between the depth intervals listed above, the average τ_{max} was linearly interpolated for liquefaction potential computations.

Written by: J. McNash Date: 10/10/2016 Reviewed by: M. Zhu/G. Rix/J. Colley Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No.: 01BT

Table 3. Susceptibility of Soil Deposits to Liquefaction during Strong Seismic Shaking (Youd and Perkins, 1978)

Type of deposit	Distribution of cohesionless sediments in deposit	Likelihood that cohesionless sediments, when saturated, would be susceptible to liquefaction			
		< 500 years	Holocene	Pleistocene	Pre-Pleistocene
Continental					
River channel	Locally variable	Very high	High	Low	Very low
Floodplain	Locally variable	High	Moderate	Low	Very low
Alluvial fan and plains	Widespread	Moderate	Low	Low	Very low
Marine terraces and plains	Widespread	—	Low	Very low	Very low
Delta and fan delta	Widespread	High	Moderate	Low	Very low
Lacustrine and playa	Variable	High	Moderate	Low	Very low
Colluvium	Variable	High	Moderate	Low	Very low
Talus	Widespread	Low	Low	Very low	Very low
Dunes	Widespread	High	Moderate	Low	Very low
Loess	Variable	High	High	High	Unknown
Glacial till	Variable	Low	Low	Very low	Very low
Tuff	Rare	Low	Low	Very low	Very low
Tephra	Widespread	High	High	?	?
Residual soils	Rare	Low	Low	Very low	Very low
Sebkha	Locally variable	High	Moderate	Low	Very low
Coastal zone					
Delta	Widespread	Very high	High	Low	Very low
Estuarine	Locally variable	High	Moderate	Low	Very low
Beach—high wave energy	Widespread	Moderate	Low	Very low	Very low
Beach—low wave energy	Widespread	High	Moderate	Low	Very low
Lagoonal	Locally variable	High	Moderate	Low	Very low
Foreshore	Locally variable	High	Moderate	Low	Very low
Artificial fill					
Uncompacted fill	Variable	Very high	—	—	—
Compacted fill	Variable	Low	—	—	—

Written by: J. McNash Date: 10/10/2016 Reviewed by: M. Zhu/G. Rix/J. Colley Date: 10/10/2016

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No.: **01BT**

Table 4. Age Correction Factor (K_{DR}) based on Soil Age

Soil Age, t (years)	$K_{DR}^{[1]}$	$K_{DR}^{[2]}$
126	1.19	1.08
546	1.30	1.20
5,038	1.46	1.38
10,000	1.51	1.44
450,000	1.79	1.75

Notes:

1. K_{DR} computed by SCDOT Geotechnical Design Manual (SCDOT, 2010), as provided in Equation 19a.
2. K_{DR} computed by Andrus et al (2008) as provided in Equation 19b.

Written by: J. McNash Date: 10/10/2016 Reviewed by: M. Zhu/G. Rix/J. Colley Date: 10/10/2016

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No.: **01BT**

Table 5. Summary of Soil Borings and Soundings Analyzed for Liquefaction Potential

Borehole ID	Northing	Easting	Elevation	Dike Bottom Elevation	Dike Bottom Basis	GWT EL. at TOB	GWT Depth at TOB	FC Basis	τ_{max} Profile
-	ft	ft	ft	ft	-	ft	ft	-	-
B-1	546477.391	2504902.240	33.6	19.0	Cooling Pond	22.6	11.0	SPT-115	Profile 2
B-2	545661.804	2504880.619	33.7	19.0	Cooling Pond	20.7	13.0	SPT-115	Profile 2
B-3	544942.310	2504538.289	33.8	19.0	Cooling Pond	20.8	13.0	SPT-309	Profile 2
B-4	544316.506	2503866.841	33.8	19.0	Cooling Pond	21.8	12.0	SPT-114	Profile 2
B-5	544537.519	2503500.488	34.3	23.7	CPT-151	22.3	12.0	SPT-114	Profile 1
B-6	545106.869	2503448.838	33.8	23.7	CPT-151	23.8	10.0	SPT-310	Profile 1
CPT-135	545352.802	2504767.509	40.47	19.0	Cooling Pond	25.9	14.6	SPT-309	Profile 2
CPT-136	546698.537	2504910.337	40.62	19.0	Cooling Pond	25.0	15.6	SPT-115	Profile 2
CPT-150	544581.748	2503504.849	40.93	23.7	CPT-151	25.9	15.0	SPT-114	Profile 1
CPT-151	544573.985	2503440.909	23.73	-	-	-	-	-	-
CPT-225	2503931.22	544347.422	24.00	-	-	-	-	-	-
CPT-226	545328.105	2504766.372	39.69	19.0	Cooling Pond	23.7	16.0	SPT-309	Profile 2
CPT-227	546414.575	2504926.725	39.97	19.0	Cooling Pond	28.0	12.0	SPT-115	Profile 2
SPT-114	544064.630	2503599.466	41.48	19.0	Cooling Pond	22.4	19.1	SPT-114	Profile 2
SPT-115	545998.280	2504990.830	40.90	19.0	Cooling Pond	25.9	15.0	SPT-115	Profile 2
SPT-121	546076.868	2503720.319	40.82	27.5	CPT-148	29.3	11.5	SPT-121	Profile 1
SPT-309	544483.417	2504245.349	40.47	19.0	Cooling Pond	26.4	14.1	SPT-309	Profile 2
SPT-310	545170.553	2503412.955	38.73	23.7	CPT-151	29.6	9.1	SPT-310	Profile 1

Notes:

1. ft NGVD29 - feet National Geodetic Vertical Datum of 1929; TOB - Time of Boring; GWT - Groundwater Table; FC - Fines Content.
2. Dike bottom elevation was estimated based on the elevation of the nearest toe boring/sounding or the Cooling Pond (19.0 ft NGVD29).
3. Elevations provided are in ft NGVD29.
4. Borings B-1 through B-6 were conducted in 1993 by PCRA to design the raising of dike structures. It was assumed that the dike was raised to the elevation of the nearest SPT-series or CPT-series boring performed recently. It was also assumed that the depth to groundwater was similar to that of a nearby boring or sounding at the time of analysis.
5. Borings performed in the interior of Ash Pond B (SPT-122 and CPT-152 through CPT-154; CPTs-221 through CPT-224) were not evaluated for liquefaction potential as they are distanced from the perimeter dikes.
6. CPT-151 and CPT-225 were not evaluated as they are situated at the downstream toe of the perimeter dike structures.
7. FC Basis refers to the source of the fines content profile for each investigation point. Fines content data is provided within the Data Package (Attachment 5).


Written by: **J. McNash** Date: **10/10/2016** Reviewed by: **M. Zhu/G. Rix/J. Colley** Date: **10/10/2016**

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No.: **01BT**

FIGURES

Written by: J. McNash Date: 10/10/2016 Reviewed by: M. Zhu/G. Rix/J. Colley Date: 10/10/2016

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No.: **01BT**



QPpm Estuarine deposits or marine deposits or both (Pleistocene) – In its lower part, quartz and phosphatic sand, medium bluish-gray (5B 5/1), poorly sorted, subrounded to very angular, fine to very coarse grained with trace amounts of very fine grained heavy minerals. Lower part 10 to 20 feet thick. In upper part, muddy sand to sandy mud, clay, silt, silty sand, clayey sand, phosphatic sand and quartz sand and shells, medium light-gray (N6) to medium bluish-gray (5B 5/1). Some zones contain broken and intact *Oliva*, *Polinices*, *Terebra*, *Mercenaria* and *Dosinia*. Upper part 1 to 10 feet thick.

Figure 1. Geologic Map of Areas Surrounding Ash Pond B
(Map taken from SC Department of Natural Resources: Geological Survey, 2012)

Written by: J. McNash Date: 10/10/2016 Reviewed by: M. Zhu/G. Rix/J. Colley Date: 10/10/2016

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No.: **01BT**




Figure 2. Liquefaction Results for Dike and Foundation Soils for SPT-121, SPT-310, and B-6

Notes:

1. Foundation soils were assumed to begin at the dike bottom, which was selected based on the top of boring of CPT-148 for SPT-121, and CPT-151 for SPT-310 and B-6, as provided in Table 5.
2. Soil boring B-6 (PCRA, 1993) was not advanced to refusal at the top of the Chicora stratum.

Written by: J. McNash Date: 10/10/2016 Reviewed by: M. Zhu/G. Rix/J. Colley Date: 10/10/2016

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No.: **01BT**




Figure 3. Liquefaction Results for Dike and Foundation Soils for CPT-150, B-5, and SPT-114

Notes:

1. Foundation soils were assumed to begin at the dike bottom for CPT-150 and B-5, which was selected based on the surface elevation of toe sounding CPT-151; while, the dike bottom for SPT-114 was selected based on the ground surface elevation of the Cooling Pond, as provided in Table 5.
2. Soil boring B-5 (PCRA, 1993) was not advanced to refusal at the top of the Chicora stratum.

Written by: J. McNash Date: 10/10/2016 Reviewed by: M. Zhu/G. Rix/J. Colley Date: 10/10/2016

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No.: **01BT**




Figure 4. Liquefaction Results for Dike and Foundation Soils for B-4, SPT-309 and B-3

Notes:

1. Foundation soils were assumed to begin at the dike bottom, which was selected based on the surface elevation of the Cooling Pond, as provided in Table 5.
2. Soil boring B-4 and B-3 (PCRA, 1993) were not advanced to refusal at the top of the Chicora stratum.

Written by: J. McNash Date: 10/10/2016 Reviewed by: M. Zhu/G. Rix/J. Colley Date: 10/10/2016

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No.: **01BT**




Figure 5. Liquefaction Results for Dike and Foundation Soils for CPT-135, B-2, and SPT-115

Notes:

1. Foundation soils were assumed to begin at the dike bottom which was selected based on the surface elevation of the Cooling Pond, as provided in Table 5.
2. Soil boring B-2 (PCRA, 1993) was not advanced to refusal at the top of the Chicora stratum.
3. CPT-135 and CPT-226 were plotted together as the two locations are positioned within 50-ft of each other.

Written by: J. McNash Date: 10/10/2016 Reviewed by: M. Zhu/G. Rix/J. Colley Date: 10/10/2016

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No.: **01BT**




Figure 6. Liquefaction Results for Dike and Foundation Soils for CPT-227, B-1, and CPT-136

Note:

1. Foundation soils were assumed to begin at the dike bottom which was selected based on the surface elevation of the Cooling Pond, as provided in Table 5.
2. Soil boring B-1 (PCRA, 1993) was not advanced to refusal at the top of the Chicora stratum.

Written by: **J. McNash** Date: **10/10/2016** Reviewed by: **M. Zhu/G. Rix/J. Colley** Date: **10/10/2016**

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No.: **01BT**

Appendix 1

MathCAD[®] Example Calculation

CPT - based Liquefaction Analysis

BoringID := "CPT_135"

Site Parameters:

Age Correction Factor of Pleistocene Soils:

$K_{dr} := 1.3$

Earthquake Magnitude:

$M := 7.3$

Site Response Profile:

Prof := "Profile2"

CyclicStress := $\begin{cases} \text{READEXCEL}(\text{"APB_Profile_1.xlsx"}) & \text{if Prof = "Profile1"} \\ \text{READEXCEL}(\text{"APB_Profile_2.xlsx"}) & \text{if Prof = "Profile2"} \end{cases}$

Defining external units:

CPT-Specific data:

Import the CPT-Specific Data in the form of Depth, tip resistance (tsf), sleeve friction (tsf), porepressure (tsf), and fines content profile (%) with headers and units:

Full := READEXCEL(concat(BoringID, ".xlsx"))

Data := submatrix(Full, 2, rows(Full) - 1, 0, cols(Full) - 1)

depth := Data⁽⁰⁾ · ft qc := Data⁽¹⁾ · tsf $f_s := \text{Data}^{(2)}$ tsf $u_2 := \text{Data}^{(3)}$ tsf Fines := Data⁽⁴⁾

Simple counter used in the Algorithm: $i := 0.. \text{rows}(\text{Data}) - 1$

Tip net area ratio:

$a := 1$

Correction applied when converting Hogentogler Data (.cpt) to Excel (.xls) format.

Boring Information Inputs:

Boring Elevation: $\text{Elevation} := 40.47\text{ft}$ NGVD 29

Groundwater Depth at Time of Boring (TOB): $\text{GWT}_b := 14.55\text{ft}$ bgs

Bottom of Holocene Elevation / Bottom of
Dike Fill Soils:

$\text{Elev}_h := 19.0\text{ft}$ NGVD 29

Sounding elevation profile:

Elev := Elevation - depth

Initial Total Unit Weight Assignments

Initial Unit Weight Estimates to be used with Robertson and Campanella (1983):

Adjust according to specific site conditions

1. Sand	$\gamma_1 := 115\text{pcf}$
2. Silty Sand	$\gamma_2 := 105\text{pcf}$
3. Sandy silt and silt	$\gamma_3 := 100\text{pcf}$
4. Silty clay/Clayey silt	$\gamma_4 := 90\text{pcf}$
5. Clay	$\gamma_5 := 90\text{pcf}$
Water	$\gamma_{\text{water}} := 62.4\text{pcf}$

Tip resistance back calculated from q_t and tip net area ratio a provided in the original data:

$$q_{t_i} := q_{c_i} - (1 - a) \cdot u_{2_i}$$

Average friction ratio:

$$Rf_i := \left(\frac{f_{s_i}}{q_{t_i}} \right) \cdot 100\%$$

Initial Total Unit Weight Assignments

Robertson and Campanella 1983 Plot data:

Extract Robertson (1983) plot lines based on values extracted from original plot:

<i>sand-silty sand</i>	S01 := submatrix(READPRN("Robertson1983.txt"), 0, 11, 0, 1)
<i>silty sand-silts</i>	S02 := submatrix(READPRN("Robertson1983.txt"), 0, 12, 2, 3)
<i>silts-silty clay</i>	S03 := submatrix(READPRN("Robertson1983.txt"), 0, 18, 4, 5)
<i>clay</i>	S04 := submatrix(READPRN("Robertson1983.txt"), 0, 19, 6, 7)

Linear interpolation used to evaluate Q_t as a function of depth based on plot lines:

$$\begin{aligned} s01(x) &:= \text{linterp}(S01^{(0)}, S01^{(1)}, x) & s02(x) &:= \text{linterp}(S02^{(0)}, S02^{(1)}, x) \\ s03(x) &:= \text{linterp}(S03^{(0)}, S03^{(1)}, x) & s04(x) &:= \text{linterp}(S04^{(0)}, S04^{(1)}, x) \end{aligned}$$

Rough estimate (initial guess) of unit weight based on Robertson 1983 soil classification:

$$\text{class}_{1983} := \left| \begin{array}{l} \text{for } i \in 0 \dots \text{rows}(qt) - 1 \\ \text{class}_i \leftarrow 5 \\ \text{class}_i \leftarrow 4 \text{ if } \frac{qt_i}{100 \cdot \text{kPa}} \geq s04(Rf_i) \\ \text{class}_i \leftarrow 3 \text{ if } \frac{qt_i}{100 \cdot \text{kPa}} \geq s03(Rf_i) \\ \text{class}_i \leftarrow 2 \text{ if } \frac{qt_i}{100 \cdot \text{kPa}} \geq s02(Rf_i) \\ \text{class}_i \leftarrow 1 \text{ if } \frac{qt_i}{100 \cdot \text{kPa}} \geq s01(Rf_i) \\ \text{class} \end{array} \right.$$

$$\gamma_l := \left| \begin{array}{l} \text{for } i \in 0 \dots \text{rows}(qt) - 1 \\ \text{for } m \in 1 \dots 5 \\ \gamma_l^i \leftarrow \gamma_m \text{ if } \text{class}_{1983}_i = m \\ \gamma_l \end{array} \right.$$

▣ Extract Robertson (1983) plot lines based on values extracted from original plot:

Refined soil classification using Robertson and Cabal 2010:

▣ Calculation of Robertson (1990) plot parameters

Calculating Static Pore Pressures at time of Sounding:

$$u_{0_i} := \left| \begin{array}{l} (\text{depth}_i - \text{GWT}_b) \cdot \gamma_{\text{water}} \text{ if } \text{depth}_i > \text{GWT}_b \\ 0 \text{ otherwise} \end{array} \right.$$

Calculating Total and Effective Overburden Pressure

$$\sigma_{v0_i} := \left| \begin{array}{l} (\text{depth}_i - \text{depth}_{i-1}) \cdot \left(\frac{\gamma_l^i + \gamma_l^{i-1}}{2} \right) + \sigma_{v0_{i-1}} \text{ if } i > 0 \\ \text{depth}_i \cdot \gamma_{l_0} \text{ otherwise} \end{array} \right. \quad \sigma_{v0\text{eff}_i} := \sigma_{v0_i} - u_{0_i}$$

$$Q_{t_i} := \frac{qt_i - \sigma_{v0_i}}{\sigma_{v0\text{eff}_i}} \quad B_{q_i} := \frac{u_{2_i} - u_{0_i}}{qt_i - \sigma_{v0_i}} \quad F_{r_i} := \frac{f_{s_i}}{qt_i - \sigma_{v0_i}} \cdot 100$$

▣ Calculation of Robertson (1990) plot parameters

Unit weight values to be assigned to Robertson (1990) classification:

Unit weight adjusted to according to specific site conditions:

- | | |
|-----------------------------------|--------------------------------------|
| 1. Sensitive, fine grained | $\hat{\gamma}_{u1} := 85\text{pcf}$ |
| 2. Organic Soils-peat to Clay | $\hat{\gamma}_{u2} := 100\text{pcf}$ |
| 3. Clay mixtures | $\hat{\gamma}_{u3} := 100\text{pcf}$ |
| 4. Silt mixtures | $\hat{\gamma}_{u4} := 100\text{pcf}$ |
| 5. Sand mixtures | $\hat{\gamma}_{u5} := 110\text{pcf}$ |
| 6. Sands | $\hat{\gamma}_{u6} := 120\text{pcf}$ |
| 7. Gravelly sand to sand | $\hat{\gamma}_{u7} := 125\text{pcf}$ |
| 8. Very stiff sand to clayey sand | $\hat{\gamma}_{u8} := 105\text{pcf}$ |
| 9. Very stiff fine grained | $\hat{\gamma}_{u9} := 105\text{pcf}$ |

▣ Refined soil classification and assigning unit weights

Compute Soil Behavior Index (I_c) corresponding to initial unit weight classification:

$$I_{c_i} := \left[\left(3.47 - \log(Q_{t_i}) \right)^2 + \left(\log(F_{r_i}) + 1.22 \right)^2 \right]^{0.5}$$

Soil classification routine for Robertson (2010) (updated from Robertson, 1990) plot:

```
class2010 := | for i ∈ 0..rows(Qt) - 1
               | classi ← 2
               | classi ← 3 if 2.95 < Ici ≤ 3.6
               | classi ← 4 if 2.60 < Ici ≤ 2.95
               | classi ← 5 if 2.05 < Ici ≤ 2.60
               | classi ← 6 if 1.31 < Ici ≤ 2.05
               | classi ← 7 if Ici ≤ 1.31
               | class
```

Assigning unit weight based on soil classification:

```
γfm := | for i ∈ 0..rows(Qt) - 1
           | for m ∈ 1..9
           | γi ← γm if class2010i = m
           | γ2
```

▣ Refined soil classification and assigning unit weights

▣ Applying Robertson (2010) values for remaining calculations:

$$\gamma_i := \gamma_{fin} \quad \text{class} := \text{class}_{2010}$$

Final Static Pore Pressure Calculation for CPT interpretation:

$$u_{0i} := \begin{cases} (\text{depth}_i - \text{GWT}_b) \cdot \gamma_{\text{water}} & \text{if } \text{depth}_i > \text{GWT}_b \\ 0 & \text{otherwise} \end{cases}$$

Total and Effective Overburden Pressure Final Calculation for CPT interpretation:

$$\sigma_{v0i} := \begin{cases} (\text{depth}_i - \text{depth}_{i-1}) \cdot \left(\frac{\gamma_i + \gamma_{i-1}}{2} \right) + \sigma_{v0_{i-1}} & \text{if } i > 0 \\ \text{depth}_0 \cdot \gamma_0 & \text{otherwise} \end{cases} \quad \sigma_{v0eff_i} := \sigma_{v0_i} - u_{0_i}$$

$$Q_i := \frac{qt_i - \sigma_{v0_i}}{\sigma_{v0eff_i}} \quad B_{r_i} := \frac{u_{2_i} - u_{0_i}}{qt_i - \sigma_{v0_i}} \quad F_{r_i} := \frac{f_{s_i}}{qt_i - \sigma_{v0_i}} \cdot 100$$

$$Q_i := \frac{qt_i - \sigma_{v0_i}}{\sigma_{v0eff_i}}$$

Recompute Soil Behavior Index (I_c) corresponding to final unit weight classification:

$$I_{c_i} := \left[\left(3.47 - \log(Q_{t_i}) \right)^2 + \left(\log(F_{r_i}) + 1.22 \right)^2 \right]^{.5}$$

▣ Applying Robertson (2010) values for remaining calculations:

Corrected Normalized CPT Sounding:

Overburden corrected tip resistance calculations

Overburden corrected tip resistance:

$$\begin{aligned}
 q_{c1_it} := & \left[\begin{array}{l} c \leftarrow 0 \\ \text{"initial CN"} \\ \text{for } i \in 0 \dots \text{rows}(qt) - 1 \\ \quad C_{N_i} \leftarrow 1.7 \\ \text{for } i \in 0 \dots \text{rows}(qt) - 1 \\ \quad \left[\begin{array}{l} \text{while } c < 500 \\ \quad q_{c1_i} \leftarrow C_{N_i} \cdot qt_i \\ \quad q_{c1N_i} \leftarrow \frac{q_{c1_i}}{1 \text{ atm}} \\ \quad C_{N_i} \leftarrow \min \left[1.7, \left(\frac{1 \text{ atm}}{\sigma_{v0eff_i}} \right)^{1.338 - 0.249 \cdot \left(\max(21, \min(q_{c1N_i}, 254)) \right)^{0.264}} \right] \\ \quad c \leftarrow c + 1 \\ \quad c \leftarrow 0 \end{array} \right] \\ \left(\begin{array}{l} q_{c1} \\ \text{psf} \quad q_{c1N} \end{array} \right) \end{array} \right] \\
 q_{c1} := & \left(q_{c1_it} \right)_0 \text{ psf} \quad q_{c1N} := \left(q_{c1_it} \right)_0
 \end{aligned}$$

Overburden corrected tip resistance calculations

Compute CRR with Overburden, MSF, and Kdr Corrections

Compute the CRR ($M_w = 7.5$, 1 atm) based on the CPT values:

Cyclic Resistance Ratio (CRR):

$$i := 0 \dots \text{rows}(qc) - 1$$

Correction factor for soils with fines:

$$\Delta q_{c1N_i} := \left(5.4 + \frac{q_{c1N_i}}{16} \right) \cdot \exp \left[1.63 + \frac{9.7}{\text{Fines}_i + 0.01} - \left(\frac{15.7}{\text{Fines}_i + 0.01} \right)^2 \right]$$

Equivalent clean sand corrected tip resistance: $q_{c1Ncs_i} := q_{c1N_i} + \Delta q_{c1N_i}$

$$CRR_1 := \begin{cases} \exp\left[\frac{q_{c1Ncs_i}}{540} + \left(\frac{q_{c1Ncs_i}}{67}\right)^2 - \left(\frac{q_{c1Ncs_i}}{80}\right)^3 + \left(\frac{q_{c1Ncs_i}}{114}\right)^4 - 3\right] & \text{if } I_{c_i} \leq 2.60 \wedge q_{c1Ncs_i} < 211 \\ 2.0 & \text{if } I_{c_i} \leq 2.60 \wedge q_{c1Ncs_i} > 211 \\ 2.0 & \text{otherwise} \end{cases}$$

Overburden Correction Factor (K σ) for Sands:

$$C_{\sigma_i} := \min\left[\frac{1}{37.3 - 8.27 \cdot (\min(q_{c1N_i}, 211))^{0.264}}, 0.3\right]$$

$$K_{\sigma_i} := \begin{cases} \min\left(1 - C_{\sigma_i} \cdot \ln\left(\frac{\sigma_{v0eff_i}}{1tsf}\right), 1.1\right) & \text{if } I_{c_i} \leq 2.60 \\ 1.0 & \text{otherwise} \end{cases}$$

Corrected CRR: $CRR1_1 := CRR_1 \cdot K_{\sigma_i}$

Magnitude Scaling Factor (MSF) [SCDOT 2010, pg. 13-44]:

MSF is dependent on material type and for cyclic softening calculations, two MSF correlations are applicable.

$$MSF_1 := \min(1.80, 6.9 \cdot \exp(-0.25 \cdot M) - 0.058)$$

$$CRR2_1 := CRR1_1 \cdot MSF_1$$

Adjust CRR for Age Correction Factor for Pleistocene Sands [SCDOT, 2010 - pg. 13-60 & 13-61]:

K_{dr} is only applicable for Sands that are of Pleistocene-Age or older.

$$CRR_{final_1} := \begin{cases} CRR2_1 \cdot K_{dr} & \text{if } I_{c_i} \leq 2.60 \wedge Elev_i < Elev_h \\ CRR2_1 & \text{otherwise} \end{cases}$$

Compute CRR with Overburden, MSF, and Kdr Corrections

Compute CSR and FS

Compute the CSR for the Soil Profile

$$\tau_{cyc} := \text{submatrix}(\text{CyclicStress}, 1, \text{rows}(\text{CyclicStress}) - 1, 1, 1) \text{ psf}$$

$d_{cyc} := \text{submatrix}(\text{CyclicStress}, 1, \text{rows}(\text{CyclicStress}) - 1, 0, 0) \text{ ft}$

$\tau_{max} := \text{linterp}(d_{cyc}, \tau_{cyc}, \text{depth})$

$$CSR_i := \frac{0.65 \tau_{max_i}}{\sigma_{v0eff_i}}$$

Compute Factor of Safety

$$FS_i := \begin{cases} 2.00 & \text{if } \text{depth}_i < \text{GWT}_b \\ \min\left(\frac{CRR_{final_i}}{CSR_i}, 2.00\right) & \text{otherwise} \end{cases}$$

▶ Compute CSR and FS

Export Results:

Headers := augment("Depth", "Elevation", "qc1N", "SBT Index", "FScyclic")

Units := augment("ft", "ft NGVD29", "-", "-", "-")

Export := augment $\left(\frac{\text{depth}}{\text{ft}}, \frac{\text{Elev}}{\text{ft}}, \text{qc1N}, I_c, \text{FS}\right)$

Export2 := stack(Headers, Units, Export)

FileName := concat(BoringID, "_Results", ".xlsx")

Export3 := WRITEEXCEL(Export2, FileName)

SPT - based Liquefaction Analysis

BoringID := "SPT-114"

Site Parameters:

Age Correction Factor: $K_{dr} := 1.3$ (Geosyntec, 2013)

Earthquake Magnitude: $M := 7.3$

Site Response Profile: $Prof := "Profile2"$

CyclicStress := $\begin{cases} \text{READEXCEL}("APB_Profile_1.xlsx") & \text{if Prof} = "Profile1" \\ \text{READEXCEL}("APB_Profile_2.xlsx") & \text{if Prof} = "Profile2" \end{cases}$

SPT-Specific data:

Import the SPT-Specific Data in the form of Depth, Blow Count, Visual Classification ("Sand-Like"/"Clay-Like"), fines content, and USCS Classification. Upper two rows contain the headers and units for each field:

Full := READEXCEL(coucat(BoringID, ".xlsx"))

Data := submatrix(Full, 2, rows(Full) - 1, 0, cols(Full) - 1)

depth_l := Data^{<0>} · ft N_{blows} := Data^{<1>} Class := Data^{<2>} Fines := Data^{<3>} USCS := Data^{<4>}

Boring Information:

Boring Elevation: $Elevation := 41.48\text{ft}$ NGVD29

Groundwater Depth: $GWT := 19.1\text{ft}$ bgs

Boring Diameter: $Diameter := 4$ inches

Holocene Elevation: $Elev_h := 19.00\text{ft}$ NGVD29

Energy Calibration: $ER := 88$ % (SCI, 2014)

Sampling Method: $C_S := 1.0$

RodDepth_l := depth_l + 5 ft (Assume 5 ft of rod stick up during SPT test)

Miscellaneous Constants:

Defining external units: $tsf := \frac{\text{tonf}}{\text{ft}^2}$ $kPa := \frac{1}{95.760518} tsf$

▼ Compute Calibration Factors and N60

Compute Calibration Factors

$$C_E := \frac{ER}{60}$$

$$C_B := \begin{cases} 1.0 & \text{if Diameter} \leq 4.0 \\ 1.05 & \text{if } 4.0 < \text{Diameter} < 6.0 \\ 1.15 & \text{otherwise} \end{cases}$$

$$C_R := \begin{cases} \text{for } i \in 0 \dots \text{rows}(\text{depth}_i) - 1 \\ \quad \text{rod}_i \leftarrow 0.75 & \text{if RodDepth}_i \leq 13\text{ft} \\ \quad \text{rod}_i \leftarrow 0.85 & \text{if } 13\text{ft} < \text{RodDepth}_i \leq 20\text{ft} \\ \quad \text{rod}_i \leftarrow 0.95 & \text{if } 20\text{ft} < \text{RodDepth}_i \leq 33\text{ft} \\ \quad \text{rod}_i \leftarrow 1 & \text{otherwise} \\ \text{rod} \end{cases}$$

Compute N₆₀:

$$N_{60} := \begin{cases} \text{for } i \in 0 \dots \text{rows}(\text{depth}_i) - 1 \\ \quad x_i \leftarrow C_B \cdot C_E \cdot C_S \cdot N_{\text{blows}_i} \cdot C_{R_i} \\ x \end{cases}$$

▲ Compute Calibration Factors and N60

▼ Calculation of CN and Effective Overburden Stress

Compute C_N:

Develop Representative Unit Weight Profile

Unit weight values to be assigned based on density and material class:

Adjust according to specific site conditions

- | | |
|--|-----------------------------|
| 1. Coal Combustion Residuals | $\gamma_1 := 100\text{pcf}$ |
| 2. Loose Sands ($N_{\text{blows}} < 10$) | $\gamma_2 := 105\text{pcf}$ |
| 3. Medium Dense Sands ($10 < N_{\text{blows}} < 30$) | $\gamma_3 := 115\text{pcf}$ |
| 4. Dense Sands | $\gamma_4 := 120\text{pcf}$ |
| 5. Soft Clays | $\gamma_5 := 100\text{pcf}$ |
| 6. Chicora Member | $\gamma_6 := 130\text{pcf}$ |
| 7. Williamsburg Formation Clay | $\gamma_7 := 105\text{pcf}$ |

Relate depth to elevation to screen unit weights for Williamsburg Formation Clay

Elev := (Elevation - depth)

WMElev := -8ft

(Approx. Top of Williamsburg Formation Clay)

```

Class2 := | for i ∈ 0..rows(depth) - 1
            |   | yi ← 7
            |   | yi ← 1 if Class1 = "SILT"
            |   | yi ← 2 if Class1 = "SAND" ∧ Nblowsi ≤ 10
            |   | yi ← 3 if Class1 = "SAND" ∧ 10 < Nblowsi < 30
            |   | yi ← 4 if Class1 = "SAND" ∧ 30 < Nblowsi
            |   | yi ← 5 if Class1 = "CLAY" ∧ Elevi > WMElev
            |   | yi ← 6 if Class1 = "CHICORA"
            | y
    
```

Assign unit weight based on soil classification:

```

γfin := | for i ∈ 0..rows(depth) - 1
          |   for m ∈ 1..7
          |     γ2i ← γm if Class2i = m
          | γ2
    
```

γ := γ_{fin} γ_{water} := 62.4pcf

i := 0..rows(depth) - 1

Final Static Pore Pressure Calculation:

$$u_{0_i} := \begin{cases} (\text{depth}_i - \text{GWT}) \cdot \gamma_{\text{water}} & \text{if } \text{depth}_i > \text{GWT} \\ 0 & \text{otherwise} \end{cases}$$

Total and Effective Overburden Pressure Final Calculation:

$$\sigma_{v0_i} := \begin{cases} (\text{depth}_i - \text{depth}_{i-1}) \cdot \left(\frac{\gamma_i + \gamma_{i-1}}{2} \right) + \sigma_{v0_{i-1}} & \text{if } i > 0 \\ \text{depth}_0 \cdot \gamma_0 & \text{otherwise} \end{cases} \quad \sigma_{v0\text{eff}} := \sigma_{v0} - u_0$$

Calculation of C_{NL} (For Liquefaction) [SCDOT, 2010 - pg. 13-48] Calculation limited to a maximum N -value = 46 blows/ft

```

CNLit := | c ← 0
           | "initial CN"
           | for i ∈ 0 .. rows(depth) - 1
           |   CNi ← 1.7
           |   for i ∈ 0 .. rows(depth) - 1
           |     while c < 600
           |       N160Li ← CNi · N60i
           |       CNi ← min [ 1.7, (  $\frac{1 \text{ atm}}{\sigma_{v0\text{eff}_i}$  )(0.784-0.0768 · √(min(46, N160Li))) ]
           |       c ← c + 1
           |     c ← 0
           | (CN N160L)

```

$$C_{NL} := \left(C_{NLit}^{(0)} \right)_0 \quad N_{160_i} := C_{NL_i} \cdot N_{60_i}$$

▣ Calculation of CN and Effective Overburden Stress

▣ Compute N160 for Liquefaction

Compute (N_{160L}) (For Liquefaction):

Correct N_{160} for influence of fines [SCDOT, 2010 pg. 13-51]

```

ΔN160L := | for i ∈ 0 .. rows(depth) - 1
           |   xi ← min [ 5.5, exp [ 1.63 + [  $\frac{9.7}{(\text{Fines}_i + 0.01)}$  ] - [  $\frac{15.7}{(\text{Fines}_i + 0.01)}$  ]2 ] ]
           | x

```

$$N_{160cs_i} := N_{160_i} + \Delta N_{160L_i}$$

Compute N160 for Liquefaction

Compute CRR with Overburden, MSF, and Kdr Corrections

Compute the CRR ($M_w=7.5$, 1 atm) based on the SPT values [SCDOT, 2010 - pg. 13-54 & 13-55 - and is consistent with Idriss and Boulanger 2008]:

$$CRR1_i := \exp \left[\left(\frac{N_{160cs_i}}{14.1} \right) + \left(\frac{N_{160cs_i}}{126} \right)^2 - \left(\frac{N_{160cs_i}}{23.6} \right)^3 + \left(\frac{N_{160cs_i}}{25.4} \right)^4 - 2.8 \right]$$

Overburden Correction Factor (K_{σ}):

$$C_{\sigma_i} := \min \left[\frac{1}{18.9 - 2.55 \cdot (\min(N_{160_i}, 37))^{0.50}}, 0.3 \right]$$

$$K_{\sigma_i} := \min \left(1 - C_{\sigma_i} \cdot \ln \left(\frac{\sigma_{v0eff_i}}{2117 \text{psf}} \right), 1.1 \right)$$

$$CRR2_i := CRR1_i \cdot K_{\sigma_i}$$

Magnitude Scaling Factor (MSF) [SCDOT 2010, pg. 13-44]:

MSF is dependent on material type and for cyclic softening calculations, two MSF correlations are applicable.

$$MSF_i := \min(1.80, 6.9 \cdot \exp(-0.25 \cdot M) - 0.058)$$

$$CRR3_i := CRR2_i \cdot MSF_i$$

Adjust CRR for Age Correction Factor for Pleistocene Sands [SCDOT, 2010 - pg. 13-60 & 13-61]:

K_{dr} is only applicable for Sands that are of Pleistocene-Age (assumed to be below bottom of dike fill):

$$CRR_{final_i} := \begin{cases} CRR3_i \cdot K_{dr} & \text{if } Class_i = \text{"SAND"} \wedge Elev_i < Elev_H \\ CRR3_i & \text{otherwise} \end{cases}$$

Compute CRR with Overburden, MSF, and Kdr Corrections

Compute CSR and FS

Compute the CSR for the Soil Profile

$\tau_{cyc} := \text{submatrix}(\text{CyclicStress}, 1, \text{rows}(\text{CyclicStress}) - 1, 1, 1) \text{ psf}$

$d_{cyc} := \text{submatrix}(\text{CyclicStress}, 1, \text{rows}(\text{CyclicStress}) - 1, 0, 0) \text{ ft}$

$\tau_{max} := \text{interp}(d_{cyc}, \tau_{cyc}, \text{depth})$

$$\text{CSR}_i := \frac{0.65 \tau_{max_i}}{\sigma_{v0eff_i}}$$

Compute Factor of Safety

$$\text{FS}_i := \begin{cases} 2.01 & \text{if } \text{Class}_i = \text{"CHICORA"} \\ 2.01 & \text{if } \text{depth}_i < \text{GWT} \\ 2.01 & \text{if } \text{Class}_i = \text{"CLAY"} \\ \min\left(\frac{\text{CRR}_{final_i}}{\text{CSR}_i}, 2.01\right) & \text{otherwise} \end{cases}$$

-Assume Chicora statum does NOT Liquefy

▲ Compute CSR and FS

▶ Evaluate the Soil Strength Loss (SSL) due to Cyclic Liquefaction or Cyclic Softening: _____

Export Results:

Headers := augment("Depth", "Elevation", "N160", "Class", "FS cyclic")

Units := augment("ft", "ft NGVD29", "-", "-", "-")

Export := augment($\left(\frac{\text{depth}}{\text{ft}}, \frac{\text{Elev}}{\text{ft}}, \text{N160}, \text{Class}, \text{FS}\right)$)

Export2 := stack(Headers, Units, Export)

FileName := concat(BoringID, "_Results", ".xlsx")

Export3 := WRITEEXCEL(Export2, FileName)

Export Liquefaction Results

SPT - based Liquefaction Analysis

BoringID := "SPT-114"

Site Parameters:

Age Correction Factor: $K_{dr} := 1.3$ (Geosyntec, 2013)

Earthquake Magnitude: $M := 7.3$

Site Response Profile: $Prof := "Profile2"$

CyclicStress := $\begin{cases} \text{READEXCEL}("APB_Profile_1.xlsx") & \text{if } Prof = "Profile1" \\ \text{READEXCEL}("APB_Profile_2.xlsx") & \text{if } Prof = "Profile2" \end{cases}$

SPT-Specific data:

Import the SPT-Specific Data in the form of Depth, Blow Count, Visual Classification ("Sand-Like"/"Clay-Like"), fines content, and USCS Classification. Upper two rows contain the headers and units for each field:

Full := READEXCEL(coucat(BoringID, ".xlsx"))

Data := submatrix(Full, 2, rows(Full) - 1, 0, cols(Full) - 1)

depth_l := Data^{<0>} · ft N_{blows} := Data^{<1>} Class := Data^{<2>} Fines := Data^{<3>} USCS := Data^{<4>}

Boring Information:

Boring Elevation: $Elevation := 41.48\text{ft}$ NGVD29

Groundwater Depth: $GWT := 19.1\text{ft}$ bgs

Boring Diameter: $Diameter := 4$ inches

Holocene Elevation: $Elev_h := 19.00\text{ft}$ NGVD29

Energy Calibration: $ER := 88$ % (SCI, 2014)

Sampling Method: $C_S := 1.0$

RodDepth_l := depth_l + 5 ft (Assume 5 ft of rod stick up during SPT test)

Miscellaneous Constants:

Defining external units: $tsf := \frac{tonf}{ft^2}$ $kPa := \frac{1}{95.760518} tsf$

▼ Compute Calibration Factors and N60

Compute Calibration Factors

$$C_E := \frac{ER}{60}$$

$$C_B := \begin{cases} 1.0 & \text{if Diameter} \leq 4.0 \\ 1.05 & \text{if } 4.0 < \text{Diameter} < 6.0 \\ 1.15 & \text{otherwise} \end{cases}$$

$$C_R := \begin{cases} \text{for } i \in 0 \dots \text{rows}(\text{depth}) - 1 \\ \left| \begin{array}{l} \text{rod}_i \leftarrow 0.75 \text{ if RodDepth}_i \leq 13\text{ft} \\ \text{rod}_i \leftarrow 0.85 \text{ if } 13\text{ft} < \text{RodDepth}_i \leq 20\text{ft} \\ \text{rod}_i \leftarrow 0.95 \text{ if } 20\text{ft} < \text{RodDepth}_i \leq 33\text{ft} \\ \text{rod}_i \leftarrow 1 \text{ otherwise} \end{array} \right. \\ \text{rod} \end{cases}$$

Compute N₆₀:

$$N_{60} := \begin{cases} \text{for } i \in 0 \dots \text{rows}(\text{depth}) - 1 \\ \left| \begin{array}{l} x_i \leftarrow C_B \cdot C_E \cdot C_S \cdot N_{\text{blows}_i} \cdot C_{R_i} \end{array} \right. \\ x \end{cases}$$

▲ Compute Calibration Factors and N60

▼ Calculation of CN and Effective Overburden Stress

Compute C_N:

Develop Representative Unit Weight Profile

Unit weight values to be assigned based on density and material class:

Adjust according to specific site conditions

- | | |
|--|-----------------------------|
| 1. Coal Combustion Residuals | $\gamma_1 := 100\text{pcf}$ |
| 2. Loose Sands ($N_{\text{blows}} < 10$) | $\gamma_2 := 105\text{pcf}$ |
| 3. Medium Dense Sands ($10 < N_{\text{blows}} < 30$) | $\gamma_3 := 115\text{pcf}$ |
| 4. Dense Sands | $\gamma_4 := 120\text{pcf}$ |
| 5. Soft Clays | $\gamma_5 := 100\text{pcf}$ |
| 6. Chicora Member | $\gamma_6 := 130\text{pcf}$ |
| 7. Williamsburg Formation Clay | $\gamma_7 := 105\text{pcf}$ |

Relate depth to elevation to screen unit weights for Williamsburg Formation Clay

Elev := (Elevation - depth)

WMElev := -8ft

(Approx. Top of Williamsburg
Formation Clay)

```

Class2 := | for i ∈ 0..rows(depth) - 1
            |   yi ← 7
            |   yi ← 1 if Class1 = "SILT"
            |   yi ← 2 if Class1 = "SAND" ∧ Nblowsi ≤ 10
            |   yi ← 3 if Class1 = "SAND" ∧ 10 < Nblowsi < 30
            |   yi ← 4 if Class1 = "SAND" ∧ 30 < Nblowsi
            |   yi ← 5 if Class1 = "CLAY" ∧ Elevi > WMElev
            |   yi ← 6 if Class1 = "CHICORA"
            | y
    
```

Assign unit weight based on soil classification:

```

γfin := | for i ∈ 0..rows(depth) - 1
          |   for m ∈ 1..7
          |     γ2i ← γm if Class2i = m
          | γ2
    
```

γ := γ_{fin} γ_{water} := 62.4pcf

i := 0..rows(depth) - 1

Final Static Pore Pressure Calculation:

$$u_{0_i} := \begin{cases} (\text{depth}_i - \text{GWT}) \cdot \gamma_{\text{water}} & \text{if } \text{depth}_i > \text{GWT} \\ 0 & \text{otherwise} \end{cases}$$

Total and Effective Overburden Pressure Final Calculation:

$$\sigma_{v0_i} := \begin{cases} (\text{depth}_i - \text{depth}_{i-1}) \cdot \left(\frac{\gamma_i + \gamma_{i-1}}{2} \right) + \sigma_{v0_{i-1}} & \text{if } i > 0 \\ \text{depth}_0 \cdot \gamma_0 & \text{otherwise} \end{cases} \quad \sigma_{v0\text{eff}} := \sigma_{v0} - u_0$$

Calculation of C_{NL} (For Liquefaction) [SCDOT, 2010 - pg. 13-48] Calculation limited to a maximum N-value = 46 blows/ft

```

CNLit := | c ← 0
           | "initial CN"
           | for i ∈ 0 .. rows(depth) - 1
           |   CNi ← 1.7
           |   for i ∈ 0 .. rows(depth) - 1
           |     while c < 600
           |       N160Li ← CNi · N60i
           |       CNi ← min [ 1.7, (  $\frac{1 \text{ atm}}{\sigma_{v0\text{eff}_i}$  )(0.784-0.0768 · √(min(46, N160Li))) ]
           |       c ← c + 1
           |     c ← 0
           | (CN N160L)

```

$$C_{NL} := \left(C_{NLit}^{(0)} \right)_0 \quad N_{160_i} := C_{NL_i} \cdot N_{60_i}$$

▣ Calculation of CN and Effective Overburden Stress

▣ Compute N160 for Liquefaction

Compute (N_{160L}) (For Liquefaction):

Correct N_{160} for influence of fines [SCDOT, 2010 pg. 13-51]

```

ΔN160L := | for i ∈ 0 .. rows(depth) - 1
           |   xi ← min [ 5.5, exp [ 1.63 + [  $\frac{9.7}{(\text{Fines}_i + 0.01)}$  ] - [  $\frac{15.7}{(\text{Fines}_i + 0.01)}$  ]2 ] ]
           | x

```

$$N_{160cs_i} := N_{160_i} + \Delta N_{160L_i}$$

Compute N160 for Liquefaction

Compute CRR with Overburden, MSF, and Kdr Corrections

Compute the CRR ($M_w=7.5$, 1 atm) based on the SPT values [SCDOT, 2010 - pg. 13-54 & 13-55 - and is consistent with Idriss and Boulanger 2008]:

$$CRR1_i := \exp \left[\left(\frac{N_{160cs_i}}{14.1} \right) + \left(\frac{N_{160cs_i}}{126} \right)^2 - \left(\frac{N_{160cs_i}}{23.6} \right)^3 + \left(\frac{N_{160cs_i}}{25.4} \right)^4 - 2.8 \right]$$

Overburden Correction Factor (K_{σ}):

$$C_{\sigma_i} := \min \left[\frac{1}{18.9 - 2.55 \cdot (\min(N_{160_i}, 37))^{0.50}}, 0.3 \right]$$

$$K_{\sigma_i} := \min \left(1 - C_{\sigma_i} \cdot \ln \left(\frac{\sigma_{v0eff_i}}{2117 \text{psf}} \right), 1.1 \right)$$

$$CRR2_i := CRR1_i \cdot K_{\sigma_i}$$

Magnitude Scaling Factor (MSF) [SCDOT 2010, pg. 13-44]:

MSF is dependent on material type and for cyclic softening calculations, two MSF correlations are applicable.

$$MSF_i := \min(1.80, 6.9 \cdot \exp(-0.25 \cdot M) - 0.058)$$

$$CRR3_i := CRR2_i \cdot MSF_i$$

Adjust CRR for Age Correction Factor for Pleistocene Sands [SCDOT, 2010 - pg. 13-60 & 13-61]:

K_{dr} is only applicable for Sands that are of Pleistocene-Age (assumed to be below bottom of dike fill):

$$CRR_{final_i} := \begin{cases} CRR3_i \cdot K_{dr} & \text{if } Class_i = \text{"SAND"} \wedge Elev_i < Elev_H \\ CRR3_i & \text{otherwise} \end{cases}$$

Compute CRR with Overburden, MSF, and Kdr Corrections

Compute CSR and FS

Compute the CSR for the Soil Profile

$\tau_{cyc} := \text{submatrix}(\text{CyclicStress}, 1, \text{rows}(\text{CyclicStress}) - 1, 1, 1) \text{ psf}$

$d_{cyc} := \text{submatrix}(\text{CyclicStress}, 1, \text{rows}(\text{CyclicStress}) - 1, 0, 0) \text{ ft}$

$\tau_{max} := \text{linterp}(d_{cyc}, \tau_{cyc}, \text{depth})$

$$CSR_i := \frac{0.65 \tau_{max_i}}{\sigma_{v0eff_i}}$$

Compute Factor of Safety

$$FS_i := \begin{cases} 2.01 & \text{if } Class_i = \text{"CHICORA"} \\ 2.01 & \text{if } depth_i < \text{GWT} \\ 2.01 & \text{if } Class_i = \text{"CLAY"} \\ \min\left(\frac{CRR_{final_i}}{CSR_i}, 2.01\right) & \text{otherwise} \end{cases}$$

-Assume Chicora statum does NOT Liquefy

▲ Compute CSR and FS

▶ Evaluate the Soil Strength Loss (SSL) due to Cyclic Liquefaction or Cyclic Softening: _____

Export Results:

Headers := augment("Depth", "Elevation", "N160", "Class", "FS cyclic")

Units := augment("ft", "ft NGVD29", "-", "-", "-")

Export := augment($\left(\frac{\text{depth}}{\text{ft}}, \frac{\text{Elev}}{\text{ft}}, N_{160}, \text{Class}, \text{FS}\right)$)

Export2 := stack(Headers, Units, Export)

FileName := concat(BoringID, "_Results", ".xlsx")

Export3 := WRITEEXCEL(Export2, FileName)

Export Liquefaction Results

ATTACHMENT 8


Safety Factor Assessment

CALCULATION PACKAGE COVER SHEET


Client: Santee Cooper **Project:** Winyah Generating Station **Project No.** GSC5242

TITLE OF PACKAGE: **SAFETY FACTOR ASSESSMENT: ASH POND B**

**Calculation Prepared
by:**

Signature		10/10/2016
Name	James McNash, P.E.	Date


**Assumptions &
Procedures Checked
by:**
(peer reviewer)

Signature		10/10/2016
Name	Ming Zhu, Ph.D., P.E. Glenn Rix, Ph.D., P.E.	Date


**Computations Checked
by:**

Signature		10/10/2016
Name	Meena Viswanath, P.E.	Date

**Computations Back-
checked by:**

Signature		10/10/2016
Name	James McNash, P.E.	Date

Approved by:
(pm or designate)

Signature		10/10/2016
Name	Fabian Benavente, P.E.	Date

Approval notes:

Revisions (number and initial all revisions)

No.	Sheet	Date	By	Checked by	Approval
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____

Written by: J. McNash Date: 10/10/2016 Reviewed by: M. Viswanath/M. Zhu Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT

SAFETY FACTOR ASSESSMENT: ASH POND B

INTRODUCTION

This calculation package was prepared as Attachment 8 to the *2016 Surface Impoundment Periodic Safety Factor Assessment Report: Ash Pond B* (Safety Factor Assessment Report) and presents the slope stability analyses for the Ash Pond B perimeter dikes at Winyah Generating Station (WGS). Ash Pond B is a 65-acre surface impoundment, which manages coal combustion residuals (CCRs) in the form of fly ash, boiler slag, and bottom ash produced as by-products during electric generating activities. On 17 April 2015, the United States Environmental Protection Agency (USEPA) published the CCR Rule (40 Code of Federal Regulations (CFR) 257.73). Under the CCR Rule, Ash Pond B is classified as an “existing surface impoundment” and the impoundment owner is required to periodically assess and demonstrate that the impoundment maintains specific safety factors. This calculation package presents the slope stability analysis performed as a part of the periodic safety factor assessment required by §257.73(e)(1) for existing CCR surface impoundments. The remainder of this calculation package presents: (i) safety factor criteria; (ii) methodology; (iii) cross section geometry; (iv) engineering parameters; (v) results; (vi) conclusions; and (vii) references.

SAFETY FACTOR CRITERIA

Slope stability analyses were conducted to assess whether the Ash Pond B perimeter dikes achieve the safety factor (also referred to as “factor of safety”) criteria described within §257.73(e)(1) of the CCR Rule. §257.73(e)(1) requires that:

- (i) *“The calculated static factor of safety under the long-term, maximum storage pool loading condition must equal or exceed 1.50.*
- (ii) *The calculated static factor of safety under the maximum surcharge pool loading condition must equal or exceed 1.40.*
- (iii) *The calculated seismic factor of safety must equal or exceed 1.00.*
- (iv) *For embankments constructed of soils that have susceptibility to liquefaction, the calculated liquefaction factor of safety must equal or exceed 1.20.”*

It is noted that the liquefaction potential analysis results presented in Attachment 7: *Liquefaction Potential Analysis: Ash Pond B* (Liquefaction Package) of this Safety Factor Assessment Report did not indicate that the Ash Pond B dike fill or foundation soils immediately beneath the perimeter dikes are susceptible to liquefaction. Therefore, the liquefaction factor of safety (FS) for

Written by: J. McNash Date: 10/10/2016 Reviewed by: M. Viswanath/M. Zhu Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT

the Ash Pond B perimeter dikes utilizing post-liquefaction residual shear strengths is not required and was not evaluated as a part of this safety factor assessment.

METHODOLOGY

Static Slope Stability

Global slope stability analyses were performed using Spencer's method (Spencer, 1973), as implemented in the computer program SLIDE[®], version 6.037 (Rocscience, 2015). Spencer's method, which satisfies vertical and horizontal force equilibrium as well as moment equilibrium, is considered to be more rigorous than other methods, such as the simplified Janbu method (Janbu, 1973) and the simplified Bishop method (Bishop, 1955).

Both rotational mode (i.e., circular slip surface mode) and non-rotational (i.e., block slip surface mode) were considered during these analyses, and the slip mechanism resulting in the lowest calculated FS is reported. SLIDE[®] generates potential slip surfaces, calculates the FS for each of these surfaces, and identifies the critical slip surface with the lowest calculated FS. Information required for these analyses include the slope geometry, the subsurface soil stratigraphy, the phreatic surface elevation, the external loading conditions, and the engineering properties of subsurface materials.

Seismic Slope Stability

Pseudo-static slope stability analyses were performed to evaluate the seismic performance of the perimeter dike structures using a procedure consistent with Hynes-Griffin and Franklin (1984). The procedure is described as follows:

1. Estimate the maximum horizontal equivalent acceleration (MHEA) for the potential critical slip surfaces of the perimeter dike system based on results from the site response analyses presented in Attachment 6: *Seismic Hazard Evaluation and Site Response Analysis: Ash Pond B* (Site Response Package) of the Safety Factor Assessment Report.
2. Compute the seismic horizontal force coefficient (k_h) using the ratio of the critical acceleration (N) to the peak value of earthquake acceleration (A) based an allowable displacement (u) in which the perimeter dikes are considered stable (from Figure 7 of Hynes-Griffin and Franklin [1984]). The critical acceleration, N, was selected as the k_h for the purposes of this analysis and the MHEA at the depth of the critical slip surface was selected as the peak earthquake acceleration, A.

Written by: J. McNash Date: 10/10/2016 Reviewed by: M. Viswanath/M. Zhu Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT

3. Perform slope stability analysis applying the seismic horizontal force coefficient to compute a horizontal force ($F = k_h \times W$), for each slice based on slice weight (W), and evaluate the resulting FS. If the calculated FS meets or exceeds the target FS (i.e., $FS \geq 1.0$), the slope is considered to be stable and to meet the requirements of the CCR Rule.

It is noted that during pseudo-static slope stability analyses, undrained shear strengths should be reduced by 20% to account for potential strength degradation during cyclic loading (Hynes-Griffin and Franklin, 1984).

CROSS SECTION GEOMETRY

The following section describes the development for the: (i) external geometry, (ii) subsurface stratigraphy; and (iii) water levels and phreatic surface for the cross sections evaluated as a part of this safety factor assessment.

External Geometry

The current height of the Ash Pond B perimeter dikes ranges from approximately 15 feet (ft) adjacent to the Discharge Canal to 21 ft adjacent to the Cooling Pond. The upstream and downstream side slopes range from 2 horizontal to 1 vertical (2H:1V) in the west to 3H:1V adjacent to the Cooling Pond to the east, while the dike crest is typically 12 to 15 ft wide (Thomas and Hutton, 2012). The perimeter dikes of Ash Pond B were raised by approximately 7 ft to their current crest elevation of 41.0 ft NGVD29 in 1999. Design cross sections provided by Paul C. Rizzo & Associates (PCRA, 1993) were utilized in conjunction with topographic survey data to develop the geometry of each cross section in this safety factor assessment.

Four cross sections were developed and evaluated as a part of this safety factor assessment. These cross sections were selected based on the critical slope geometry, engineering parameters of subsurface materials, and phreatic conditions. Cross sections were also selected to evaluate at least one cross section for each of the Ash Pond B perimeter dikes. The external geometry of each cross section was based on a topographic survey prepared by Thomas and Hutton (2012) and a limited bathymetric survey within the Cooling Pond at the downstream toe of the perimeter dikes. Parker Land Surveying, LLC visited WGS in November 2015 to collect survey transects of the Cooling Pond at the base of the Ash Pond B perimeter dikes where the Cooling Pond appeared to be the deepest based on aerial photography and site visits. Contours of the topographic survey were modeled as a triangular-irregular-network (TIN) surface within the computer program AutoCAD[®] and surveyed transects within the Cooling Pond were added to the TIN surface. Four cross sections (Cross Section A through Cross Section D) were developed within AutoCAD[®] and

Written by: J. McNash Date: 10/10/2016 Reviewed by: M. Viswanath/M. Zhu Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT

exported directly into the SLIDE[®] program. The location and extent of each analyzed cross section are depicted in Figure 1.

Subsurface Stratigraphy

The subsurface stratigraphy for each cross section was developed based on soil borings and cone penetration tests conducted as a part of Geosyntec’s 2013 and 2016 subsurface investigations and Paul C. Rizzo Associates’ (PCRA) investigation in 1993 (PCRA, 1993). Generally, the subsurface in the depth of interest for slope stability analyses consists of the following strata (from top to bottom): Dike Fill, Foundation Soils, Chicora Member, and Williamsburg Formation Clay. Further discussion on the development of subsurface conditions can be found in Attachment 5: *Subsurface Stratigraphy and Material Properties: Ash Pond B* (Data Package) of the Safety Factor Assessment Report.

Water Levels:

The CCR Rule requires the evaluation of safety factors considering static and seismic slope stability analyses under long-term “Maximum Normal Storage Pool” conditions and static slope stability analysis under short-term “Maximum Surcharge Pool” conditions. As described within the Hydrologic and Hydraulic (H&H) analysis for Ash Pond B provided in Attachment 1 of this Safety Factor Assessment Report, the water level within Ash Pond B is maintained at an elevation of approximately 34.9 ft National Geodetic Vertical Datum of 1929 (NGVD29) by 4-ft by 4-ft concrete riser structure. Ash Pond B receives stormwater and process water from Ash Pond A through a series of rim ditches and a 30-in diameter corrugated metal pipe and a 48-in diameter smooth steel pipe through the divider dike until it collects in the southern corner of the Ash Pond B. The concrete riser structure in Ash Pond B discharges surface water westward into the Discharge Canal. An operating level of 34.9 ft NGVD29 was selected as the “Maximum Normal Storage Pool” for Ash Pond B. Since Ash Pond B is considered a “Low Hazard Potential” surface impoundment (Geosyntec, 2016), the 100-yr rainfall event was selected as the Inflow Design Flood (IDF), as required by §257.73(d)(1)(B). The maximum surface water elevation within Ash Pond B during and after the IDF was computed as 37.1 ft NGVD29, which was selected as the “Maximum Surcharge Pool” for this safety factor assessment.

The phreatic surface through the perimeter dikes to the downstream toe at the time of this factor of safety assessment was predominantly developed based on water levels collected from CPT sounding dissipation tests, supplemental monitoring wells installed within the perimeter dikes, depth to water measurements, and the Cooling Pond free water elevation. The water level of the Cooling Pond was selected as 19.13 ft NGVD29 based on the operating pool level of the Cooling

Written by: J. McNash Date: 10/10/2016 Reviewed by: M. Viswanath/M. Zhu Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT

Pond required to manage the 25-yr, 24-hr rainfall event and from free water elevation measurements. In both the “Maximum Normal Storage Pool” and “Maximum Surcharge Pool” conditions, the phreatic surface through the Ash Pond B perimeter dikes was assumed to reach steady-state conditions.

Final Cross Section Geometry

The final geometric models implemented within SLIDE[®] for Cross Sections A through D are provided in Figures 2 through 5, respectively.

ENGINEERING PARAMETERS

The following sections describe the engineering parameters selected for the safety factor analyses presented within this calculation package.

Material Parameters

Material parameters for dike fill, foundation soils, and underlying strata have been evaluated in the Data Package (Attachment 5) using in-situ and laboratory data collected in the vicinity of Ash Pond B. Table 1 provides a summary of the material properties selected for each evaluated cross section as a part of this safety factor assessment. Drained shear strength parameters of cross section-specific dike fill and sandy foundation soil were developed, predominantly from in-situ measurements (i.e., Standard Penetration Test (SPT) N-values, etc.) for each section. The interpretation and selection of properties are shown on Figures 6 through 9 for Cross Sections A through D, respectively.

It was assumed that seismic waves generated during a potential seismic event would load clayey foundation soils rapidly enough to induce an undrained loading condition within the clayey soils. In accordance with recommendations made within Hynes-Griffin and Franklin (1984), the selected undrained shear strength values were reduced by 20% for the seismic safety factor case to account for potential cyclic degradation during an earthquake at the Site. Thus, both drained and undrained strength parameters for clayey foundation soils were developed for Cross Sections C and D from in-situ testing and laboratory results, as shown on Figures 8 through 9. Clayey foundation soils are not present in Cross Sections A and B. The perimeter dikes of Ash Pond B were found to consist primarily of well compacted, poorly graded sands and silty sands and thus, were not considered to lose strength during a seismic event.

Written by: J. McNash Date: 10/10/2016 Reviewed by: M. Viswanath/M. Zhu Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT

Seismic Loading and Allowable Displacement

An evaluation of the seismic hazard for WGS and the site response analysis for the Ash Pond B perimeter dikes is presented in the *Seismic Hazard Evaluation and Site Response Analysis: Ash Pond B* (Attachment 6) of this Safety Factor Assessment Report. Within Attachment 6, six ground motions for WGS were evaluated for two representative dike soil profiles for Ash Pond B, and profiles of the cyclic shear stress were computed. These computed cyclic shear stress profiles were utilized to compute the profiles of MHEA in general accordance with Bray et al (1995). Preliminary pseudo-static analyses of the perimeter dikes structures of Ash Pond B indicated that the critical depth of the anticipated slip surface is approximately 20 ft to 30 ft below the dike crest. Thus, the maximum MHEA at the depth of the anticipate critical slip surface was selected assuming the critical slip surface is located at 20 ft, 24 ft, 20 ft, and 29 ft below the dike crest for Cross Sections A through D, respectively. The maximum MHEA from the six ground motions at the critical slip surface depth was selected to compute the k_h during pseudo-static analyses. The MHEA for each ground motion and representative soil profile to a depth of 107 ft bgs is provided in Table 2. MHEAs of 0.068g, 0.062g, 0.063g, and 0.057g were selected for Cross Sections A through D, respectively.

As described in the Methodology section, the k_h must be computed assuming an allowable displacement (u). An allowable displacement of 12 inches (30.48 centimeters) was selected for the Ash Pond B perimeter dike structures. Using the Hynes-Griffin and Franklin (1984) chart and assuming the “Upper Bound” displacement, the ratio of N/A (or $k_h/MHEA$) was conservatively selected as 0.50, as shown in Figure 10. Thus, a k_h of 0.034 was computed for Cross Section A based on Profile 1, and k_h values of 0.031, 0.032, and 0.029 were computed based on Profile 2 for Cross Sections B through D, respectively.

RESULTS

The safety factor evaluation for Cross Sections A through D was performed according to the methodology and parameters outlined within this calculation package, and the results are summarized within Table 3. Computed safety factors were found to exceed the minimum safety factors required by §257.73(e)(1) of the CCR Rule. The critical cross section, i.e., the section with the lowest computed safety factor, was Cross Section C under each of the evaluated conditions. Figures 11 through 13 depict the computed critical values of FS for Cross Section C.

Written by: J. McNash Date: 10/10/2016 Reviewed by: M. Viswanath/M. Zhu Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT

CONCLUSIONS

Based on the assumptions, analyses, and results presented within this calculation package, Ash Pond B at WGS meets the periodic safety factor requirements described within the CCR Rule for existing CCR surface impoundments.

REFERENCES

- Bishop, A. (1955), "The Use of the Slip Circle in the Stability Analysis of Slopes," *Géotechnique*, Volume 5, No. 1, Jan 1955, pp. 7-17.
- Bray, J. D., Augello, A. J., Leonards, G. A., Repetto, P. C., & Byrne, R. J. (1995). "Seismic Stability Procedures for Solid-Waste Landfills." *Journal of Geotechnical Engineering*, 121(2), 139-151.
- Geosyntec Consultants (2016), "Winyah Generating Station: Hazard Classification Memorandum: Ash Pond B".
- Hynes-Griffin, M. and Franklin, A. (1984) "Rationalizing the Seismic Coefficient Method", Department of the Army, Waterways Experiment Station, Corps of Engineers, Vicksburg, Mississippi, Miscellaneous Paper GL-84-14, Jul 1984.
- Janbu, N. (1973), "Slope Stability Computations in Embankment-Dam Engineering", R.C. Hirschfeld and S.J. Poulos, Eds. New York: Wiley, pp. 47-86.
- Paul C. Rizzo Associates, Inc. (1993), "Report: Ash Pond B Dike Elevation: Winyah Generating Station", December 1993.
- Roesscience (2015), "SLIDE[®] – 2-D Limit Equilibrium Slope Stability for Soil and Rock Slopes," User's Guide, Roesscience Software, Inc., Toronto, Ontario, Canada.
- Spencer, E. (1973), "The Thrust Line Criterion in Embankment Stability Analysis," *Géotechnique*, Vol. 23, No. 1, pp. 85-100, March 1973.
- Thomas and Hutton (2012). "Topographic Survey of a Portion of Santee Cooper Winyah Generating Station", prepared for Santee Cooper, 14 January 2014.

Written by: **J. McNash** Date: **10/10/2016** Reviewed by: **M. Viswanath/M. Zhu** Date: **10/10/2016**

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No: **01BT**

TABLES

Written by: J. McNash Date: 10/10/2016 Reviewed by: M. Viswanath/M. Zhu Date: 10/10/2016

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No: **01BT**

Table 1. Selected Material Parameters for Slope Stability Analyses

Material	Total Unit Weight (pcf) ^[2]	Drained Parameters		Undrained Parameters ^[1]	
		ϕ' (°)	c' (psf)	S_u/σ'_{vo}	$S_{u,min}$ (psf)
Dike Fill	125	38 to 40 ^[3]	0	-	-
Clayey Foundation Soils	100	18	250	Varies ^[4]	100
Upper Sandy Foundation Soils	115	36 to 38 ^[3]	0	-	-
Lower Sandy Foundation Soils	115	30 to 32 ^[3]	0	-	-
Chicora	130	50 ^[2]	0	-	-
Williamsburg Formation Clay	105	50 ^[2]	-	-	-
Fly Ash	100	34 ^[2]	0	-	-

Notes:

1. Undrained shear strength parameters for clayey foundation soils were applied for the seismic slope stability case only.
2. The selection of shear strength parameters for Chicora, Williamsburg Formation Clay, and Fly Ash, as well as total unit weights for all materials, is explained in the Data Package.
3. These drained shear strengths (ϕ') vary by location. Interpretation of in-situ results applied in the selection is provided in Figures 6 through 9.
4. The selected undrained strength ratio (S_u/σ'_{vo}) varies between locations and ranges from 0.25 to 0.45 for the selected cross section. Interpretation of in-situ results applied in the selection is provided in Figures 8 and 9.

Written by: J. McNash Date: 10/10/2016 Reviewed by: M. Viswanath/M. Zhu Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT

Table 2. Maximum Equivalent Horizontal Acceleration from Site Response Analysis for Ash Pond B Perimeter Dikes

Representative Profile 1 (Discharge Canal)								Representative Profile 2 (Cooling Pond)							
Maximum Horizontal Equivalent Acceleration (g)								Maximum Horizontal Equivalent Acceleration (g)							
Depth (ft)	BOS-T1	DEL090	RSN8529	Winyah 1	Winyah 2	YER360	Max	Depth (ft)	BOS-T1	DEL090	RSN8529	Winyah 1	Winyah 2	YER360	Max
1.5	0.099	0.094	0.091	0.076	0.103	0.123	0.123	1.5	0.079	0.091	0.083	0.084	0.093	0.107	0.107
5	0.077	0.087	0.082	0.065	0.088	0.100	0.100	5	0.070	0.084	0.076	0.077	0.084	0.096	0.096
7	0.055	0.079	0.071	0.058	0.061	0.083	0.083	7	0.056	0.074	0.061	0.059	0.067	0.078	0.078
9	0.065	0.079	0.071	0.058	0.071	0.083	0.083	9	0.061	0.074	0.065	0.059	0.067	0.080	0.080
13	0.054	0.071	0.061	0.055	0.063	0.073	0.073	13	0.054	0.067	0.062	0.055	0.064	0.069	0.069
16	0.052	0.066	0.056	0.054	0.059	0.070	0.070	17	0.052	0.063	0.058	0.052	0.060	0.065	0.065
17	0.055	0.068	0.055	0.056	0.062	0.072	0.072	20.5	0.050	0.060	0.053	0.051	0.057	0.063	0.063
19.5	0.052	0.065	0.053	0.053	0.058	0.068	0.068	22	0.053	0.062	0.051	0.052	0.056	0.065	0.065
24.5	0.051	0.060	0.051	0.050	0.054	0.063	0.063	24.5	0.051	0.060	0.049	0.050	0.054	0.062	0.062
29.5	0.049	0.054	0.045	0.047	0.049	0.057	0.057	29.5	0.049	0.054	0.046	0.047	0.050	0.057	0.057
34.5	0.048	0.049	0.043	0.044	0.045	0.051	0.051	34.5	0.048	0.049	0.042	0.044	0.045	0.051	0.051
39.5	0.046	0.045	0.041	0.041	0.042	0.047	0.047	39.5	0.046	0.045	0.041	0.041	0.042	0.047	0.047
44.5	0.044	0.042	0.038	0.039	0.040	0.044	0.044	44.5	0.044	0.042	0.038	0.038	0.040	0.043	0.044
49.5	0.050	0.042	0.037	0.039	0.040	0.047	0.050	49.5	0.049	0.041	0.037	0.039	0.040	0.047	0.049
57	0.056	0.043	0.037	0.044	0.040	0.051	0.056	57	0.056	0.042	0.038	0.044	0.040	0.051	0.056
67	0.059	0.046	0.045	0.048	0.040	0.058	0.059	67	0.059	0.048	0.044	0.047	0.040	0.059	0.059
77	0.059	0.051	0.050	0.049	0.044	0.062	0.062	77	0.058	0.051	0.049	0.047	0.045	0.063	0.063
87	0.062	0.054	0.052	0.048	0.045	0.067	0.067	87	0.062	0.053	0.052	0.047	0.047	0.068	0.068
97	0.067	0.054	0.053	0.046	0.045	0.071	0.071	97	0.067	0.054	0.053	0.046	0.046	0.072	0.072
107	0.073	0.055	0.051	0.047	0.044	0.077	0.077	107	0.072	0.054	0.052	0.047	0.044	0.078	0.078

Notes:

1. Cross Section A, located adjacent to the Discharge Canal, was found to have a depth to the critical slip surface of 20 ft. A MHEA of 0.068g was selected for Cross Section A.
2. Cross Section B, Cross Section C, and Cross Section D, located adjacent to the Cooling Pond, were found to have depths to the critical slip surface of 24 ft, 20 ft, and 29 ft, respectively. MHEAs of 0.062g, 0.063g, and 0.057g were selected for Cross Section B, Cross Section C, and Cross Section D, respectively.

Written by: J. McNash Date: 10/10/2016 Reviewed by: M. Viswanath/M. Zhu Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT

Table 3. Summary of Safety Factor Analysis Results

Safety Factor Case	Target FS	Cross Section A	Cross Section B	Cross Section C	Cross Section D
Static - Maximum Normal Storage Pool	1.5	1.97	1.80	<i>1.55^[3]</i>	1.74
Static FS - Maximum Surcharge Pool	1.4	1.91	1.74	<i>1.52^[3]</i>	1.63
Seismic - Maximum Normal Storage Pool	1.0	1.72	1.67	<i>1.04^[3]</i>	1.11
Liquefaction ^[1]	1.2	-	-	-	-


Notes:

1. The liquefaction safety factor was not evaluated since dike fill soils were not found to be liquefiable (Attachment 7).
2. Safety factors between 1.80 and 1.86 for a veneer or surficial slip surface (i.e., less than 2-ft deep) for the Cross Section A static slope stability case were computed but not reported within the above table. Safety factors shown above correspond to deep (i.e., global) slip surfaces.
3. The lowest computed safety factor for each analysis case was *italicized*. Critical FS's for Cross Section C are shown in Figures 10 through 12 as this cross section was computed with the lowest safety factors for the static and seismic slope stability cases.

Written by: **J. McNash** Date: **10/10/2016** Reviewed by: **M. Viswanath/M. Zhu** Date: **10/10/2016**

Client: **Santee Cooper** Project: **Winyah Generating Station** Project/ Proposal No.: **GSC5242** Task No: **01BT**

FIGURES



LEGEND

- GAS
- GAS
- 30
- EXISTING MAJOR GRADE CONTOUR
- EXISTING RAILROAD
- EXISTING WATER
- EXISTING STAFF GAUGE
- GEOSYNTEC CONE PENETRATION TEST
- GEOSYNTEC SOIL BORING
- HISTORICAL BORING
- GROUNDWATER MONITORING WELL
- PIEZOMETER

NOTES:

1. TOPOGRAPHIC SURVEY PROVIDED BY THOMAS & HUTTON DATED 06/26/11 AND REVISED ON 01/14/12.
2. ELEVATIONS FROM THIS SURVEY ARE REFERENCED TO NSVD 1929 DATUM AS DERIVED FROM NGS MONUMENT PIDRDD1957.
3. THE POSITION OF UNDERGROUND UTILITIES SHOWN ON THIS DRAWING IS BASED UPON THE LOCATION OF SURFACE APERTURES AND/OR SURFACE MARKINGS AND SHOULD BE CONSIDERED APPROXIMATE.

CROSS SECTION LOCATION MAP
ASH POND B



FIGURE

1

PROJECT NO. GSC5242 OCTOBER 2018




Figure 2. Cross Section A Geometry during Maximum Normal Operating Pool Conditions (as implemented within SLIDE®)

Notes:

1. The water level at WAP-10 (dike toe) was measured as 21.9 ft NGVD29 on 20 June 2016 (Attachment 5).
2. "Maximum Surcharge Pool" (not shown in this Figure) was computed as 37.1 ft NGVD29 within the Ash Pond B interior, as shown in Attachment 1.

Written by: J. McNash Date: 10/10/2016 Reviewed by: M. Viswanath/M. Zhu Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT




Figure 3. Cross Section B Geometry during Maximum Normal Operating Pool Conditions (as implemented within SLIDE 6)

Note:

1. "Maximum Surcharge Pool" (not shown in this Figure) was computed as 37.1 ft NGVD29 within the Ash Pond B interior, as shown in Attachment 5.

Written by: J. McNash Date: 10/10/2016 Reviewed by: M. Viswanath/M. Zhu Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT




Figure 4. Cross Section C Geometry during Maximum Normal Operating Pool Conditions (as implemented within SLIDE[®])

Notes:

1. The water level at WAP-21 (dike crest) was measured as 26.6 ft NGVD29 on 20 June 2016 (Attachment 5). WAP-21 total depth shown was approximated as well construction information was not available. Water level was interpreted from CPT-135 in 2013.
2. "Maximum Surgecharge Pool" (not shown in this Figure) was computed as 37.1 ft NGVD29 within the Ash Pond B interior, as shown in Attachment 1.

Written by: J. McNash Date: 10/10/2016 Reviewed by: M. Viswanath/M. Zhu Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT




Figure 5. Cross Section D Geometry during Maximum Normal Operating Pool Conditions (as implemented within SLIDE®)

Notes:

1. The water level at WAP-20 (dike crest) was measured as 24.0 ft NGVD29 on 20 June 2016 (Attachment 5). WAP-20 total depth shown was approximated as well construction information was not available. Water level was interpreted from CPT-136 in 2013.
2. "Maximum Surcharge Pool" (not shown in this Figure) was computed as 37.1 ft NGVD29 within the Ash Pond B interior, as shown in Attachment 1.

Written by: J. McNash Date: 10/10/2016 Reviewed by: M. Viswanath/M. Zhu Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT




Figure 6. Subsurface Stratigraphy and Shear Strength Model for Cross Section A

Written by: J. McNash Date: 10/10/2016 Reviewed by: M. Viswanath/M. Zhu Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT




Figure 7. Subsurface Stratigraphy and Shear Strength Model for Cross Section B

Written by: J. McNash Date: 10/10/2016 Reviewed by: M. Viswanath/M. Zhu Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT




Figure 8. Subsurface Stratigraphy and Shear Strength Model for Cross Section C

Notes:

1. Clayey foundation soils were modeled with a $\phi' = 18^\circ$ and a $c' = 250$ psf during static slope stability and with 80% of the $S_u/\sigma'_v = 0.45$ (i.e., $S_u/\sigma'_v = 0.36$) and a $S_{u,min} = 100$ psf during pseudo-static stability analysis (i.e., seismic safety factor).
2. A soil behavior index (I_c) > 2.60 was considered a “clay-like” soil during this evaluation. $I_c < 2.60$ were plotted as zero within the plot of S_u/σ'_v vs. elevation above.

Written by: J. McNash Date: 10/10/2016 Reviewed by: M. Viswanath/M. Zhu Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT




Figure 9. Subsurface Stratigraphy and Shear Strength Model for Cross Section D

Notes:

1. Clayey foundation soils were modeled with a $\phi' = 18^\circ$ and a $c' = 250$ psf during static slope stability and with 80% of the $S_u/\sigma'_v = 0.25$ (i.e., $S_u/\sigma'_v = 0.20$) and a $S_{u,min} = 100$ psf during pseudo-static stability analysis (i.e., seismic safety factor).
2. A soil behavior index ($I_c > 2.60$) was considered a “clay-like” soil during this evaluation. $I_c < 2.60$ were plotted as zero within the plot of S_u/σ'_v vs. elevation above.

Written by: J. McNash Date: 10/10/2016 Reviewed by: M. Viswanath/M. Zhu Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT




Figure 10. Allowable Displacement (u) vs. N/A (from Figure 7 of Hynes-Griffin and Franklin, 1984)

Notes:

1. An allowable deformation (u) of 12 inches (30.48 cm) and the “Upper Bound” curve were selected during these analyses.
2. A ratio of N/A of 0.50 was selected assuming 12 inches of displacement.

Written by: J. McNash Date: 10/10/2016 Reviewed by: M. Viswanath/M. Zhu Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT




Figure 11. Critical Factor of Safety for Cross Section C: Static Factor of Safety - Maximum Normal Storage Pool

Written by: J. McNash Date: 10/10/2016 Reviewed by: M. Viswanath/M. Zhu Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT




Figure 12. Critical Factor of Safety for Cross Section C: Static Factor of Safety - Maximum Surcharge Pool

Written by: J. McNash Date: 10/10/2016 Reviewed by: M. Viswanath/M. Zhu Date: 10/10/2016

Client: Santee Cooper Project: Winyah Generating Station Project/ Proposal No.: GSC5242 Task No: 01BT




Figure 13. Critical Factor of Safety for Cross Section C: Seismic Factor of Safety – Maximum Normal Storage Pool