

**Notice of Exceedance of Groundwater Protection Standards  
Winyah Generating Station, Ash Pond B**

The South Carolina Public Service Authority (Santee Cooper) is implementing the April 17, 2015 U.S. Environmental Protection Agency (U.S. EPA) Federal Coal Combustion Residuals (CCR) Rule (40 CFR § 257 and 261) for the Winyah Generating Station, located in Georgetown County, South Carolina.

In accordance with 40 CFR §257.95(g), Arsenic, Lithium and Molybdenum, Appendix IV constituents, exceeded the groundwater protection standard for one of the wells at the Ash Pond B.