Fugitive Dust Control Report & Effectiveness Assessment

for compliance with

40CFR257: Disposal of Coal Combustion Residuals from Electric Utilities

CCR UNITS:

(located at Winyah Station)

Class 3 Landfill Area 1

Class 3 Landfill Area 2

Ash Pond A

Ash Pond B

Slurry Pond 3 & 4

Sign _____ **Date** 10/13/26

Print Name/Title: Jack W. Huggins, Superintendent Technical Services, Winyah Generating Station

I. EFFECTIVENESS ASSESSMENT

The CCR Fugitive Dust Control Plan was reviewed by evaluating all documented sources and control measures.

II. FUGITIVE DUST CONTROL MEASURES

Fugitive dust control measures were put into place based on routine visual inspections of all CCR Units by plant personnel. When excess fugitive dust was observed, plant personnel took action to minimize dust by executing control measures as described in Table 1 below:

Table 1: List of CCR Units

CCR Unit	Description	Control Measures
Ash Pond A	Wind Erosion and Haul Roads	- Maintain vegetation - Water Truck on haul roads
Ash Pond B	Excavating, Wind Erosion, Haul Roads	- Maintain vegetation - Water Truck on haul roads
Slurry Pond 3 & 4	Excavating, Wind Erosion, Haul Roads	- Water Truck on haul roads
Class 3 Landfill Area 2	Wind Erosion, Haul Roads	- Ash Conditioning - Interim Cover - Water Truck - Water Tank - Vegetative Cover
Class 3 Landfill Area 1	Landfill was closed July 24,2024	Final Cover Placement

III. CITIZEN COMPLAINTS

N/A

IV. CORRECTIVE ACTIONS

N/A